



Report Date: 02/01/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Alachua**

License Number: 1150248

**EIM THAI**

License Type: Food

213 NW 10 AVE , GAINESVILLE 32601

Insp Date: 01/25/2025

Inspection Number: 1299466

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher on the wall in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103532

**CREEKS 19TH**

License Type: Food

11440 TURKEY CREEK BLVD , ALACHUA 32615

Insp Date: 01/27/2025

Inspection Number: 3498929

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Portable fire extinguisher next to dish machine.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1150277

**LA MARACUCHA FOOD & SERVICES**

License Type: Food

1025 W UNIVERSITY AVE , GAINESVILLE 32601

Insp Date: 01/24/2025

Inspection Number: 1297778

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by reach in freezer in the red recharge zone. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/01/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Bay**

License Number: 1305809

**BEEF O'BRADY'S**

License Type: Food

11226 HUTCHISON BLVD , PANAMA CITY BEACH 32407

Insp Date: 01/31/2025

Inspection Number: 3487043

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed large LP gas tank by side door to dining area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506340

**YAAKUZA JAPANESE THAI SAKE BAR**

License Type: Food

925 N COURTENAY PKWY #8 , MERRITT ISLAND 32953

Insp Date: 01/27/2025

Inspection Number: 3482844

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Operator built a wall near restroom to block access to rear exit door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505555

**TASTE OF INDIA**

License Type: Food

606 N WICKHAM RD , MELBOURNE 32935

Insp Date: 01/30/2025

Inspection Number: 3492646

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Several lp tanks stored in banquet room.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/01/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Brevard**

License Number: 1505717

**PANERA BREAD STORE 2782**

License Type: Food

275 E EAU GALLIE BLVD , INDIAN HARBOUR BEACH 32937

Insp Date: 01/24/2025

Inspection Number: 3558059

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Gauge in recharge by back door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506931

**POKE POKE**

License Type: Food

66 S ORLANDO AVE , COCOA BEACH 32931

Insp Date: 01/24/2025

Inspection Number: 3494991

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank in rear storage area  
\*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506340

**YAAKUZA JAPANESE THAI SAKE BAR**

License Type: Food

925 N COURTENAY PKWY #8 , MERRITT ISLAND 32953

Insp Date: 01/30/2025

Inspection Number: 3482844

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Operator built a wall near restroom to block access to rear exit door - From follow-up inspection 2025-01-30: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/01/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Broward**

License Number: 1624717

**PETER'S ICE CREAM**

License Type: Food

6333 MIRAMAR PKWY , MIRAMAR 33023

Insp Date: 01/31/2025

Inspection Number: 3558092

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed fryers not under a hood system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1625559

**LOLORESTAURANT**

License Type: Food

2708 WEST OAKLAND PARK BLVD , OAKLAND PARK 33311

Insp Date: 01/28/2025

Inspection Number: 3503186

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed new cover for electrical panel too short to cover entire exposed wiring. 5-6 inches of wiring exposed.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Broward**

License Number: 1625188

**FT LAUDERDALE HOME2**

License Type: Food

315 NW 1 AVENUE , FORT LAUDERDALE 33301

Insp Date: 01/31/2025

Inspection Number: 3450542

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1623090

**CHIMNEY HOUSE**

License Type: Food

701 W LAS OLAS BLVD , FORT LAUDERDALE 33312

Insp Date: 01/28/2025

Inspection Number: 3503022

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. At the front line

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Broward**

License Number: 1622356

**EL PATIO COLOMBIAN RESTAURANT**

License Type: Food

5416 S SR 7 (US 441) , HOLLYWOOD 33314

Insp Date: 01/29/2025

Inspection Number: 3558296

Insp Type: Routine - Food

Disposition: Administrative  
recommended

complaint

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. The silver extinguisher on the cook line.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620474

**BIG CITY TAVERN**

License Type: Food

609 E LAS OLAS BLVD , FORT LAUDERDALE 33301

Insp Date: 01/29/2025

Inspection Number: 3441752

Insp Type: Routine - Food

Disposition: Administrative  
recommended

complaint

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.12 by office door. Inspector will email inspection report to fire marshal for review.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Citrus**

License Number: 1901407

**HARDEE'S**

License Type: Food

16 NE US 19 , CRYSTAL RIVER 34429

Insp Date: 01/27/2025

Inspection Number: 3486204

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in front counter area next to tea machines

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001271

**TIJUANA FLATS BURRITO CO**

License Type: Food

1647 CR 220 #103 , FLEMING ISLAND 32003

Insp Date: 01/29/2025

Inspection Number: 3488989

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher under front counter is in the recharge zone. \*\*Repeat Violation\*\*

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Collier**

License Number: 2103190

**PATINELLA'S CHICKEN GRILL**

License Type: Food

1201 PIPERS BLVD #16 , NAPLES 34110

Insp Date: 01/27/2025

Inspection Number: 3502114

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-02-4

Observed electrical outlet covers missing in restrooms.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2101657

**MIRAMARE RISTORANTE LLC**

License Type: Food

4236 GULF SHORE BLVD N , NAPLES 34103

Insp Date: 01/30/2025

Inspection Number: 3456524

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. In preparation area near ice machines, observed electrical switches exposed and not secure. - From follow-up inspection 2025-01-30: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337590

**MASTER CREPES**

License Type: Food

3905 NW 107 AVE STE 106 , DORAL 33178

Insp Date: 01/29/2025

Inspection Number: 3494451

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher near exit of front counter in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Dade**

License Number: 2328086

**BLUE MATISSE RESTAURANT**

License Type: Food

2505 NW 87 AVE , MIAMI 21610

Insp Date: 01/30/2025

Inspection Number: 3483323

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 059615 11/17/24. 021243 01/09/25. As per chief engineer units had been inspected and pending certificates to be issued.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2328087

**IHC BALLROOM & MEETING ROOMS**

License Type: Food

2505 NW 87 AVE , MIAMI 21610

Insp Date: 01/30/2025

Inspection Number: 3559055

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. As per chief engineer units had been inspected and pending certificates to be issued.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Dade**

License Number: 2332613

**SOHO HOUSE CECCONIS RESTAURANT**

License Type: Food

4385 COLLINS AVE , MIAMI 33140

Insp Date: 01/28/2025

Inspection Number: 3492439

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2332615

**8TH FLOOR BAR**

License Type: Food

4385 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 01/28/2025

Inspection Number: 3492232

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Dade**

License Number: 2333644

**COURTYARD BY MARRIOTT SOUTH HOMESTEAD**

License Type: Food

2905 NE 9 ST , HOMESTEAD 33033

Insp Date: 01/28/2025

Inspection Number: 3496820

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expired certificate.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2334410

**BAR FLAMENCO**

License Type: Food

1695 NW 111 AVE , SWEETWATER 33172

Insp Date: 01/31/2025

Inspection Number: 3485702

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 4 boiler certificates expire 08/22/2024. As per chief engineering inspection for all four units performed on 09/06/2024 by Hartford steam boiler and certificates has been delayed.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Dade**

License Number: 2336808

**HOTEL INDIGO MIAMI BRICKELL/ ATWELL SUITES MIAMI  
BRICKELL**

License Type: Food

145 SW 11 STREET , MIAMI 33130

Insp Date: 01/27/2025

Inspection Number: 3489704

Insp Type: Routine - Food

Disposition: Inspection Completed - No  
Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler  
certificate available for boiler. For reporting purposes only.  
Observed boiler with 700 BTU no certificate provided.  
\*\*Repeat Violation\*\*

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be  
kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit  
throughout the building. The insurance inspectors boiler report is required annually  
for power boilers and high pressure/high temperature boilers and biannually for low  
pressure steam or vapor heating boilers and shall be posted in the boiler room. For  
reporting purposes only.

License Number: 2329736

**SOHO BEACH HOUSE**

License Type: Food

4385 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 01/28/2025

Inspection Number: 1129045

Insp Type: Routine - Food

Disposition: Inspection Completed - No  
Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler  
certificate available for boiler. For reporting purposes only.  
Expired boiler certificates.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be  
kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit  
throughout the building. The insurance inspectors boiler report is required annually  
for power boilers and high pressure/high temperature boilers and biannually for low  
pressure steam or vapor heating boilers and shall be posted in the boiler room. For  
reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Dade**

License Number: 2332801

**LA SANTA TAQUERIA BRICKELL LLC**

License Type: Food

1250 S MIAMI AVE UNIT 107 , MIAMI 33130

Insp Date: 01/29/2025

Inspection Number: 3502250

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

51-04-4

No child labor law poster. For reporting purposes only.

Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.

License Number: 2652832

**EL MESÓN COLOMBIANO**

License Type: Food

7244 BLANDING BLVD , JACKSONVILLE 32244

Insp Date: 01/31/2025

Inspection Number: 1313479

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

51-04-4

No child labor law poster. For reporting purposes only.

Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Duval**

License Number: 2615770

**MOES SOUTHWEST GRILL #243**

License Type: Food

10478 SAN JOSE BLVD UNIT 1 , JACKSONVILLE 32257

Insp Date: 01/24/2025

Inspection Number: 3501903

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Rear exit blocked by boxes. Moved by manager. \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615487

**STONER'S PIZZA JOINT NORTH JACKSONVILLE**

License Type: Food

11565 N MAIN ST STE 200 , JACKSONVILLE 32218

Insp Date: 01/29/2025

Inspection Number: 3496307

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.At back door, wood plank over door. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Duval**

License Number: 2614901

**SEÑORITAS MEXICAN KITCHEN**

License Type: Food

6426 BOWDEN RD #206 , JACKSONVILLE 32216

Insp Date: 01/27/2025

Inspection Number: 3564994

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Back kitchen exit door blocked with food delivery from today. Employee moving items \*\*Corrective Action Taken\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2603805

**ENKELANA CAFFE**

License Type: Food

3861 BAYMEADOWS RD , JACKSONVILLE 32217

Insp Date: 01/28/2025

Inspection Number: 3502695

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Large propane tank in rear kitchen. Removed by manger. \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Duval**

License Number: 2600573

**SAN JOSE CO CLUB D R**

License Type: Food

7529 SAN JOSE BLVD , JACKSONVILLE 73524

Insp Date: 01/31/2025

Inspection Number: 3496109

Insp Type: Routine - Food

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.No current is a boiler certificate .(Per website , Establishment certificate is current.) \*\*Repeat Violation\*\*

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2616289

**GEMMA FISH + OYSTER**

License Type: Food

2039 HENDRICKS AVE UNIT 111 , JACKSONVILLE 32207

Insp Date: 01/24/2025

Inspection Number: 3489480

Insp Type: Routine - Food

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.5 by side entrance

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Flagler**

License Number: 2800714

**BED AND BREAKFAST BY THE SEA**

License Type: Food

1536 S OCEANSHORE DR , FLAGLER BEACH 32136

Insp Date: 01/24/2025

Inspection Number: 3498353

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Missing electrical cover on outlet beside hand washing sink in dry storage.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800721

**BARNHILLS**

License Type: Food

202 S CENTRAL AVE , FLAGLER BEACH 32136

Insp Date: 01/24/2025

Inspection Number: 3496493

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Electrical outlet is missing cover in storage area of kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Hendry**

License Number: 3650076

**PEREZ FRUIT CUP AND MORE LLC**

License Type: Food

420 E COWBOY WAY , LABELLE 33935

Insp Date: 01/27/2025

Inspection Number: 1299698

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800804

**DIMITRI'S FAMILY RESTAURANT**

License Type: Food

2710 KENILWORTH BLVD , SEBRING 33870

Insp Date: 01/28/2025

Inspection Number: 3455525

Insp Type: Routine - Food

Disposition: Emergency order recommended

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher located towards back of kitchen in the red.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Highlands**

License Number: 3800804

**DIMITRI'S FAMILY RESTAURANT**

License Type: Food

2710 KENILWORTH BLVD , SEBRING 33870

Insp Date: 01/28/2025

Inspection Number: 3455525

Insp Type: Routine - Food

Disposition: Emergency  
recommended

order

Violation Code

47-02-4

Observation

Observed scorch marks around electrical outlet. For reporting purposes only. Observed in kitchen next to reach in cooler, scorch marks on top of electrical outlet.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800981

**SUNSET GRILLE**

License Type: Food

2650 US HWY 27 S , SEBRING 33870

Insp Date: 01/29/2025

Inspection Number: 3440437

Insp Type: Routine - Food

Disposition: Emergency  
recommended

order

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed approximately 4 propane tanks inside their dry storage area.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/01/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Highlands**

License Number: 3800804

**DIMITRI'S FAMILY RESTAURANT**

License Type: Food

2710 KENILWORTH BLVD , SEBRING 33870

Insp Date: 01/29/2025

Inspection Number: 3455525

Insp Type: Routine - Food

Disposition: Emergency Order Callback  
Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.Observed fire extinguisher located towards back of kitchen in the red.  
- From follow-up inspection 2025-01-29: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918377

**POKEWORKS 004**

License Type: Food

2223 N WEST SHORE BLVD STE 230-B , TAMPA 33607

Insp Date: 01/27/2025

Inspection Number: 3491659

Insp Type: Routine - Food

Disposition: Inspection Completed - No  
Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.Observed at fire extinguisher located on wall next to 3-compartment sink.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

---

**Hillsborough**

License Number: 3919169

**PALIHOUSE HYDE PARK VILLAGE**

License Type: Food

1509 W SWANN AVE , TAMPA 33606

Insp Date: 01/29/2025

Inspection Number: 3491781

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Counter top grill added to kitchen without a hood system. Manager unplugged grill and discontinued use of grill. \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

---

License Number: 3905611

**APOLLO BEACH DINER**

License Type: Food

6048 N US HWY 41 , APOLLO BEACH 33572

Insp Date: 01/30/2025

Inspection Number: 3496489

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Exit door blocked with racks of bread.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/01/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Hillsborough**

License Number: 3916677

**LA ESQUINA SABROSA RESTAURANT**

License Type: Food

2730 W WATERS AVE , TAMPA 33614

Insp Date: 01/28/2025

Inspection Number: 3495871

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Kitchen exit blocked by a speed cart and trash can.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4100961

**NETTIES ROADSIDE RESTAURANT**

License Type: Food

2555 27 AVE , VERO BEACH 32960

Insp Date: 01/29/2025

Inspection Number: 3445459

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Grill top across from hood system. Heavy build up of grease on wall and electrical outlets

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4101020

**CHILI'S RESTAURANT #394**

License Type: Food

940 US HWY 1 , VERO BEACH 05950

Insp Date: 01/27/2025

Inspection Number: 3489707

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only.At front counter next to small flip top cooler

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Indian River**

License Number: 4100961

**NETTIES ROADSIDE RESTAURANT**

License Type: Food

2555 27 AVE , VERO BEACH 32960

Insp Date: 01/30/2025

Inspection Number: 3445459

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Grill top across from hood system. Heavy build up of grease on wall and electrical outlets - From follow-up inspection 2025-01-30: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4400071

**MI VIEJO LLC**

License Type: Food

530 S FLETCHER AVE , MAYO 32066

Insp Date: 01/31/2025

Inspection Number: 3500220

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.Fire extinguisher on wall in back of kitchen, near back door gauge in red.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Lake**

License Number: 4509077

**LONGHORN STEAKHOUSE**

License Type: Food

1275 E HWY 50 , CLERMONT 34711

Insp Date: 01/24/2025

Inspection Number: 3493961

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only.-extinguisher beside hand sink by dish area

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4509034

**JERSEY MIKE'S SUB SHOP**

License Type: Food

1685 N HANCOCK RD UNIT 104 , MINNEOLA 34715

Insp Date: 01/24/2025

Inspection Number: 3458581

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only.-back door, multiple boxes

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Lee**

License Number: 4605263

**WENDY'S**

License Type: Food

8661 COMMONS WAY , ESTERO 33928

Insp Date: 01/27/2025

Inspection Number: 3580003

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

47-03-4

Observation

Observed electrical wiring in disrepair. For reporting purposes only. Observed wiring box for 3 compartment sink rusting thru.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4607759

**ICE SSSSCREAMIN**

License Type: Food

1017 CAPE CORAL PKY E STE A , CAPE CORAL 33904

Insp Date: 01/27/2025

Inspection Number: 3580014

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Lee**

License Number: 4651544

**BEAU'S TEX MEX**

License Type: Food

16371 CORPORATE COMMERCE WAY , FORT MYERS 33913

Insp Date: 01/31/2025

Inspection Number: 1297847

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-01-4

Observation

No portable fire extinguisher present. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605719

**BURGER KING #15194**

License Type: Food

4738 COLONIAL BLVD , FORT MYERS 33966

Insp Date: 01/29/2025

Inspection Number: 3491195

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Kitchen exit/path blocked w/5 garbage bin. Operator removed the garbage bin. \*\*Corrected On-Site\*\*

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Lee**

License Number: 4651544

**BEAU'S TEX MEX**

License Type: Food

16371 CORPORATE COMMERCE WAY , FORT MYERS 33913

Insp Date: 01/31/2025

Inspection Number: 1297847

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

47-03-4

Observation

Observed electrical wiring in disrepair. For reporting purposes only. Outlet left of entrance to vehicle with exposed wiring.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4650736

**ARIAS'S PUPUSAS**

License Type: Food

1501 ORTIZ AVE , FORT MYERS 33905

Insp Date: 01/25/2025

Inspection Number: 1292113

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tanks stored within structure. \*\*Repeat Violation\*\*

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/01/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Levy**

License Number: 4800167

**HARDEE'S**

License Type: Food

1024 N YOUNG BLVD , CHIEFLAND 32626

Insp Date: 01/24/2025

Inspection Number: 3483324

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher on wall at front counter gauge in red.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5203090

**HARDEE'S OF DUNNELLON**

License Type: Food

11564 N WILLIAMS ST , DUNNELLON 34432

Insp Date: 01/29/2025

Inspection Number: 3502267

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Gauge on fire extinguisher on wall by office in red zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811356

**BORDER GRILL FRESH-MEX**

License Type: Food

5695 WEST VINELAND RD STE A , ORLANDO 32819

Insp Date: 01/24/2025

Inspection Number: 3491163

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. By back door by restrooms.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Orange**

License Number: 5811703

**CARIBBEAN SHACK LLC**

License Type: Food

805 S KIRKMAN RD SUITE 106 , ORLANDO 32811

Insp Date: 01/27/2025

Inspection Number: 3504327

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. One in back kitchen area

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5816243

**B1305**

License Type: Food

4700 W SAND LAKE RD , ORLANDO 32819

Insp Date: 01/31/2025

Inspection Number: 3422234

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. BTU 400,000

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Orange**

License Number: 5811588

**CHIPOTLE MEXICAN GRILL #821**

License Type: Food

464 N ALAFAYA TRL STE 111 , ORLANDO 32828

Insp Date: 01/31/2025

Inspection Number: 3488019

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Boxes all the way to the exit door .Operator removed it . \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807114

**HAVANNA'S #2 RESTAURANT**

License Type: Food

1325 W WASHINGTON ST STE-A1 , ORLANDO 32805

Insp Date: 01/24/2025

Inspection Number: 3484668

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Push cart blocking exit door. Operator removed. \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Orange**

License Number: 5810149

**BOMA FLAVORS OF AFRICA AT DAKL**

License Type: Food

2901 OSCEOLA PKWY , BAY LAKE 01000

Insp Date: 01/30/2025

Inspection Number: 3571078

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.Expired 1/18/25.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5815736

**PESTANA ORLANDO SUITES LAKE BUENA VISTA**

License Type: Food

11942 RAVALLLO RESORT DR , ORLANDO 32836

Insp Date: 01/31/2025

Inspection Number: 3484783

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.Observed no copy of boiler certificates, Person in charge did not know concerning boilers.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Orange**

License Number: 5805044

**KRES RESTAURANT**

License Type: Food

17 W CHURCH ST , ORLANDO 32801

Insp Date: 01/30/2025

Inspection Number: 3495302

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.2 Gas cans stored in downstairs storage area. Operator immediately removed \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804437

**MILLENIA CAFE & CATERING**

License Type: Food

4303 VINELAND ROAD #F18 , ORLANDO 32811

Insp Date: 01/27/2025

Inspection Number: 3494788

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.3 gas tanks in back storage area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Orange**

License Number: 5815853

**SCHWEINI'S DELICATESSEN**

License Type: Food

108 S MAIN ST , WINTER GARDEN 34787

Insp Date: 01/24/2025

Inspection Number: 3446342

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814679

**OSPHERE**

License Type: Food

407 E CENTRAL BLVD , ORLANDO 32801

Insp Date: 01/29/2025

Inspection Number: 3484765

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator immediately removed - From follow-up inspection 2025-01-22: \*\*Time Extended\*\* - From follow-up inspection 2025-01-29: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Osceola**

License Number: 5904844

**HOKKAIDO CHINESE & JAPANESE**

License Type: Food

5737 W IRLO BRONSON MEMORIAL HWY , KISSIMMEE 34746

Insp Date: 01/30/2025

Inspection Number: 3579992

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Dry storage

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Palm Beach**

License Number: 6009055

License Type: Food

**FOUR SEASONS RESORT PALM BEACH BANQUET KITCHEN**

2800 S OCEAN BLVD , PALM BEACH 05540

Insp Date: 01/27/2025

Inspection Number: 3490523

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6009436

License Type: Food

**FOUR SEASONS RESORT PALM BEACH EMPLOYEE CAFE**

2800 S OCEAN BLVD , PALM BEACH 05540

Insp Date: 01/27/2025

Inspection Number: 3490436

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Pinellas**

License Number: 6218152

**KOGI GRILL**

License Type: Food

7500 49 ST N , PINELLAS PARK 33781

Insp Date: 01/24/2025

Inspection Number: 3494594

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguishers across restrooms yellow gauge in recharge zone.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217275

**WAREHOUSE DELI**

License Type: Food

141 STEVENS AVE STE 8 , OLDSMAR 34677

Insp Date: 01/31/2025

Inspection Number: 3488453

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator is cooking bacon on a small table top flat top griddle with no hood system. Smoke is present in establishment. Discussed with operator to discontinue use of flat top griddle.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Pinellas**

License Number: 6218152

**KOGI GRILL**

License Type: Food

7500 49 ST N , PINELLAS PARK 33781

Insp Date: 01/24/2025

Inspection Number: 3494594

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Stainless steel push cart with equipment stored on it blocking pathway to back door exit. Manager moved items to unblock area. \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216306

**TAQUITOS MEXICAN**

License Type: Food

9617 BAY PINES BLVD , ST PETERSBURG 33708

Insp Date: 01/28/2025

Inspection Number: 3491094

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 15 lb propane tanks in rear storage room, relocated outside \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6251427

**C & J BBQ**

License Type: Food

13255 118 ST N , LARGO 33778

Insp Date: 01/24/2025

Inspection Number: 1291375

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-01-4

- From initial inspection : No portable fire extinguisher present by exit door . For reporting purposes only. - From follow-up inspection 2025-01-24: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Putnam**

License Number: 6400924

**VELCHOFF'S CORNER**

License Type: Food

105 N 2 ST STE D , PALATKA 32177

Insp Date: 01/29/2025

Inspection Number: 3482626

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Inside the prep area, table top fryer turned on with no hood system present.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6400934

**LA RAZA SNACKS LLC**

License Type: Food

234 S SUMMIT ST , CRESCENT CITY 32112

Insp Date: 01/24/2025

Inspection Number: 3440210

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a one burner and a pot of hot oil on table by 3 compartment sink with no hood. Operator stated that she cooks chips in oil.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Sarasota**

License Number: 6804971

**GIUSEPPE'S RISTORANTE AND PIZZERIA**

License Type: Food

103 TRIPLE DIAMOND BLVD UNIT 2 , NORTH VENICE 34275

Insp Date: 01/29/2025

Inspection Number: 3502054

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher near the wait station gauge in red zone. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805733

**ART OVATION HOTEL**

License Type: Food

1255 N PALM AVE , SARASOTA 34236

Insp Date: 01/27/2025

Inspection Number: 3493661

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.5 propane tank stored in the hallway next to the back exit.Manager placed the tanks outside. \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6550211

**AREPA LIFE**

License Type: Food

121 YACHT CLUB DR , SAINT AUGUSTINE 32084

Insp Date: 01/29/2025

Inspection Number: 1296420

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.Observed no portable fire extinguisher on truck.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



## Division of Hotels &amp; Restaurants

**Fire Observations Reporting***FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***St. Johns**

License Number: 6550211

**AREPA LIFE**

License Type: Food

121 YACHT CLUB DR , SAINT AUGUSTINE 32084

Insp Date: 01/29/2025

Inspection Number: 1296420

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed hood system in truck not on and not functioning per person in charge. Person in charge is using fryers and flat top grill that is producing grease laden vapors and smoke.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6501723

**BRONX HOUSE PIZZA**

License Type: Food

880 SR A1A S #8 , PONTE VEDRA BEACH 32082

Insp Date: 01/28/2025

Inspection Number: 3574407

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

51-04-4

No child labor law poster. For reporting purposes only.

Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.





Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

St. Lucie

License Number: 6603087

**FUSION CUISINE RESTAURANT A INC**

License Type: Food

1721 AVE D , FORT PIERCE 34950

Insp Date: 01/28/2025

Inspection Number: 3495683

Insp Type: Routine - Food

Disposition: Emergency recommended

order

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top commercial fryer not rated for suppression system. Spoke with fire department and must remove fryer and partial board and use commercial fryer as intended for suppression system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6603087

**FUSION CUISINE RESTAURANT A INC**

License Type: Food

1721 AVE D , FORT PIERCE 34950

Insp Date: 01/28/2025

Inspection Number: 3495683

Insp Type: Routine - Food

Disposition: Emergency recommended

order

Violation Code

Observation

Violation Citation

49-01-4

Flammables stored/debris present in storage room. For reporting purposes only. Generator stored in storage area, cannot be stored in building.

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.



Report Date: 02/01/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**St. Lucie**

License Number: 6603087

**FUSION CUISINE RESTAURANT A INC**

License Type: Food

1721 AVE D , FORT PIERCE 34950

Insp Date: 01/29/2025

Inspection Number: 3495683

Insp Type: Routine - Food

Disposition: Emergency Order Callback  
Time Extension

Violation Code

Observation

Violation Citation

49-01-4

- From initial inspection : Flammables stored/debris present in storage room. For reporting purposes only. Generator stored in storage area, cannot be stored in building. - From follow-up inspection 2025-01-29: Power washer stored inside \*\*Time Extended\*\*

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 7407046

**BRUNOS PIZZA**

License Type: Food

1254 OCEAN SHORE BLVD , ORMOND BEACH 32176

Insp Date: 01/27/2025

Inspection Number: 3579848

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-full size fryer and table top flat grill in back kitchen area. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407616

**KNUCKLE SANDWICH DELI AND CATERING PIERSON FL**

License Type: Food

138 E SR 40 , PIERSON 32180

Insp Date: 01/31/2025

Inspection Number: 3579398

Insp Type: Food-Licensing Inspection

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-table top fryers -flat grill in use to cook burgers.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/01/2025

## Division of Hotels &amp; Restaurants

**Fire Observations Reporting**

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE &amp; LODGING ESTABLISHMENTS

**Volusia**

License Number: 7401545

**PIZZA HUT**

License Type: Food

500 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 01/27/2025

Inspection Number: 3483716

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

46-04-4

Exit door locked. For reporting purposes only.-marked fire exit next to restrooms, locked and unable to be opened.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407497

**JACKIES JAMAICA POT**

License Type: Food

996 DERBYSHIRE RD , DAYTONA BEACH 32117

Insp Date: 01/24/2025

Inspection Number: 3486407

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-table top fryer in use.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407539

**BLAZE PIZZA #1302**

License Type: Food

1405 CORNERSTONE BLVD RETAIL D , DAYTONA BEACH 32117

Insp Date: 01/28/2025

Inspection Number: 3470582

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

46-01-4

Marked exit double door in disrepair. Per manager west door of the double door is locked because it will fall off and they have a new door coming next week to be installed. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/01/2025

**Volusia**

License Number: 7407216

**IHOP RESTAURANT #36-221**

License Type: Food

155 BILL FRANCE BLVD , DAYTONA BEACH 32114

Insp Date: 01/30/2025

Inspection Number: 3490460

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

49-01-4

Wood stored in water heater room. For reporting purposes only.

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 7407841

**AVANU ON FLAGLER**

License Type: Food

392 FLAGLER AVE , NEW SMYRNA BEACH 32169

Insp Date: 01/31/2025

Inspection Number: 3491102

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. Back exit near stairs. High chair in front of door inside; beer keg and cart laden with propane tanks obstructing door on the outside. For reporting purposes only. - From follow-up inspection 2025-01-31: Large platform truck cart outside behind exterior outward swinging door \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407491

**ROCK BOTTOM RESTAURANT & BREWERY**

License Type: Food

1864 VICTORY CIRCLE , DAYTONA BEACH 32114

Insp Date: 01/29/2025

Inspection Number: 3494761

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

49-01-4

2 LP tanks stored in on bottom floor of stairway near marked exit. For reporting purposes only.

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.