



Report Date: 03/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Bay

License Number: 1305504

SANDPIPER BEACON BEACH RESORT'S COCONUTS

License Type: Food

17458 FRONT BEACH RD , PANAMA CITY BEACH 32413

Insp Date: 03/10/2025

Inspection Number: 3578441

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher in server station I recharge zone. Operator replaced with a new extinguisher.
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1306045

FORD'S GARAGE

License Type: Food

601 S PIER PARK SR STE 103 , PANAMA CITY BEACH 32413

Insp Date: 03/12/2025

Inspection Number: 3499840

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class by back door in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1501684

CROWNE PLAZA

License Type: Food

2605 N HWY A1A , MELBOURNE 32903

Insp Date: 03/11/2025

Inspection Number: 3558953

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver extinguisher in kitchen next to cold side. **Corrective Action Taken**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1617982

WENDY'S #02077

License Type: Food

10265 STERLING RD , COOPER CITY 33330

Insp Date: 03/12/2025

Inspection Number: 3571528

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-Observed exit door blocked with cardboard boxes.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1624693

SHIPUDIM

License Type: Food

5650 STIRLING RD STE 6 , HOLLYWOOD 33021

Insp Date: 03/12/2025

Inspection Number: 3583373

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit door blocked

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623007

595 TIKI BAR AND GRILL

License Type: Food

2775 BURRIS RD 2A , DAVIE 33314

Insp Date: 03/13/2025

Inspection Number: 3567269

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Near bathrooms

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Broward

License Number: 1619969

SAKE THAI & SUSHI BAR

License Type: Food

4401 SHERIDAN ST #1 , HOLLYWOOD 33021

Insp Date: 03/11/2025

Inspection Number: 3466190

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at fire extinguisher in prep area near back door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1622616

OAKWOOD STADIUM 18

License Type: Food

2800 OAKWOOD BLVD , HOLLYWOOD 33020

Insp Date: 03/07/2025

Inspection Number: 3460431

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at kitchen fire extinguisher

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Broward

License Number: 1610753

WENDY'S 1949

License Type: Food

3535 HOLLYWOOD BLVD , HOLLYWOOD 33021

Insp Date: 03/07/2025

Inspection Number: 3563401

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by hand sink at dish washing area in red under charged zone. **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1626142

YIP

License Type: Food

849 SEABREEZE BLVD STE K107 , FORT LAUDERDALE 33316

Insp Date: 03/10/2025

Inspection Number: 3560432

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone, next to hand wash sink. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1623384

LEMONICA

License Type: Food

1817 NORTH YOUNG CIRCLE , HOLLYWOOD 33020

Insp Date: 03/14/2025

Inspection Number: 3434654

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. On cook line induction burner used to cook shrimp. Not under hood system

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1625680

SUSHI HOUSE

License Type: Food

5818 STIRLING RD , HOLLYWOOD 33021

Insp Date: 03/12/2025

Inspection Number: 3576781

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryers in use no hood system

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623007

595 TIKI BAR AND GRILL

License Type: Food

2775 BURRIS RD 2A , DAVIE 33314

Insp Date: 03/14/2025

Inspection Number: 3567269

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Near bathrooms - From follow-up inspection 2025-03-14: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Collier

License Number: 2103380

FELIPE'S MEXICAN TAQUERIA

License Type: Food

4255 9 ST N , NAPLES 34103

Insp Date: 03/12/2025

Inspection Number: 3497084

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone near by cook line. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2319651

EL SARTEN RESTAURANT & LOUNGE

License Type: Food

5904 W 20 AVE , HIALEAH 33016

Insp Date: 03/10/2025

Inspection Number: 3492735

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335732

TOPGOLF USA MIAMI GARDENS

License Type: Food

17321 NW 7 AVE , MIAMI GARDENS 33169

Insp Date: 03/11/2025

Inspection Number: 3560117

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. At the time of the inspection observed water heating device with a maximum input of 499990 btu. No boiler certificate provided.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Dade

License Number: 2337510

FIRST WATCH RESTAURANT #0499

License Type: Food

3737 NW 87TH AVE STE 108 , DORAL 33166

Insp Date: 03/07/2025

Inspection Number: 3559201

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone located inside kitchen. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336904

SEEME CAFE

License Type: Food

180 NW 183 ST STE 103 , MIAMI GARDENS 33169

Insp Date: 03/10/2025

Inspection Number: 3488513

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed pot with cooking oil on a 3 burner stove attached to a propane tank next to the 3 compartment sink with no hood system. Operator removed burner, and propane tank from the establishment.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Dade

License Number: 2332046

ALOFT MIAMI DADELAND

License Type: Food

7600 N KENDALL DR , MIAMI 33156

Insp Date: 03/14/2025

Inspection Number: 3567228

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed countertop fryer on prep table not under hood system.
Repeat Violation

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320006

WHITNEY'S RESTAURANT

License Type: Food

9090 S DADELAND BLVD , MIAMI 67820

Insp Date: 03/07/2025

Inspection Number: 3560321

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL98799, FL98798, FL 123243, FL123244 with not boiler certification

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Dade

License Number: 2335951

TOPGOLF USA DORAL

License Type: Food

11850 NW 22 ST , MIAMI 33182

Insp Date: 03/10/2025

Inspection Number: 3560640

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
Repeat Violation

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2336904

SEEME CAFE

License Type: Food

180 NW 183 ST STE 103 , MIAMI GARDENS 33169

Insp Date: 03/10/2025

Inspection Number: 3488513

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***DeSoto**

License Number: 2400327

YIYI'S BARS, BEERS, CIGARS AND DELI SHOP

License Type: Food

11 W MAGNOLIA ST , ARCADIA 34266

Insp Date: 03/13/2025

Inspection Number: 3453184

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a flat top grill and fryer on the counter without a hood suppression system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615014

AL SHAMI

License Type: Food

8606 BAYMEADOWS RD STE 22-23 , JACKSONVILLE 32256

Insp Date: 03/12/2025

Inspection Number: 3582433

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Two tabletop fryers observed on prep table not under hood in kitchen. Observed grease buildup on wall.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2652718

FOOD WOW OF JAX

License Type: Food

5960 RICHARD ST , JACKSONVILLE 32216

Insp Date: 03/13/2025

Inspection Number: 1291894

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) . For reporting purposes only. Propane tanks hooked up to food truck not in cages or secure to truck. Tanks on floor near truck

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Duval

License Number: 2613391

UNCLE GENES SOUL & SEAFOOD CAFE

License Type: Food

5123-4 TIMUQUANA RD , JACKSONVILLE 32210

Insp Date: 03/13/2025

Inspection Number: 3499589

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.Observed fire extinguisher with gauge in overcharge zone on wall by rear exit of establishment.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615074

TIMUQUANA COUNTRY CLUB - THE GROVE

License Type: Food

4028 TIMUQUANA RD , JACKSONVILLE 32210

Insp Date: 03/12/2025

Inspection Number: 3440777

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.Observed fire extinguisher with gauge in recharge zone by kitchen entrance.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2615383

LA NOPALERA MEXICAN RESTAURANT

License Type: Food

1434 HENDRICKS AVE , JACKSONVILLE 32207

Insp Date: 03/11/2025

Inspection Number: 3566054

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.By cook line **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800821

METRO DINER

License Type: Food

250 PALM COAST PKWY NE STE 205 , PALM COAST 32137

Insp Date: 03/10/2025

Inspection Number: 3499301

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.By cart. Person in charge moved cart. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800632

OUTBACK STEAKHOUSE #1040

License Type: Food

45 PLAZA DR , PALM COAST 32137

Insp Date: 03/13/2025

Inspection Number: 3564623

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.By boxes. Person in charge removed all boxes. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Hendry

License Number: 3600523

CACTUS MEX

License Type: Food

512 COWBOY WAY , LABELLE 33935

Insp Date: 03/14/2025

Inspection Number: 3494580

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-04-4

Observation

Exit door locked. For reporting purposes only. Observed emergency fire exit doors locked. **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Hillsborough

License Number: 3905946

MANDY'S RESTAURANT

License Type: Food

4025 W WATERS AVE STE 101 , TAMPA 33614

Insp Date: 03/11/2025

Inspection Number: 3568618

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Sandwich press machine not under hood suppressing system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913010

PHO QUYEN VIETNAMESE CUISINE

License Type: Food

8404 W HILLSBOROUGH AVE , TAMPA 33615

Insp Date: 03/10/2025

Inspection Number: 3488803

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer on cookline prep table.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Lee

License Number: 4606909

WALLY'S DELI

License Type: Food

8024 ALICO ROAD UNIT B , FORT MYERS 33912

Insp Date: 03/14/2025

Inspection Number: 3559596

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. In back of kitchen , marked exit blocked with trash bin and clean rag bin. Operator cleared the exit.
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4607082

DRURY INN & SUITES - FORT MYERS

License Type: Food

9950 UNIVERSITY PLAZA DR , FORT MYERS 33913

Insp Date: 03/12/2025

Inspection Number: 3452068

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certification expired, 124540 05/18/2023.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Lee

License Number: 4607058

JIMMIE THE BEEF GUY

License Type: Food

3664 CLEVELAND AVE , FORT MYERS 33901

Insp Date: 03/13/2025

Inspection Number: 3568985

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator moved item outside. **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4800125

WILLARDS

License Type: Food

3490 SE CR 337 , MORRISTON 32668

Insp Date: 03/12/2025

Inspection Number: 3566844

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher gauge in red in back of kitchen, near bar entrance.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Marion

License Number: 5202067

GOLDEN CORRAL

License Type: Food

2111 SW COLLEGE RD , OCALA 34471

Insp Date: 03/13/2025

Inspection Number: 3582965

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Emergency exit in back of kitchen blocked with empty boxes

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5501104

SEAGLASS

License Type: Food

41 BEACH LAGOON RD , AMELIA ISLAND 32034

Insp Date: 03/10/2025

Inspection Number: 3500053

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler jurisdiction #131447 expired on 12/02/2024. Establishment has invoice showing that new certificate has been paid and are awaiting new certificate. **Corrective Action Taken**

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Nassau

License Number: 5501185

COASTAL PIZZA

License Type: Food

1916 S 14 ST , FERNANDINA BEACH 32034

Insp Date: 03/13/2025

Inspection Number: 3568903

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Entrance door by booths blocked by chairs. Chairs moved. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500835

FLORA BELLE

License Type: Food

41 BEACH LAGOON RD , FERNANDINA BEACH 32034

Insp Date: 03/10/2025

Inspection Number: 3499801

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler jurisdiction #131447 expired on 12/02/2024. Establishment has invoice showing that new certificate has been paid and are awaiting new certificate. **Corrective Action Taken**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Report Date: 03/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Nassau

License Number: 5501102

OCEAN SIDE GRILL

License Type: Food

51 BEACH LAGOON RD , AMELIA ISLAND 32034

Insp Date: 03/10/2025

Inspection Number: 3500212

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler jurisdiction #131447 expired on 12/02/2024. Establishment has invoice showing that new certificate has been paid and are awaiting new certificate. **Corrective Action Taken**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5814274

LA CARRAIA

License Type: Food

7600 DR PHILLIPS BLVD SUITE #38 , ORLANDO 32819

Insp Date: 03/11/2025

Inspection Number: 3450499

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site** **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Orange

License Number: 5856471

BAYSIDE BITES

License Type: Food

1590 EVERMORE WAY , ORLANDO 32836

Insp Date: 03/11/2025

Inspection Number: 1314194

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

45-01-4

Observation

portable fire extinguisher present. For reporting purposes only.Observed no tag classification 3A40BC must be inspected and dated before mobile unit in operation.Spoke to Chef concerning fire extinguisher.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809223

UNIVERSAL CINEMARK

License Type: Food

6000 UNIVERSAL BLVD STE 740 , ORLANDO 32819

Insp Date: 03/14/2025

Inspection Number: 3461882

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Under per lock machine outside beer cooler
Corrected On-Site

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Orange

License Number: 5814155

BLU CAFE

License Type: Food

9401 W COLONIAL DR STE 546 , OCOEE 34761

Insp Date: 03/11/2025

Inspection Number: 3558813

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator immediately removed to outside
Corrected On-Site

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900434

WENDY'S #3482

License Type: Food

915 W VINE ST , KISSIMMEE 34741

Insp Date: 03/12/2025

Inspection Number: 3461933

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Exit door at back of kitchen blocked with empty boxes. **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Palm Beach

License Number: 6010556

THAI BASIL

License Type: Food

10311 SOUTHERN BLVD , ROYAL PALM BEACH 33411

Insp Date: 03/11/2025

Inspection Number: 3571789

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Exit door blocked by mop sink and rice container. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6021448

POLLO TROPICAL #168

License Type: Food

21852 S SR 7 , BOCA RATON 33428

Insp Date: 03/13/2025

Inspection Number: 3583455

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge at back door in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Pinellas

License Number: 6217242

CEDARS GRILL

License Type: Food

6549 54 AVE N , ST.PETERSBURG 33709

Insp Date: 03/14/2025

Inspection Number: 3505206

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top vertical broiler for cooking gyro cones on prep table in kitchen with grease laden vapors not located under a hood system **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217413

BUFFET CITY

License Type: Food

1030 58 ST N , ST PETERSBURG 33710

Insp Date: 03/10/2025

Inspection Number: 3558607

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. In front separate dining room area blocked with high chairs. And a piece of wood panel nailed to doorway in dry storage area.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 03/15/2025

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6217413

BUFFET CITY

License Type: Food

1030 58 ST N , ST PETERSBURG 33710

Insp Date: 03/10/2025

Inspection Number: 3558607

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/15/2025

Sarasota

License Number: 6806191

JANIES AMMAN

License Type: Food

1400 DR MLK JR WAY UNIT 107 , SARASOTA 34234

Insp Date: 03/13/2025

Inspection Number: 3583387

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

46-04-4

Observation

Exit door locked. For reporting purposes only. Observed two out of their three fire exit doors not unlocked. Operator states he has to get the key from their landlord.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805580

CUBA 1958

License Type: Food

1766 MAIN ST , SARASOTA 34236

Insp Date: 03/11/2025

Inspection Number: 3566784

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 5 propane tanks stored in the kitchen area. Owner placed the tanks outside the establishment.
Corrected On-Site

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Seminole

License Number: 6905177

BREWLANDO SANFORD

License Type: Food

400 S SANFORD AVE , SANFORD 32771

Insp Date: 03/11/2025

Inspection Number: 3582954

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room.
For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6904634

DAYS INN

License Type: Food

8245 S US HWY 17-92 , FERN PARK 32730

Insp Date: 03/11/2025

Inspection Number: 3447009

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.-
per State Fire Marshall website, boiler certificate expired 11/18/24.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Report Date: 03/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

St. Johns

License Number: 6502245

TIJUANA FLATS

License Type: Food

41 SETTLEMENT DR STE 501 , PONTE VEDRA 32081

Insp Date: 03/12/2025

Inspection Number: 3483271

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Rear exit door blocked by garbage can. Moved by manager.
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6605149

HAVANA GEORGE CAFE

License Type: Food

100 SOUTH 2 STREET SUITE 102 , FORT PIERCE 34950

Insp Date: 03/12/2025

Inspection Number: 3496867

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Counter top fryer in preparation room. Employee they have good system in a box, waiting for approval from landlord to install. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.