



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/12/2025

Duval

License Number: 2613429

SAVOR JACKSONVILLE ARENA CLUB

License Type: Food

300 A PHILIP RANDOLPH BLVD , JACKSONVILLE 32202

Insp Date: 04/05/2025

Inspection Number: 3429247

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.099864, mgr showed me the inspection from 10/31/24 but no certification yet, the fire marshal website still shows it expired on 11/8/24

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2613432

SAVOR JACKSONVILLE MAIN COMMISSARY

License Type: Food

300 A PHILIP RANDOLPH BLVD , JACKSONVILLE 32202

Insp Date: 04/05/2025

Inspection Number: 3569818

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.099864, mgr showed me the inspection from 10/31/24 but no certification yet, the fire marshal website still shows it expired on 11/8/24

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/12/2025

Duval

License Number: 2613424

SAVOR STAND 109

License Type: Food

300 A PHILIP RANDOLPH BLVD , JACKSONVILLE 32202

Insp Date: 04/05/2025

Inspection Number: 3474232

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 099864, mgr showed me the inspection from 10/31/24 but no certification yet, the fire marshal website still shows it expired on 11/8/24

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2613420

SAVOR JACKSONVILLE 7 BRIDGES PIZZA 305

License Type: Food

300 A PHILIP RANDOLPH BLVD , JACKSONVILLE 32202

Insp Date: 04/05/2025

Inspection Number: 3466327

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 099864, mgr showed me the inspection from 10/31/24 but no certification yet, the fire marshal website still shows it expired on 11/8/24

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/12/2025

Duval

License Number: 2613421

SAVOR JACKSONVILLE GATEWAY GRILL #320

License Type: Food

300 A PHILIP RANDOLPH GATEWAY BLVD , JACKSONVILLE 32202

Insp Date: 04/05/2025

Inspection Number: 3472487

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.099864, mgr showed me the inspection from 10/31/24 but no certification yet, the fire marshal website still shows it expired on 11/8/24

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2613422

SAVOR JACKSONVILLE GATEWAY GRILL 302

License Type: Food

300 A PHILIP RANDOLPH BLVD , JACKSONVILLE 32202

Insp Date: 04/05/2025

Inspection Number: 3429256

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.099864, mgr showed me the inspection from 10/31/24 but no certification yet, the fire marshal website still shows it expired on 11/8/24

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/12/2025

Duval

License Number: 2614808

CONFETTIS

License Type: Food

301 W BAY ST STE 220 , JACKSONVILLE 32202

Insp Date: 04/04/2025

Inspection Number: 3568085

Insp Type: Routine - Food

Disposition: Administrative complaint
recommended

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By mop sink

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5750077

MA DEL REFUGIO BERUMEN NIETO

License Type: Food

1600 HWY 70 E , OKEECHOBEE 34972

Insp Date: 04/04/2025

Inspection Number: 1314625

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.