



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Alachua

License Number: 1102456

MCDONALDS

License Type: Food

1030 E UNIVERSITY AVE , GAINESVILLE 32601

Insp Date: 04/15/2025

Inspection Number: 3476768

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher outside of office the yellow arrow is in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305966

CANOPY ROAD CAFE

License Type: Food

12805 US HWY 98 E , INLET BEACH 32413

Insp Date: 04/17/2025

Inspection Number: 3562507

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. 2 fire extinguishers stored under hand wash sink on make/cook line.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1303388

EDGEWATER BEACH RESORT CONFR

License Type: Food

11212 W FRONT BEACH RD , PANAMA CITY BCH 73603

Insp Date: 04/14/2025

Inspection Number: 3562435

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. LP tanks stored in dry storage. Manager placed tanks outside during inspection. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Broward

License Number: 1618060

TACO BELL # 134

License Type: Food

3500 W BROWARD BLVD , FORT LAUDERDALE 33312

Insp Date: 04/17/2025

Inspection Number: 3585725

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to restroom

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1622326

WAVES BAR & GRILL

License Type: Food

321 N FORT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 04/18/2025

Inspection Number: 3585458

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Operator provided invoice for North Tower boiler.
Corrective Action Taken **Repeat Violation**

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Broward

License Number: 1622542

SAJNA INDIAN CUISINE

License Type: Food

1933 HOLLYWOOD BLVD , HOLLYWOOD 33020

Insp Date: 04/15/2025

Inspection Number: 3585498

Insp Type: Complaint Full

Disposition: Emergency recommended

order

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623139

EL REY DE LA MEDIALUNA

License Type: Food

3253 HOLLYWOOD BLVD , HOLLYWOOD 33021

Insp Date: 04/15/2025

Inspection Number: 3579651

Insp Type: Routine - Food

Disposition: Emergency recommended

order

Violation Code

Observation

Violation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only. Gasoline container stored under triple sink near water heater. Operator removed **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 04/19/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Collier

License Number: 2101858

WHISKEY PARK

License Type: Food

3380 MERCANTILE AVE , NAPLES 34104

Insp Date: 04/17/2025

Inspection Number: 3578466

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Emergency exit blocked in front dry storage area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2103340

MAINE SHACK

License Type: Food

6434 NAPLES BLVD. SUITE 404 , NAPLES 34109

Insp Date: 04/18/2025

Inspection Number: 3575243

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed two fire extinguishers away from designated location.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2103618

MIZU SUSHI & THAI

License Type: Food

5979 PINE RIDGE RD , NAPLES 34119

Insp Date: 04/11/2025

Inspection Number: 3578045

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed a large propane tank stood inside the kitchen. Operator placed it outside. **Corrected On-Site** **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Dade

License Number: 2335079

LEMON PEPPERS

License Type: Food

2701 NW 54TH ST , MIAMI 33142

Insp Date: 04/18/2025

Inspection Number: 3562853

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By the office.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326341

PAELLA PARTY

License Type: Food

16155 SW 117 AVE STE 8 , MIAMI 33177

Insp Date: 04/11/2025

Inspection Number: 3577704

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed a LP tank inside the kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337316

EMILY AND PHILLIP'S CREPERIE

License Type: Food

9420 NW 41 ST UNIT 111 , DORAL 33178

Insp Date: 04/18/2025

Inspection Number: 3585706

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Dade

License Number: 2334447

LA MAMUCHI RESTAURANT

License Type: Food

3610 NW 183 ST , MIAMI GARDENS 33056

Insp Date: 04/18/2025

Inspection Number: 3585562

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

49-03-4

Observation

Flammables stored/debris present in boiler room. For reporting purposes only.

Violation Citation

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 2319899

TWO SISTERS

License Type: Food

50 ALHAMBRA PLAZA , CORAL GABLES 33134

Insp Date: 04/15/2025

Inspection Number: 3559445

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 093786/093787/093788/093789. All expired 02/13/2025

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Dade

License Number: 2319901

LOBBY LOUNGE

License Type: Food

50 ALHAMBRA PLAZA , CORAL GABLES 33134

Insp Date: 04/15/2025

Inspection Number: 3559207

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 093786/093787/093788/093789. All expired 02/13/2025.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2319902

EMPLOYEE CAFETERIA

License Type: Food

50 ALHAMBRA PLAZA , CORAL GABLES 33134

Insp Date: 04/15/2025

Inspection Number: 3559447

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 093786/093787/093788/093789. All expired 02/13/2025.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Dade**

License Number: 2337590

MASTER CREPES

License Type: Food

3905 NW 107 AVE STE 106 , DORAL 33178

Insp Date: 04/14/2025

Inspection Number: 3494451

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher near exit of front counter in the recharge zone. - From follow-up inspection 2025-04-14: Observed fire extinguisher near exit of front counter in the recharge zone. **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2333307

FIRST HONG KONG CAFE

License Type: Food

117 SE 2 STREET , MIAMI 33131

Insp Date: 04/11/2025

Inspection Number: 3565267

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

51-04-4

- From initial inspection : No child labor law poster. For reporting purposes only. - From follow-up inspection 2025-04-11: **Time Extended**

Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

DeSoto

License Number: 2400088

AZUL TEQUILA MEXICAN RESTAURANT LLC

License Type: Food

1121 E OAK ST , ARCADIA 34266

Insp Date: 04/15/2025

Inspection Number: 3503960

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-05-4

Observation

Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed 2 fire extinguishers on floor.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608566

J J'S CAFE

License Type: Food

6622 SOUTHPOINT DR S , JACKSONVILLE 32216

Insp Date: 04/18/2025

Inspection Number: 3585091

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator has flat top grill for cooking eggs & chicken with no hood system

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Hardee

License Number: 3500210

WENDYS 8590

License Type: Food

1440 N US 17 , WAUCHULA 33873

Insp Date: 04/16/2025

Inspection Number: 3498310

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in the red next to hand washing sink in the kitchen.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Hernando

License Number: 3701187

TASTE OF NEW ORLEANZ

License Type: Food

809 S BROAD ST , BROOKSVILLE 34601

Insp Date: 04/15/2025

Inspection Number: 3575288

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Counter top fryer not under hood system to the left of the cook line. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3701208

DELI WORLD

License Type: Food

701 W JEFFERSON ST , BROOKSVILLE 34601

Insp Date: 04/15/2025

Inspection Number: 3576551

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed griddle with squeeze bottle of oil stored to the right of the cooking equipment with no hood suppression system installed.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Hillsborough

License Number: 3919330

SMASHED BUN BURGER

License Type: Food

6113 N FLORIDA AVE , TAMP 33604

Insp Date: 04/15/2025

Inspection Number: 3585595

Insp Type: Food-Licensing Inspection

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3919131

EINSTEIN BROS. BAGELS

License Type: Food

10442 STELLING DR , RIVERVIEW 33578

Insp Date: 04/15/2025

Inspection Number: 3497025

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Back door blocked with boxes. Manager unblocked back door at time of inspection. **Corrected On -Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Hillsborough

License Number: 3906436

COURTYARD RESTAURANT

License Type: Food

3805 W CYPRESS AVE , TAMPA 33607

Insp Date: 04/11/2025

Inspection Number: 3493533

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Both boiler reports have been expired.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 3918380

NAANS INDIAN GRILL AND BAR

License Type: Food

2010 TOWN CENTER BLVD , BRANDON 33511

Insp Date: 04/17/2025

Inspection Number: 3440766

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed Propane tank attached to flat top on cook line away from hood system

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Hillsborough

License Number: 3916505

JERK PIT

License Type: Food

1939 E FLETCHER AVE , TAMPA 33612

Insp Date: 04/16/2025

Inspection Number: 3441592

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

51-04-4

No child labor law poster. For reporting purposes only.

Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.

License Number: 3906785

ITALIAN DREAM CAFE

License Type: Food

4300 WEST CYPRESS STE 110 , TAMPA 33607

Insp Date: 04/18/2025

Inspection Number: 3440758

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. 2 countertop fryers, a griddle and 2 press grills used on front service line. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Lee

License Number: 4605263

WENDY'S

License Type: Food

8661 COMMONS WAY , ESTERO 33928

Insp Date: 04/14/2025

Inspection Number: 3585468

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed wiring box next to the three compartment sink rusting with holes in it. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5428370

SQUARE GROUPER-ISLAMORADA

License Type: Food

80460 OVERSEAS HIGHWAY , ISLAMORADA 33036

Insp Date: 04/16/2025

Inspection Number: 3575311

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

At bar entrance the Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 04/19/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Nassau

License Number: 5501180

FIRST LOVE BREWING

License Type: Food

22 S 8 ST #5 , FERNANDINA BEACH 32034

Insp Date: 04/18/2025

Inspection Number: 3575559

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.No boiler certificate could be presented.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5814373

SUS HI EATSTATION

License Type: Food

1830 E COLONIAL DR STE A , ORLANDO 32803

Insp Date: 04/11/2025

Inspection Number: 3585386

Insp Type: Complaint Full

Disposition: Inspection Completed - No
Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Table top frying outside hood area.Operator moved table back under hood system **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Orange

License Number: 5810733

P F CHANG'S CHINA BISTRO

License Type: Food

4200 CONROY RD , ORLANDO 32839

Insp Date: 04/17/2025

Inspection Number: 3572498

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. On cook line

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805780

COURTYARD ORLANDO INTERNATIONAL DRIVE - CONVENTION CENTER

License Type: Food

8600 AUSTRIAN CT , ORLANDO 32819

Insp Date: 04/18/2025

Inspection Number: 3574499

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. /FL130444, 093796/both expired 1/19/2025.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Orange

License Number: 5811227

OLD CUBAN CAFE

License Type: Food

1672 N GOLDENROD RD , ORLANDO 32807

Insp Date: 04/15/2025

Inspection Number: 3560099

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 propane gas tanks in back storage

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Palm Beach

License Number: 6019453

TWO TOMATOES

License Type: Food

12040 S JOG RD UNIT 13 , BOYNTON BEACH 33437

Insp Date: 04/14/2025

Inspection Number: 3585243

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6010593

LESSING'S AT KRAVIS CENTER

License Type: Food

701 OKEECHOBEE BLVD , WEST PALM BEACH 16323

Insp Date: 04/17/2025

Inspection Number: 3575173

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Not available at time of inspection.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Pasco

License Number: 6113661

TROPICAL SMOOTHIE CAFE

License Type: Food

23673 SR 54 STE E1 , LUTZ 33559

Insp Date: 04/17/2025

Inspection Number: 3459174

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Discussed with manager.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Pinellas

License Number: 6218436

OZ CHOICE

License Type: Food

180 Race Tra RACE TRACK RD. , OLDSMAR 34677

Insp Date: 04/12/2025

Inspection Number: 3579717

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment using fryers with no hood suppression system. Spoke with Ross with the Oldsmar fire department who provided me with the number to the Fire Marshall Brian Ludeker 813-749-1202 who is off today. I will contact on Monday

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217885

NITALLY'S THAIMEX CUISINE

License Type: Food

1163 DR MLK JR STREET , ST. PETERSBURG 33701

Insp Date: 04/16/2025

Inspection Number: 3569424

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 propane tanks larger than 2.7 lbs inside next to bar **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Seminole

License Number: 6903956

WING STOP

License Type: Food

1050 SR 436 , CASSELBERRY 32707

Insp Date: 04/11/2025

Inspection Number: 3568908

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-rear exit door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903509

WAH YOAN CHINESE RESTAURANT

License Type: Food

3385 S US HWY 17-92 STSE 141 , CASSSELBERRY 32707

Insp Date: 04/18/2025

Inspection Number: 3573711

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-rear exit door locked

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 04/19/2025

Volusia

License Number: 7407860

FIVE STAR PIZZA

License Type: Food

1290 E NORMANDY BLVD UNIT 2, DELTONA 32725

Insp Date: 04/16/2025

Inspection Number: 3439778

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked by security bar.
For reporting purposes only. **Corrected On-Site**
Repeat Violation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407860

FIVE STAR PIZZA

License Type: Food

1290 E NORMANDY BLVD UNIT 2, DELTONA 32725

Insp Date: 04/16/2025

Inspection Number: 3439778

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Gas powered pressure washer stored in employee bathroom **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.