



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/03/2025

**Bay**

License Number: 1305378

**SHAN KISHI CUISINE INC**

License Type: Food

13800 PANAMA CITY BEACH PARKWAY SUITE 101D, PANAMA CITY BEACH 32407

Insp Date: 04/25/2025

Inspection Number: 3579018

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Exit near dry storage blocked by CO2 tanks and dry storage goods.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1504249

**FIESTA AZTECA MEXICAN REST**

License Type: Food

3194 W NEW HAVEN AVE , W MELBOURNE 43536

Insp Date: 04/29/2025

Inspection Number: 3567423

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class next too ice machine in recharge zone

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/03/2025

**Broward**

License Number: 1619969

**SAKE THAI & SUSHI BAR**

License Type: Food

4401 SHERIDAN ST #1 , HOLLYWOOD 33021

Insp Date: 04/28/2025

Inspection Number: 3586332

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at fire extinguisher next to rear exit \*\*Repeat Violation\*\*

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



## Division of Hotels &amp; Restaurants

**Fire Observations Reporting***FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Collier**

License Number: 2101883

**ROMA IN LIMA PIZZA & CUISINE LLC**

License Type: Food

1025 W MAIN ST , IMMOKALEE 34142

Insp Date: 05/02/2025

Inspection Number: 3567978

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed chairs stored in the hallway leading to the fire exit. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2101883

**ROMA IN LIMA PIZZA & CUISINE LLC**

License Type: Food

1025 W MAIN ST , IMMOKALEE 34142

Insp Date: 05/02/2025

Inspection Number: 3567978

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed rear exit door locked. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2150502

**FRIENDLY MARKET INC**

License Type: Food

2493 TRADE CENTER WAY , NAPLES 34109

Insp Date: 05/01/2025

Inspection Number: 1312111

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/03/2025

**Dade**

License Number: **BROOKLYN DUMPLING SHOP**  
License Type: Food 550 NW 1 AVE STE 110 , MIAMI 33136

Insp Date: 04/28/2025      Inspection Number: 3422243      Insp Type: Food-Licensing Inspection      Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. **Warning**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332984      **POOL AND BEACH CLUB**  
License Type: Food 1801 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 05/01/2025      Inspection Number: 3582304      Insp Type: Food-Licensing Inspection      Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Report Date: 05/03/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**DeSoto**

License Number: 2400322

**POPEYES LOUISIANA KITCHEN**

License Type: Food

2729 SE HWY 70 , ARCADIA 34266

Insp Date: 04/29/2025

Inspection Number: 3502987

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the fire extinguisher by the back door is in the red.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612833

**HYATT REGENCY JACKSONVILLE RIVERFRONT -DANIEL BUILDING ANNEX**

License Type: Food

225 E COASTLINE DR , JACKSONVILLE 32202

Insp Date: 05/02/2025

Inspection Number: 3572539

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.No boiler certificate at all, a few expired in January 2025 and a couple on 2023 per fire marshal website

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/03/2025

**Duval**

License Number: 2612827

**HYATT REGENCY JACKSONVILLE RIVERFRONT - 2ND FLOOR  
BANQUET**

License Type: Food

225 E COASTLINE DR , JACKSONVILLE 32202

Insp Date: 05/02/2025

Inspection Number: 3572621

Insp Type: Routine - Food

Disposition: Inspection Completed - No  
Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. No boiler certificate at all, a few expired in January 2025 and a couple on 2023 per fire marshal website

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2616387

**MCDONALD'S NORMANDY & CHAFFEE**

License Type: Food

11371 NORMANDY BLVD , JACKSONVILLE 32221

Insp Date: 04/28/2025

Inspection Number: 3577529

Insp Type: Routine - Food

Disposition: Inspection Completed - No  
Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank that is 25 pounds as per label stored inside building next to water heater in back area. Manager had employee to place outside of building  
\*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/03/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Duval**

License Number: 2607010

**RIVER CLUB**

License Type: Food

1 INDEPENDENT DR SUITE 3500, JACKSONVILLE 32202

Insp Date: 04/30/2025

Inspection Number: 3570630

Insp Type: Routine - Food

Disposition: Administrative  
recommended

complaint

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Pastry area \*\*Repeat Violation\*\*

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800978

**OUTBACK STEAKHOUSE**

License Type: Food

921 US 27 N , SEBRING 33870

Insp Date: 05/02/2025

Inspection Number: 3585920

Insp Type: Complaint Full

Disposition: Inspection Completed - No  
Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher by the employees restroom in the red.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/03/2025

**Highlands**

License Number: 3800978

**OUTBACK STEAKHOUSE**

License Type: Food

921 US 27 N , SEBRING 33870

Insp Date: 05/02/2025

Inspection Number: 3585920

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Observed boxes on the floor in front of the back door making it unable to get out safely, operator corrected. \*\*Corrected On-Site\*\*

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800028

**JACARANDA RESTAURANT**

License Type: Food

19 E MAIN ST , AVON PARK 53942

Insp Date: 05/02/2025

Inspection Number: 3498916

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler boiler reports expired 057118 3/22/25 and 097865 3/22/25.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.





Report Date: 05/03/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Highlands**

License Number: 3801221

**3 GEN'S GRILL AND BAR**

License Type: Food

3400 SEBRING PKWY , SEBRING 33870

Insp Date: 04/29/2025

Inspection Number: 3568321

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.1 propane tank stored in the back storage area of the kitchen.Owner placed the tank outside.  
\*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3917660

**HONDURAS RESTAURANT , LLC**

License Type: Food

902 W BUSH BLVD SUITE 101, TAMPA 33612

Insp Date: 04/28/2025

Inspection Number: 3570299

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.Electrical outlet covers missing, electrical wires sticking out above mop sink.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/03/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Hillsborough**

License Number: 3918383

**PITA PLUS+**

License Type: Food

2810 E BUSCH BLVD , TAMPA 33612

Insp Date: 04/25/2025

Inspection Number: 3579036

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

51-04-4

No child labor law poster. For reporting purposes only.

Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.

License Number: 3917660

**HONDURAS RESTAURANT , LLC**

License Type: Food

902 W BUSH BLVD SUITE 101, TAMPA 33612

Insp Date: 05/02/2025

Inspection Number: 3570299

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Electrical outlet covers missing, electrical wires sticking out above mop sink. - From follow-up inspection 2025-05-01: **\*\*Time Extended\*\*** - From follow-up inspection 2025-05-02: **\*\*Time Extended\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/03/2025

**Hillsborough**

License Number: 3917660

**HONDURAS RESTAURANT , LLC**

License Type: Food

902 W BUSH BLVD SUITE 101, TAMPA 33612

Insp Date: 05/01/2025

Inspection Number: 3570299

Insp Type: Routine - Food

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Electrical outlet covers missing, electrical wires sticking out above mop sink. - From follow-up inspection 2025-05-01: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4650736

**ARIAS'S PUPUSAS**

License Type: Food

1501 ORTIZ AVE , FORT MYERS 33905

Insp Date: 04/26/2025

Inspection Number: 1313459

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tank stored inside structure. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/03/2025

**Monroe**

License Number: 5402780

**THAI ISLAND RESTAURANT**

License Type: Food

711 EISENHOWER DR , KEY WEST 33040

Insp Date: 04/28/2025

Inspection Number: 3466245

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed several propane tanks stored at dry storage located at first floor. During the inspection operator removed them. **\*\*Corrected On-Site\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5650410

**DAT ASIAN CAJUN**

License Type: Food

671 HARBOR BLVD. , DESTIN 32541

Insp Date: 04/28/2025

Inspection Number: 1290713

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator removed tank at time of inspection. **\*\*Corrected On-Site\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/03/2025

**Orange**

License Number: 5812636

**THAI ISLAND ORLANDO RESTAURANT**

License Type: Food

2522 S SEMORAN BLVD , ORLANDO 32822

Insp Date: 04/29/2025

Inspection Number: 3495782

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814273

**CROWN FRIED CHICKEN**

License Type: Food

2912 N PINE HILLS RD , ORLANDO 32808

Insp Date: 04/25/2025

Inspection Number: 3483627

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Back exit door blocked by pieces of wood across and diagonal.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900768

**OLIVE GARDEN ITALIAN RESTAURANT #1005**

License Type: Food

5021 W IRLO BRONSON HWY , KISSIMMEE 34746

Insp Date: 04/25/2025

Inspection Number: 3572057

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. at end of cook line

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/03/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Osceola**

License Number: 5900768

**OLIVE GARDEN ITALIAN RESTAURANT #1005**

License Type: Food

5021 W IRLO BRONSON HWY , KISSIMMEE 34746

Insp Date: 04/25/2025

Inspection Number: 3572057

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. By cardboard boxes. Operator immediately removed \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911674

**MEXAS TACOS**

License Type: Food

5256 W IRLO BRONSON HWY , KISSIMMEE 34746

Insp Date: 04/30/2025

Inspection Number: 3573203

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Gas can inside bathroom. Operator immediately removed \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911442

**DUNKIN DONUTS**

License Type: Food

8898 W IRLO BRONSON MEMORIAL HWY , KISSIMMEE 34747

Insp Date: 04/30/2025

Inspection Number: 3443446

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Exit door at back of kitchen blocked with boxes. \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/03/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Pinellas**

License Number: 6218429

**SIMONS PUB**

License Type: Food

608 UNION ST , DUNEDIN 34698

Insp Date: 04/29/2025

Inspection Number: 3470061

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator is cooking bacon on a portable flat top grill in the back kitchen with no hood system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216515

**TROPICO**

License Type: Food

301 GULF VIEW BLVD , CLEARWATER 33767

Insp Date: 04/30/2025

Inspection Number: 3584389

Insp Type: Complaint Partial

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FI 137791, FL 137792, exp 4/12/2024 - From follow-up inspection 2025-04-30: \*\*Time Extended\*\*

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6400811

**DJ'S BILLIARD ROOM**

License Type: Food

1024 ST JOHNS AVE , PALATKA 32177

Insp Date: 04/30/2025

Inspection Number: 3479037

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top George Forman grill present for cooking raw beef hamburgers. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



## Division of Hotels &amp; Restaurants

**Fire Observations Reporting***FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Seminole**

License Number: 6905226

**LOCA ELOTES**

License Type: Food

451 E ALTAMONTE DR STE 5575 , ALTAMONTE SPRINGS 32701

Insp Date: 05/02/2025

Inspection Number: 3444289

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-tabletop fryer with lid.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903954

**ORLANDO MARRIOTT LAKE MARY**

License Type: Food

1501 INTERNATIONAL PKWY , LAKE MARY 32746

Insp Date: 04/29/2025

Inspection Number: 3572482

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.-boiler certification expired.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6904975

**DIGINOS PIZZA**

License Type: Food

1271 SEMORAN BLVD SR 436 , CASSELBERRY 32707

Insp Date: 04/29/2025

Inspection Number: 3572047

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-exit door by restroom blocked by table and chair

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/03/2025

**Seminole**

License Number: 6903256

**ALADDINS CAFE**

License Type: Food

1015 SR 436 #141 , CASSELBERRY 32707

Insp Date: 04/30/2025

Inspection Number: 3573526

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-rear door by bathrooms

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905476

**AN VI VIETNAMESE FOOD & CRAWFISH CAJUN**

License Type: Food

1052 STATE RD 436 , CASSELBERRY 32707

Insp Date: 04/29/2025

Inspection Number: 3574572

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.-behind white chest freezers, 2 tanks

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/03/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Seminole**

License Number: 6903954

**ORLANDO MARRIOTT LAKE MARY**

License Type: Food

1501 INTERNATIONAL PKWY , LAKE MARY 32746

Insp Date: 05/02/2025

Inspection Number: 3572482

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.- boiler certification expired. - From follow-up inspection 2025-05-02: \*\*Time Extended\*\*

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6501026

**SCHMAGEL'S BAGELS**

License Type: Food

69 HYPOLITA ST , SAINT AUGUSTINE 32084

Insp Date: 04/25/2025

Inspection Number: 3571746

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Observed grease laden vapors in air while flat top griddle is used for cooking.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407175

**EL MOLCAJETE COCINA MEXICANA**

License Type: Food

2976 S RIDGEWOOD AVE , EDGEWATER 32141

Insp Date: 05/01/2025

Inspection Number: 3582523

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by large artificial plant, exit in dining room between restrooms

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/03/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Volusia**

License Number: 7407666

**4RIVERS SMOKEHOUSE**

License Type: Food

1866 VICTORY CIR , DAYTONA BEACH 32114

Insp Date: 04/29/2025

Inspection Number: 3567785

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-exit partial blocked by delivery of chairs ,west side of dining

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7404896

**YUMMY RICE THAI AND ASIAN**

License Type: Food

3781 S NOVA RD STE P , PORT ORANGE 32129

Insp Date: 04/28/2025

Inspection Number: 3497228

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.-unit in recharge zone on back wall in storage area next to 3 compartment sink

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405612

**MANNY'S PIZZA HOUSE VI**

License Type: Food

4606 CLYDE MORRIS BLVD , PORT ORANGE 32129

Insp Date: 04/28/2025

Inspection Number: 3571264

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-back door marked with fire exit obstructed by stacked supplies/wire container holders/boxes

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/03/2025

**Volusia**

License Number: 7407583

**HOME2 SUITES BY HILTON DAYTONA**

License Type: Food

200 FENTRESS BLVD , DAYTONA BEACH 32114

Insp Date: 05/02/2025

Inspection Number: 3462374

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-prep table blocking exit door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407666

**4RIVERS SMOKEHOUSE**

License Type: Food

1866 VICTORY CIR , DAYTONA BEACH 32114

Insp Date: 05/01/2025

Inspection Number: 3567785

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.-exit partial blocked by delivery of chairs ,west side of dining - From follow-up inspection 2025-05-01:

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.