



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Bay

License Number: 1305352

BAYOU ON THE BEACH CAFE

License Type: Food

11115 HUTCHISON BLVD , PANAMA CITY BEACH 32407

Insp Date: 05/07/2025

Inspection Number: 3578707

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class in fly room overcharged.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2000845

SUNRISE TO SUNSET

License Type: Food

618 N ORANGE AVE , GREEN COVE SPRINGS 32043

Insp Date: 05/05/2025

Inspection Number: 3586625

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small table top flat grill, not under hood system, on counter by steam wells. Grill producing grease laden vapors. Observed oil being used and grill is used for french toast, pancakes and heating potatoes.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Collier

License Number: 2101883

ROMA IN LIMA PIZZA & CUISINE LLC

License Type: Food

1025 W MAIN ST , IMMOKALEE 34142

Insp Date: 05/02/2025

Inspection Number: 3567978

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed chairs stored in the hallway leading to the fire exit. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2101883

ROMA IN LIMA PIZZA & CUISINE LLC

License Type: Food

1025 W MAIN ST , IMMOKALEE 34142

Insp Date: 05/02/2025

Inspection Number: 3567978

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed rear exit door locked. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2103110

ALAMO DRAFTHOUSE CINEMA

License Type: Food

9118 STRADA PL STE 8205 , NAPLES 34108

Insp Date: 05/06/2025

Inspection Number: 3579887

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed the rear exit in the kitchen blocked by a trash bin.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Duval

License Number: 2612702

APM INN AND SUITES JACKSONVILLE

License Type: Food

510 LANE AVE S , JACKSONVILLE 32254

Insp Date: 05/07/2025

Inspection Number: 3480640

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small table fryers not under hood system

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613506

SUBWAY #37825

License Type: Food

6842 WILSON BLVD #1 , JACKSONVILLE 32210

Insp Date: 05/08/2025

Inspection Number: 3468025

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed chair and large not-in-use tea brewer blocking exit door in kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Duval

License Number: 2612833

**HYATT REGENCY JACKSONVILLE RIVERFRONT -DANIEL
BUILDING ANNEX**

License Type: Food

225 E COASTLINE DR , JACKSONVILLE 32202

Insp Date: 05/02/2025

Inspection Number: 3572539

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.No boiler certificate at all, a few expired in January 2025 and a couple on 2023 per fire marshal website

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2612827

**HYATT REGENCY JACKSONVILLE RIVERFRONT - 2ND FLOOR
BANQUET**

License Type: Food

225 E COASTLINE DR , JACKSONVILLE 32202

Insp Date: 05/02/2025

Inspection Number: 3572621

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. No boiler certificate at all, a few expired in January 2025 and a couple on 2023 per fire marshal website

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Duval

License Number: 2614293

CHULE'S GRILL

License Type: Food

11915 BEACH BLVD STE 112 , JACKSONVILLE 32246

Insp Date: 05/09/2025

Inspection Number: 3573646

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. LP propane tank stored on shelf in prep area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3600429

KENTUCKY FRIED CHICKEN

License Type: Food

411 W SUGARLAND HWY , CLEWISTON 33440

Insp Date: 05/09/2025

Inspection Number: 3587052

Insp Type: Complaint Full

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only: located in office. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Hernando

License Number: 3750350

CALI STREET TACOS

License Type: Food

4670 COMMERCIAL WAY , SPRING HILL 34606

Insp Date: 05/07/2025

Inspection Number: 1315284

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. For reporting purposes only. Hood ventilation system to the left of the grill not functional at time of inspection

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800978

OUTBACK STEAKHOUSE

License Type: Food

921 US 27 N , SEBRING 33870

Insp Date: 05/02/2025

Inspection Number: 3585920

Insp Type: Complaint Full

Disposition: Inspection Completed - No
Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher by the employees restroom in the red.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Highlands

License Number: 3800978

OUTBACK STEAKHOUSE

License Type: Food

921 US 27 N , SEBRING 33870

Insp Date: 05/02/2025

Inspection Number: 3585920

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Observed boxes on the floor in front of the back door making it unable to get out safely, operator corrected. **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800028

JACARANDA RESTAURANT

License Type: Food

19 E MAIN ST , AVON PARK 53942

Insp Date: 05/02/2025

Inspection Number: 3498916

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler boiler reports expired 057118 3/22/25 and 097865 3/22/25.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Report Date: 05/10/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hillsborough

License Number: 3909694

EL DIAMANTE RESTAURANT

License Type: Food

4422 N HUBERT AVE , TAMPA 33614

Insp Date: 05/08/2025

Inspection Number: 3565609

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Fryer on cook line not located under the FSS. Discussed with operator the possibility of moving the fryer to be located under the FSS. There appears to be enough space.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913030

RICE N ROLL

License Type: Food

19243 N DALE MABRY HWY , LUTZ 33548

Insp Date: 05/06/2025

Inspection Number: 3581085

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Shopping cart, equipment in front of back door. Discussed with manager

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/10/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hillsborough

License Number: 3917660

HONDURAS RESTAURANT , LLC

License Type: Food

902 W BUSH BLVD SUITE 101, TAMPA 33612

Insp Date: 05/02/2025

Inspection Number: 3570299

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Electrical outlet covers missing, electrical wires sticking out above mop sink. - From follow-up inspection 2025-05-01: **Time Extended** - From follow-up inspection 2025-05-02: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 3915753

LOLIS MEXICAN CRAVINGS

License Type: Food

8005 BENJAMIN RD , TAMPA 33634

Insp Date: 05/06/2025

Inspection Number: 3571919

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. A prep table with steam well blocked exit door in kitchen. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Lee

License Number: 4606437

HASAN RESTAURANT

License Type: Food

3069 DR MARTIN LUTHER KING JR BLVD , FORT MYERS 64163

Insp Date: 05/08/2025

Inspection Number: 3579226

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed exit sign hanging from wires above rear exit door. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4703763

RED HILLS VILLAGE

License Type: Food

5103 COLD HARBOR DR , TALLAHASSEE 32312

Insp Date: 05/07/2025

Inspection Number: 3498215

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher behind doors after entering in to the kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Marion

License Number: 5201923

WORKS BISTRO

License Type: Food

12169 S WILLIAMS ST , DUNNELLON 34432

Insp Date: 05/05/2025

Inspection Number: 3585280

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher at kitchen entrance.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5202998

JERSEY MIKE'S SUB SHOP

License Type: Food

8075 SW SR 200 #121 , OCALA 34481

Insp Date: 05/09/2025

Inspection Number: 3582803

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher on wall in lobby near restrooms in need of recharge.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Marion

License Number: 5202832

100 PROOF SALOON

License Type: Food

1735 N PINE AVE , OCALA 34475

Insp Date: 05/05/2025

Inspection Number: 3488966

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher outside of office.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402580

TIN CUP CHALICE

License Type: Food

2001 S ROOSEVELT BLVD , KEY WEST 33040

Insp Date: 05/06/2025

Inspection Number: 3574152

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

48-01-5

Observation

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-05-06: Still observed ****Time Extended****

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Okaloosa

License Number: 5603962

JIMMY BUFFETT'S MARGARITAVILLE CAFE 2ND FLOOR

License Type: Food

76 HARBOR BLVD , DESTIN 32541

Insp Date: 05/08/2025

Inspection Number: 3572010

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.130215 / 130233 4/11/23

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5603961

JIMMY BUFFETT'S MARGARITAVILLE

License Type: Food

76 HARBOR BLVD , DESTIN 32541

Insp Date: 05/08/2025

Inspection Number: 3572040

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.130215 / 130233 4/11/23

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Okaloosa

License Number: 5600144

COASTAL KITCHEN

License Type: Food

1500 MIRACLE STRIP PKWY SE , FORT WALTON BEACH 32548

Insp Date: 05/07/2025

Inspection Number: 3499266

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Upon inspection, observed boiler certificate expired. Jurisdiction-134306 Expiration date - 10/09/21

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Report Date: 05/10/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5812851

SENROR FROG'S

License Type: Food

8747 INTERNATIONAL DR UNIT C , ORLANDO 32819

Insp Date: 05/06/2025

Inspection Number: 3573856

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only by back door **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5806935

SUBWAY #12034

License Type: Food

7515 S ORANGE AVE , ORLANDO 96701

Insp Date: 05/06/2025

Inspection Number: 3441198

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.Back exit door blocked by cardboard boxes

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911263

ICHIBAN BUFFET

License Type: Food

5269 W IRLO BRONSON MEMORIAL HWY , KISSIMMEE 34746

Insp Date: 05/07/2025

Inspection Number: 3503496

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Exit door next to dry storage blocked with chairs

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Pinellas

License Number: 6218730

RUDYS FOOD AND MARKET

License Type: Food

1698 CLEARWATER LARGO RD , CLEARWATER 33756

Insp Date: 05/08/2025

Inspection Number: 3585847

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Portable deep fryers in table are in use without hood suppression system. Operator discontinued use of deep fryers.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217654

RED TIKI BAR AND GRILL

License Type: Food

7361 46 AVE N , ST. PETERSBURG 33709

Insp Date: 05/08/2025

Inspection Number: 3582886

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Deep fryers not under hood system. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/10/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6214974

NOVU AT PONCE

License Type: Food

95 CENTRAL AVE , ST. PETERSBURG 33701

Insp Date: 05/06/2025

Inspection Number: 3505126

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Electric deep fryer not located under hood **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905226

LOCA ELOTES

License Type: Food

451 E ALTAMONTE DR STE 5575 , ALTAMONTE SPRINGS 32701

Insp Date: 05/02/2025

Inspection Number: 3444289

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-tabletop fryer with lid.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903199

PARKS & REC DEPT SNACK BAR

License Type: Food

1000 E SR 434 , WINTER SPRINGS 32708

Insp Date: 05/07/2025

Inspection Number: 3434750

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only.-outlet on rear side of pretzel warmer facing ice machine

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/10/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Seminole

License Number: 6905205

MARQUISE CATERING

License Type: Food

1255 BELLE AVE # 116 , WINTER SPRINGS 32708

Insp Date: 05/09/2025

Inspection Number: 3448901

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.-2 tanks -operator removed

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905026

JERSEY MIKE'S SUBS

License Type: Food

5697 RED BUG LAKE RD #14 , WINTER SPRINGS 32708

Insp Date: 05/06/2025

Inspection Number: 3460708

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.-rear exit door blocked by speed racks and boxes - From follow-up inspection 2025-05-06: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903954

ORLANDO MARRIOTT LAKE MARY

License Type: Food

1501 INTERNATIONAL PKWY , LAKE MARY 32746

Insp Date: 05/02/2025

Inspection Number: 3572482

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.- boiler certification expired. - From follow-up inspection 2025-05-02: **Time Extended**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Report Date: 05/10/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7407197

POLYNESIAN FIRE LUAU

License Type: Food

180 N BEACH ST , DAYTONA BEACH 32114

Insp Date: 05/06/2025

Inspection Number: 3569599

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-partial block rear exit, per manager there is three feet between items stored in hallway

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406959

KIKI'S SOUTHERN KITCHEN

License Type: Food

456 S DR MARTIN LUTHER KING JR BLV , DAYTONA BEACH 32114

Insp Date: 05/06/2025

Inspection Number: 3586580

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-hurricane type shutters covering south side door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406283

BOB EVANS RESTAURANT 425

License Type: Food

1711 DUNLAWTON AVE , PORT ORANGE 32127

Insp Date: 05/08/2025

Inspection Number: 3573307

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.-back door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 05/10/2025

Volusia

License Number: 7407583

HOME2 SUITES BY HILTON DAYTONA

License Type: Food

200 FENTRESS BLVD , DAYTONA BEACH 32114

Insp Date: 05/02/2025

Inspection Number: 3462374

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-prep table blocking exit door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7402738

CHART HOUSE

License Type: Food

645 S BEACH ST , DAYTONA BCH 32114

Insp Date: 05/08/2025

Inspection Number: 3574211

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

49-01-4

Flammables stored/debris present in meter room. For reporting purposes only.-boxes in from of electrical panel in storage room

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.