



Report Date: 05/31/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Alachua**

License Number: 1101748

**POPEYES LOUISIANA KITCHEN #128**

License Type: Food

1412 N MAIN ST , GAINESVILLE 14368

Insp Date: 05/28/2025

Inspection Number: 3588145

Insp Type: Complaint Partial

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. 2 ceiling lights hanging down over dining table in middle of dining room. \*\*Warning\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1101152

**MCDONALDS**

License Type: Food

3826 SW ARCHER RD , GAINESVILLE 82340

Insp Date: 05/28/2025

Inspection Number: 3588272

Insp Type: Complaint Partial

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed: the fire extinguisher by the front line is in the red zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103024

**LIL RUDYS AT MIDTOWN**

License Type: Food

1702 W UNIVERSITY AVE STE A2 , GAINESVILLE 32603

Insp Date: 05/30/2025

Inspection Number: 3446940

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the silver K Class fire extinguisher indicates that it is not fully charged.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/31/2025

**Alachua**

License Number: 1101748

**POPEYES LOUISIANA KITCHEN #128**

License Type: Food

1412 N MAIN ST , GAINESVILLE 14368

Insp Date: 05/30/2025

Inspection Number: 3588145

Insp Type: Complaint Partial

Disposition: Call Back - Extension given,  
pending

Violation Code

Observation

Violation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only.2 ceiling lights hanging down over dining table in middle of dining room.  
\*\*Warning\*\* - From follow-up inspection 2025-05-30:  
\*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1306055

**TOPGOLF**

License Type: Food

15475 TOPGOLF WAY , PANAMA CITY BEACH 32413

Insp Date: 05/29/2025

Inspection Number: 3574792

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No  
Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Report Date: 05/31/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Broward**

License Number: 1623873

**JERSEY MIKE'S SUBS**

License Type: Food

2350 N FEDERAL HWY STE 105 , POMPANO BEACH 33062

Insp Date: 05/30/2025

Inspection Number: 3588452

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher, in kitchen, in recharge zone.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335871

**ALTITUDE**

License Type: Food

801 S MIAMI AVE , MIAMI 33130

Insp Date: 05/27/2025

Inspection Number: 3484924

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

48-01-5

Observation

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed FL 135542 , FL 135543 both expires on 09-27-24. - From follow-up inspection 2025-05-27: \*\*Time Extended\*\*

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/31/2025

**Duval**

License Number: 2614224

**CHIPOTLE MEXICAN GRILL #1177**

License Type: Food

4865 TOWN CENTER PAKWY , JACKSONVILLE 32246

Insp Date: 05/27/2025

Inspection Number: 3575546

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Rear exit door blocked by numerous cardboard boxes. Boxes moved. **\*\*Corrected On-Site\*\***  
**\*\*Repeat Violation\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612637

**BONOS PIT BAR-B-Q**

License Type: Food

10065 SKINNER LAKE DR , JACKSONVILLE 32246

Insp Date: 05/27/2025

Inspection Number: 3577820

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Large brown umbrella blocking exit near restrooms.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/31/2025

**Highlands**

License Number: 3801128

**TIENDA & RESTAURANTE LAMALQUERIDA LLC**

License Type: Food

600 W MAIN ST , AVON PARK 33825

Insp Date: 05/27/2025

Inspection Number: 3581194

Insp Type: Routine - Food

Disposition: Emergency  
recommended

order

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed in use one propane tank in back of kitchen and one propane tank stored in storage area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3801128

**TIENDA & RESTAURANTE LAMALQUERIDA LLC**

License Type: Food

600 W MAIN ST , AVON PARK 33825

Insp Date: 05/28/2025

Inspection Number: 3581194

Insp Type: Routine - Food

Disposition: Emergency Order  
Time Extension

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed in use one propane tank in back of kitchen and one propane tank stored in storage area. - From follow-up inspection 2025 -05-28: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/31/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Lee**

License Number: 4604584

**SCHNITZEL HOUSE**

License Type: Food

17274 SAN CARLOS BLVD #208 , FORT MYERS BEACH 33931

Insp Date: 05/27/2025

Inspection Number: 3574940

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Rear exit door dead bolted from the inside. Operator unlocked door.  
\*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4800633

**KFC**

License Type: Food

1105 N YOUNG BLVD , CHIEFLAND 32626

Insp Date: 05/29/2025

Inspection Number: 3587622

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by back door in need of recharge.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/31/2025

**Manatee**

License Number: 5103927

**MCDONALD'S #13722**

License Type: Food

7300 CORTEZ RD , BRADENTON 34210

Insp Date: 05/30/2025

Inspection Number: 3586952

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed back exit door from dry storage area blocked by cart. Operator removed cart. \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301302

**MIKATA BUFFET INC**

License Type: Food

3201 NW FEDERAL HWY 1 , JENSEN BEACH 34957

Insp Date: 05/27/2025

Inspection Number: 3587070

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. Overcharged fire extinguisher at the end of cook line across from prep table. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814961

**LA' DIFFERANCE BAKERY & TAKEOUT RESTAURANT, LLC**

License Type: Food

737 NORTH APOPKA VINELAND RD #200 , ORLANDO 32818

Insp Date: 05/30/2025

Inspection Number: 3559301

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in red by entry to back prep area

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/31/2025

**Orange**

License Number: 5813065

**MCDONALD'S OCOEE WEST**

License Type: Food

2281 OCOEE-APOPKA RD , OCOEE 34761

Insp Date: 05/23/2025

Inspection Number: 3587630

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Back exit door blocked. By bread crates. Operator immediately removed \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804137

**L&L RESTAURANT**

License Type: Food

8701 WORLD CENTER DR , ORLANDO 32821

Insp Date: 05/28/2025

Inspection Number: 3575945

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.Observed boiler certificates ,015117 015203 expired 10/2024.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/31/2025

**Orange**

License Number: 5814397

**ZAXBY'S**

License Type: Food

6625 FOREST CITY RD , ORLANDO 32810

Insp Date: 05/28/2025

Inspection Number: 3436992

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Large propane tank stored inside outside storage

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5815890

**GORYEO GARDEN**

License Type: Food

5319 WEST COLONIAL DRIVE , ORLANDO 32808

Insp Date: 05/27/2025

Inspection Number: 3570448

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Gas can inside storage area. Advised to remove immediately

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/31/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Orange**

License Number: 5815280

**BISTRO PARADISE RESTAURANT & BAR**

License Type: Food

737 N APOPKA VINELAND RD STE 100 , ORLANDO 32818

Insp Date: 05/27/2025

Inspection Number: 3484360

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator immediately removed to outside  
\*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811672

**EASTSIDE BISTRO**

License Type: Food

12001 AVALON LAKE DR STE F , ORLANDO 32828

Insp Date: 05/30/2025

Inspection Number: 3563337

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Blocked down bathroom hallway to rear door - From follow-up inspection 2025-05-29: No change \*\*Time Extended\*\*  
- From follow-up inspection 2025-05-30: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 05/31/2025

**Orange**

License Number: 5811672

**EASTSIDE BISTRO**

License Type: Food

12001 AVALON LAKE DR STE F , ORLANDO 32828

Insp Date: 05/29/2025

Inspection Number: 3563337

Insp Type: Routine - Food

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.Blocked down bathroom hallway to rear door - From follow-up inspection 2025-05-29: No change \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811672

**EASTSIDE BISTRO**

License Type: Food

12001 AVALON LAKE DR STE F , ORLANDO 32828

Insp Date: 05/27/2025

Inspection Number: 3563337

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Blocked down bathroom hallway to rear door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/31/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Pinellas**

License Number: 6200143

**HERNANDO CORRECTIONAL INSTITUTION-71641**

License Type: Food

4237 8 AVE S , ST. PETERSBURG 33711

Insp Date: 05/23/2025

Inspection Number: 1114476

Insp Type: Routine - Food

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  
\*\*Repeat Violation\*\*

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6805712

**NAPULE RESTAURANT**

License Type: Food

7129 TAMIAMI TRL , SARASOTA 34231

Insp Date: 05/27/2025

Inspection Number: 3588100

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed the side exit at the bottom of the stairwell locked. The operator unlocked the door. \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905520

**SHE-ISLAND SNACK SHACK**

License Type: Food

2800 HWY 17-92 , LONGWOOD 32750

Insp Date: 05/23/2025

Inspection Number: 3433410

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 05/31/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**St. Johns**

License Number: 6501831

**TASTE OF INDIA**

License Type: Food

155 HAMPTON POINT DR STE 5-8 , SAINT AUGUSTINE 32092

Insp Date: 05/30/2025

Inspection Number: 3580683

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Large LP gas tank in kitchen by rear entrance.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406393

**ROSSI'S DINER**

License Type: Food

2240 RIDGEWOOD AVE , SOUTH DAYTONA 32119

Insp Date: 05/29/2025

Inspection Number: 3573966

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Gas oven vent disconnected; partially venting into room  
\*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407781

**DAIRY QUEEN GRILL AND CHILL**

License Type: Food

3817 CLYDE MORRIS BLVD , PORT ORANGE 32129

Insp Date: 05/23/2025

Inspection Number: 3576792

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-obstructed by large trash can, several boxes \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.