



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Alachua

License Number: 1103413

SOHAO STREET FARE CAFE

License Type: Food

3045 SW 34 ST STE 16 , GAINESVILLE 32608

Insp Date: 07/24/2025

Inspection Number: 3635717

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed : 2 bikes blocking the back exit by the restrooms.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103562

NINE SPICES HOTPOT

License Type: Food

3333 SW 34 ST , GAINESVILLE 32608

Insp Date: 07/23/2025

Inspection Number: 3609703

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed: the Fire extinguisher by the restroom doors, indicates it is not fully charged.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Bay

License Number: 1304311

PEPPERS MEXICAN GRILL AND CANTINA

License Type: Food

2061 MARTIN LUTHER KING JR BLVD , PANAMA CITY 32405

Insp Date: 07/24/2025

Inspection Number: 3650118

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Exit sign by dish pit hanging by wires.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305809

BEEF O'BRADY'S

License Type: Food

11226 HUTCHISON BLVD , PANAMA CITY BEACH 32407

Insp Date: 07/25/2025

Inspection Number: 3633946

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. By dry storage room. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Bradford

License Number: 1400155

CARIBBEAN SOUL

License Type: Food

200 E CALL ST , STARKE 32091

Insp Date: 07/18/2025

Inspection Number: 3645362

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

51-04-4

Observation

No child labor law poster. For reporting purposes only.No child labor law poster available.

Violation Citation

Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.

License Number: 1502602

TACO BELL

License Type: Food

2004 S WASHINGTON AVE , TITUSVILLE 32780

Insp Date: 07/18/2025

Inspection Number: 3630944

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only.Boxes in front of back door **Corrected On -Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Broward

License Number: 1608517

LE TUB

License Type: Food

1100 N OCEAN DR , HOLLYWOOD 33019

Insp Date: 07/22/2025

Inspection Number: 3649067

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank near ice machine. Operator removed **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1624906

WENDY'S 12179

License Type: Food

4600 S SR 7 , HOLLYWOOD 33314

Insp Date: 07/24/2025

Inspection Number: 3593570

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. At the back door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Broward

License Number: 1625886

DAVE'S HOT CHICKEN

License Type: Food

15855 PINES BLVD STE 101 , PEMBROKE PINES 33027

Insp Date: 07/24/2025

Inspection Number: 3606936

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher gauge in recharge zone, in kitchen next to dish machine.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1625680

SUSHI HOUSE

License Type: Food

5818 STIRLING RD , HOLLYWOOD 33021

Insp Date: 07/23/2025

Inspection Number: 3633353

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. In use table top fryers no hood system **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Citrus

License Number: 1901326

PANERA BREAD #1788

License Type: Food

1082 W MAIN ST , INVERNESS 34450

Insp Date: 07/24/2025

Inspection Number: 3635948

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in bathroom area

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2338232

SNDWCH SUNSET

License Type: Food

1573 SUNSET DR , CORAL GABLES 33143

Insp Date: 07/18/2025

Inspection Number: 3616836

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed miniature fryer at front counter with no hood system. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331668

ALFARO'S

License Type: Food

1604 SW 8 STREET , MIAMI 33135

Insp Date: 07/24/2025

Inspection Number: 3601696

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Kitchen, establishment using a grease portable fryer used to cook fries and croquettes .

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2336668

POKE 88 RESTAURANT

License Type: Food

8817 SW 107 AVE , MIAMI 33176

Insp Date: 07/24/2025

Inspection Number: 3613897

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed small fryer on table top in back prep area with no hood.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336796

CUBATA

License Type: Food

1605 SW 8 ST , MIAMI 33135

Insp Date: 07/24/2025

Inspection Number: 3602806

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Kitchen: establishment has a portable double sided gas fryer, no hood suppression system.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2337694

ROZU

License Type: Food

200 E FLAGLER ST UNIT 207 , MIAMI 33131

Insp Date: 07/22/2025

Inspection Number: 3616670

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking Spring rolls no hood suppression system. **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2319783

304 FARMSTEAD

License Type: Food

2269 NW 199 ST , MIAMI 62600

Insp Date: 07/23/2025

Inspection Number: 3606066

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate expired. FL-133314 expiresA on 7/20/25, FL-13313 expiresA on 7/20/25

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2319790

SHULA BURGER

License Type: Food

2269 NW 199 ST , MIAMI 62600

Insp Date: 07/23/2025

Inspection Number: 3593598

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expired boiler certificate FL-133314 expiresA on 7/20/25, FL-13313 expiresA on 7/20/25

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2319804

317 LCKY CHKN

License Type: Food

2269 DAN MARINO BLVD, STAND #317 , MIAMI 33056

Insp Date: 07/23/2025

Inspection Number: 3628958

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boilers with expired certificate . FL-133314 expiresA on 7/20/25, FL-13313 expiresA on 7/20/25

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2319805

312 SOBE Q/SLOPPY JOES

License Type: Food

2269 DAN MARINO BLVD, STAND # 312 , MIAMI 33056

Insp Date: 07/23/2025

Inspection Number: 3641566

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate expired FL-133314 expiresA on 7/20/25, FL-13313 expiresA on 7/20/25

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2326620

350 BENIHANA

License Type: Food

2269 DAN MARINO BLVD STAND #350 , MIAMI 33056

Insp Date: 07/23/2025

Inspection Number: 3613751

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate expired FL-133314 expiresA on 7/20/25, FL-13313 expiresA on 7/20/25.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2326622

347 SOL CUBANO

License Type: Food

2269 DAN MARINO BLVD, STAND #C347 , MIAMI 33056

Insp Date: 07/23/2025

Inspection Number: 3622436

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boilers with expired certificate FL-133314 expiresA on 7/20/25, FL-13313 expiresA on 7/20/25

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2326624

355 FAN FAVORITES

License Type: Food

2269 DAN MARINO BLVD, STAND # 355 , MIAMI 33056

Insp Date: 07/23/2025

Inspection Number: 3598020

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boilers with expired certificates FL-133314 expiresA on 7/20/25, FL-13313 expiresA on 7/20/25

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2327611

NAUTILUS

License Type: Food

1601 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 07/22/2025

Inspection Number: 3631570

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2331718

HAMPTON INN COCONUT GROVE

License Type: Food

2800 SW 28 TERR , MIAMI 33133

Insp Date: 07/21/2025

Inspection Number: 3613952

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate expired 5/17/2025.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2335458

FOUR POINTS BY SHERIDAN

License Type: Food

3570 NW 74 AVE , MIAMI 33122

Insp Date: 07/21/2025

Inspection Number: 3614337

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler FL 134359, FL 134358 without boiler certification **Repeat Violation**

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2334856

347A EDGEWATER GRILL

License Type: Food

2269 DAN MARINO BLVD , MIAMI GARDENS 33056

Insp Date: 07/23/2025

Inspection Number: 3635732

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boilers expired certificate FL-133314 expiresA on 7/20/25, FL-13313 expiresA on 7/20/25

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2334857

345A SHULA BURGER

License Type: Food

2269 DAN MARINO BLVD STAND #345A , MIAMI 33056

Insp Date: 07/23/2025

Inspection Number: 3599255

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boilers with expired certificate FL-133314 expiresA on 7/20/25, FL-13313 expiresA on 7/20/25

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2334859

CHEESE BURGER BABY 317A

License Type: Food

2269 DAN MARINO BLVD, STAND #317A , MIAMI 33056

Insp Date: 07/23/2025

Inspection Number: 3610702

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate expired. FL-133314 expiresA on 7/20/25, FL-13313 expiresA on 7/20/25

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2337171

SNDWCH MIAMI

License Type: Food

9420 NW 41 ST #115 , DORAL 33178

Insp Date: 07/24/2025

Inspection Number: 3593541

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boiler units at 650,000 BTU's with no certification located at boiler room **Repeat Violation**

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2335344

MIAMI JOES COFFEE

License Type: Food

1601 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 07/22/2025

Inspection Number: 3614331

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-02-5

Observation

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2323609

HIALEAH LATIN AMERICA REST

License Type: Food

675 E 9 ST , HIALEAH 04523

Insp Date: 07/23/2025

Inspection Number: 3615668

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

51-04-4

No child labor law poster. For reporting purposes only.

Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.

License Number: 2615920

ANOTHER BROKEN EGG CAFÉ

License Type: Food

11949 ATLANTIC BOULEVARD UNIT 105, JACKSONVILLE 32225

Insp Date: 07/23/2025

Inspection Number: 3649629

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer for seafood on line not stored under hoods

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Duval

License Number: 2600573

SAN JOSE CO CLUB D R

License Type: Food

7529 SAN JOSE BLVD , JACKSONVILLE 73524

Insp Date: 07/18/2025

Inspection Number: 3603727

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per website , Establishment certificate is current.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2616160

TRAP HOUSE CHICKEN

License Type: Food

5516 NORMANDY BLVD , JACKSONVILLE 32205

Insp Date: 07/24/2025

Inspection Number: 3641069

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two propane tanks larger than 2.7lbs stored in establishment. Manager moved tanks outside.
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Duval

License Number: 2615250

TACOS DONA MARIA 2

License Type: Food

12192 BEACH BLVD SUITE 3 , JACKSONVILLE 32246

Insp Date: 07/24/2025

Inspection Number: 3597536

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank stored in non working walk-in-cooler. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800905

JERSEY MIKE'S SUBS

License Type: Food

250 PALM COAST PKWY NE STE 204 , PALM COAST 32137

Insp Date: 07/22/2025

Inspection Number: 3605179

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. By boxes in path of back exit door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Hardee

License Number: 3500269

TACO BELL

License Type: Food

116 W. REA RD , WAUCHULA 33873

Insp Date: 07/25/2025

Inspection Number: 3622349

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed fire extinguisher on the floor by the back door, operator put back on wall under the sign. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3550085

SMOKIN' TENDER-NESS BBQ

License Type: Food

103 E MAIN ST , WAUCHULA 33873

Insp Date: 07/25/2025

Inspection Number: 1319417

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-06-4

Portable fire extinguisher is inaccessible. For reporting purposes only. Observed fire extinguisher is covered with towel and bags not accessible, operator removed. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800978

OUTBACK STEAKHOUSE

License Type: Food

921 US 27 N , SEBRING 33870

Insp Date: 07/21/2025

Inspection Number: 3648749

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Highlands

License Number: 3800978

OUTBACK STEAKHOUSE

License Type: Food

921 US 27 N , SEBRING 33870

Insp Date: 07/21/2025

Inspection Number: 3648749

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800978

OUTBACK STEAKHOUSE

License Type: Food

921 US 27 N , SEBRING 33870

Insp Date: 07/22/2025

Inspection Number: 3648749

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2025-07-22: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800978

OUTBACK STEAKHOUSE

License Type: Food

921 US 27 N , SEBRING 33870

Insp Date: 07/22/2025

Inspection Number: 3648749

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-05-4

- From initial inspection : Portable fire extinguisher missing from its designated location. For reporting purposes only.
- From follow-up inspection 2025-07-22: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Hillsborough

License Number: 3912197

POPEYES CHICKEN & BISUITS #94

License Type: Food

5156 S DALE MABRY , TAMPA 33611

Insp Date: 07/22/2025

Inspection Number: 3648307

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed missing outlet cover in mop sink with exposed white wire at time of inspection.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906195

PAPIS CAFE1 LLC

License Type: Food

2203 N. LOIS AVE G100 , TAMPA 33607

Insp Date: 07/21/2025

Inspection Number: 3593754

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. A 20 lbs propane tank stored in storage room next to office area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Indian River

License Number: 4105068

WATERFALL RESTAURANT

License Type: Food

2227 14 AVE , VERO BEACH 32960

Insp Date: 07/25/2025

Inspection Number: 3598375

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only. Next to hand sink in prep area

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4509020

PASTELITOS MARILU

License Type: Food

342 W BURLEIGH BLVD , TAVARES 32778

Insp Date: 07/24/2025

Inspection Number: 3629251

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 propane tanks in bathroom

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605881

DAIRY QUEEN GRILL AND CHILL

License Type: Food

9011 CODY LEE RD , FORT MYERS 33912

Insp Date: 07/18/2025

Inspection Number: 3596546

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical outlet in disrepair. For reporting purposes only. Outlet over reach-in cooler on cook line closest to deep fryers cracked cover.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Lee

License Number: 4605798

STEAK N SHAKE

License Type: Food

8950 COLONIAL CENTER DR , FORT MYERS 33905

Insp Date: 07/25/2025

Inspection Number: 3623469

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher outside restroom area gauge in red.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4603671

ARBY'S #5992

License Type: Food

9290 DANIELS PKWY , FORT MYERS 33912

Insp Date: 07/22/2025

Inspection Number: 3633199

Insp Type: Routine - Food

Disposition: Emergency order recommended

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only. Far end cook line by toaster.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lee

License Number: 4603671

ARBY'S #5992

License Type: Food

9290 DANIELS PKWY , FORT MYERS 33912

Insp Date: 07/22/2025

Inspection Number: 3633199

Insp Type: Routine - Food

Disposition: Emergency Order Callback
Not Complied

Violation Code

Observation

Violation Citation

47-02-4

- From initial inspection : Observed scorch marks around electrical outlet. For reporting purposes only. Far end cook line by toaster. - From follow-up inspection 2025-07-22: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5202946

BLUE GATOR OF DUNNELLON

License Type: Food

12189 S WILLIAMS ST , DUNNELLON 34432

Insp Date: 07/22/2025

Inspection Number: 3626837

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. 1. Gauge on fire extinguisher near three-compartment sink in recharge zone. 2. Gauge on fire extinguisher near managers office in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811787

STARLIGHT RESTAURANT AND LOUNGE INC

License Type: Food

5233 OLD WINTER GARDEN RD STE A , ORLANDO 32811

Insp Date: 07/23/2025

Inspection Number: 3617911

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-locking bar on exit door next to kitchen entrance -exit door at restrooms

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Orange

License Number: 5815691

CHABUCA

License Type: Food

5928 BUTLER NATIONAL DR STE B , ORLANDO 32822

Insp Date: 07/22/2025

Inspection Number: 3621253

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator removed **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807626

WENDY'S #5317

License Type: Food

4426 HOFFNER AVE , ORLANDO 32812

Insp Date: 07/24/2025

Inspection Number: 3603391

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Full of trashed blocked the exit door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814156

DOMINO'S

License Type: Food

6401 RALEIGH ST , ORLANDO 32835

Insp Date: 07/18/2025

Inspection Number: 3594652

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. rear exit door blocked by trash bin and boxes

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Orange

License Number: 5810665

JERSEY MIKES SUBS

License Type: Food

6700 CONROY RD STE 100A , ORLANDO 32835

Insp Date: 07/21/2025

Inspection Number: 3618826

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only.-rear exit door blocked by pull wagon

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811766

FRATELLIS RESTAURANT

License Type: Food

373 N ORANGE AVE , ORLANDO 32801

Insp Date: 07/22/2025

Inspection Number: 3640878

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-04-4

Observation

Exit door locked. For reporting purposes only.Back exit door in hallway used for dry storage area is blocked by equipment . Operator immediately removed **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Orange

License Number: 5811648

CAYJO

License Type: Food

6601 OLD WINTER GARDEN RD STE 106 , ORLANDO 32835

Insp Date: 07/25/2025

Inspection Number: 3643545

Insp Type: Routine - Food

Disposition: Administrative complaint
recommended

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.-under prep sink and at rear door

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6023076

PALM HOUSE

License Type: Food

160 ROYAL PALM WAY , PALM BEACH 33480

Insp Date: 07/25/2025

Inspection Number: 3650561

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
Repeat Violation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6011280

RICE & NOODLE

License Type: Food

9850 ALT A1A STE 503 , PALM BEACH GARDENS 04936

Insp Date: 07/23/2025

Inspection Number: 3602327

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.Exit back door locked ; operator unlocked **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Pinellas

License Number: 6217240

License Type: Food

DOCKS

100 CORONADO DR , CLEARWATER 33767

Insp Date: 07/25/2025

Inspection Number: 3608631

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FI124576-fl124575-fl124574, fl136693, all exp 1/30/2025

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6218703

License Type: Food

BEACH MARKET CAFE

400 CORONADO DR , CLEARWATER BEACH 33767

Insp Date: 07/24/2025

Inspection Number: 3618427

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Pinellas

License Number: 6200047

CHATTAWAY DRIVE INN

License Type: Food

358 S 22 AVE , ST PETERSBURG 53245

Insp Date: 07/21/2025

Inspection Number: 3644409

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

45-05-4

Observation

Portable fire extinguisher missing from its designated location. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805603

DUNKIN #354508

License Type: Food

2983 EXECUTIVE DR , VENICE 34292

Insp Date: 07/23/2025

Inspection Number: 3598744

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Observed the rear exit blocked by a trash can and discarded boxes. The operator cleared the exit path. **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Sarasota

License Number: 6805946

ORANGE OCTOPUS ICE CREAM CO

License Type: Food

4141 SOUTH TAMIAMI TRAIL UNIT 14, SARASOTA 34231

Insp Date: 07/24/2025

Inspection Number: 3607903

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Rear exit door locked. For reporting purposes only.
Repeat Violation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805733

ART OVATION HOTEL

License Type: Food

1255 N PALM AVE , SARASOTA 34236

Insp Date: 07/24/2025

Inspection Number: 3593414

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificate expired.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Sarasota

License Number: 6804572

15 SOUTH BY NAPULE

License Type: Food

15 S BLVD OF THE PRESIDENTS , SARASOTA 34236

Insp Date: 07/22/2025

Inspection Number: 3643637

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 propane tanks stored in the back hallway of the establishment. Employee placed the tanks outside.
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6603152

FLAVORS CUISINE & LOUNGE BAR

License Type: Food

686 SW BAYSHORE BLVD , PORT ST LUCIE 34983

Insp Date: 07/23/2025

Inspection Number: 3594723

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke not under hood suppression system. Notified Fire AHJ. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602881

MALAIKA CARIBBEAN CUISINE AND BAKERY

License Type: Food

658 SW PORT SAINT LUCIE BLVD , PORT ST LUCIE 34953

Insp Date: 07/24/2025

Inspection Number: 3630427

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Movable racks blocking door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

St. Lucie

License Number: 6603152

FLAVORS CUISINE & LOUNGE BAR

License Type: Food

686 SW BAYSHORE BLVD , PORT ST LUCIE 34983

Insp Date: 07/24/2025

Inspection Number: 3594723

Insp Type: Routine - Food

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke not under hood suppression system. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2025-07-24: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6605229

FLAVORS CUISINE AND LOUNGE BAR

License Type: Food

751 NW AIROSO BLVD , PORT ST LUCIE 34983

Insp Date: 07/22/2025

Inspection Number: 3642582

Insp Type: Routine - Food

Disposition: Administrative complaint
recommended

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Suppression system is installed, cooking equipment has been moved and is not inline with suppression syatyem system. Call fire and reported they will send someone out today.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7401795

BURGER KING

License Type: Food

825 NOVA RD , DAYTONA BEACH 32117

Insp Date: 07/24/2025

Inspection Number: 3650570

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment/broiler producing grease laden vapors/smoke with hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-When cooking burgers a heavy amount of smoke comes out of broiler and covers kitchen .

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407124

OLIVE GARDEN #4460

License Type: Food

1780 W INTERNATIONAL SPEEDWAY BLVD , DAYTONA BEACH 32114

Insp Date: 07/21/2025

Inspection Number: 3593162

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Water heater screen states blocked exhaust.For reporting purposes only.Manager will be calling tech

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407197

POLYNESIAN FIRE LUAU

License Type: Food

180 N BEACH ST , DAYTONA BEACH 32114

Insp Date: 07/22/2025

Inspection Number: 3569599

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.-partial block rear exit, per manager there is three feet between items stored in hallway - From follow-up inspection 2025-07-11: **Time Extended** - From follow-up inspection 2025-07-22:

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Volusia

License Number: 7408009

LUNA'S RESTAURANT

License Type: Food

2516 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 07/24/2025

Inspection Number: 3642106

Insp Type: Routine - Food

Disposition: Administrative complaint
recommended

Violation Code

49-01-4

Observation

Flammables stored/debris present in front of electrical switch panels inside establishment. For reporting purposes only.

Violation Citation

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.