



Report Date: 09/20/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Alachua

License Number: 1103773

TOSH

License Type: Food

2201 NE 2 ST , GAINESVILLE 32609

Insp Date: 09/16/2025

Inspection Number: 3626757

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two 20 pound propane tanks stored in back building. Managers placed tanks outside **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103454

CHINA EXPRESS OF GAINESVILLE

License Type: Food

6250 NW 23RD ST # 4 & 5 , GAINESVILLE 32653

Insp Date: 09/17/2025

Inspection Number: 3595390

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Back exit door blocked by shelf.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1550727

MNJ'S

License Type: Food

660 TUCKER LANE , COCOA 32926

Insp Date: 09/15/2025

Inspection Number: 1316326

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Brevard**

License Number: 1506337

HUNKER DOWN LOUNGE HIDEAWAY/CATEGORY 5

License Type: Food

9 S ATLANTIC AVE , COCOA BEACH 32931

Insp Date: 09/18/2025

Inspection Number: 3601891

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Behind the bar on hunker down side

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505871

JUICE N' JAVA CAFE

License Type: Food

75 N ORLANDO AVE , COCOA BEACH 32931

Insp Date: 09/17/2025

Inspection Number: 3633767

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tanks in office. Operator removed
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506547

SLOW & LOW BBQ

License Type: Food

5490 STADIUM PARKWAY , VIERA 32940

Insp Date: 09/15/2025

Inspection Number: 3641905

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed silver fire extinguisher in kitchen is meter is border line in the red.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Brevard

License Number: 1502089

BURGER KING #3734

License Type: Food

423 BARTON BLVD , ROCKLEDGE 32955

Insp Date: 09/19/2025

Inspection Number: 3637327

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver fire extinguisher meter in reading red

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505113

HANGRY JOE'S MELBOURNE

License Type: Food

1630 S WICKHAM RD , WEST MELBOURNE 32904

Insp Date: 09/19/2025

Inspection Number: 3642277

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher stowed on floor by hand wash station in kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Brevard

License Number: 1505113

HANGRY JOE'S MELBOURNE

License Type: Food

1630 S WICKHAM RD , WEST MELBOURNE 32904

Insp Date: 09/19/2025

Inspection Number: 3642277

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Light switch for kitchen lighting has no plastic cover exposed wires.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623691

VITOLO

License Type: Food

551 N FT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 09/15/2025

Inspection Number: 3602297

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
Repeat Violation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Broward

License Number: 1623881

VITOLO

License Type: Food

551 N FORT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 09/15/2025

Inspection Number: 3639995

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1625673

CAFE TOQUE CUBANO

License Type: Food

37 S FEDERAL HWY STE A , DANIA BEACH 33004

Insp Date: 09/12/2025

Inspection Number: 3612697

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed two table top fryers producing smoke while cooking meats

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/20/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1625864

CONRAD GOURMET MARKET

License Type: Food

551 N FORT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 09/15/2025

Inspection Number: 3622114

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
Repeat Violation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1623881

VITOLO

License Type: Food

551 N FORT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 09/16/2025

Inspection Number: 3639995

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2025-09-16: Observed same. **Time Extended**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Broward

License Number: 1623693

CONRAD EMPLOYEE DINING

License Type: Food

551 N FT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 09/16/2025

Inspection Number: 3630668

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2025-09-16: Observed same. **Time Extended**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1623693

CONRAD EMPLOYEE DINING

License Type: Food

551 N FT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 09/15/2025

Inspection Number: 3630668

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Calhoun

License Number: 1700136

GARRETT'S OYSTER BAR

License Type: Food

16039 SE RIVERSTREET , BLOUNTSTOWN 32424

Insp Date: 09/12/2025

Inspection Number: 3621248

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only.K-class extinguisher by bar in recharge zone.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2102711

SARKU JAPAN

License Type: Food

1858 TAMIAMI TRL N UNIT FC5A , NAPLES 34102

Insp Date: 09/17/2025

Inspection Number: 3621134

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone near front entrance. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/20/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Columbia

License Number: 2200620

HOLIDAY INN HOTEL & SUITES

License Type: Food

213 SW COMMERCE DR , LAKE CITY 32025

Insp Date: 09/16/2025

Inspection Number: 3652839

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.No fire extinguisher in extinguisher hanger in kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312526

SHORTY'S BAR-B-QUE

License Type: Food

9200 S DIXIE HWY , MIAMI 62930

Insp Date: 09/18/2025

Inspection Number: 3618607

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed mini flat top used for cooking across steam table.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330429

CADILLAC HOTEL & BEACH CLUB

License Type: Food

3925 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 09/18/2025

Inspection Number: 3637841

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Dade

License Number: 2319251

CLUB TIPICO DOMINICANO

License Type: Food

1342 NW 36 ST , MIAMI 25556

Insp Date: 09/18/2025

Inspection Number: 3666033

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher by rear exit door in recharge zone.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2357952

ALL STARS ROLLING CAFE

License Type: Food

18739 SW 107 AVE , MIAMI 33157

Insp Date: 09/18/2025

Inspection Number: 1317858

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-01-4

Observation

No portable fire extinguisher present. For reporting purposes only. Observed no fire extinguisher available.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Dade

License Number: 2334432

MLK RESTAURANT INC

License Type: Food

5931 NW 17 AVE , MIAMI 33142

Insp Date: 09/16/2025

Inspection Number: 3609069

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher by rear exit door in recharge zone.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328734

MIKE'S CAFE & DELI

License Type: Food

9155 S DADELAND BLVD #100 , MIAMI 33156

Insp Date: 09/17/2025

Inspection Number: 3624085

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Dade

License Number: 2336237

LORANAS CARIBBEAN AND AMERICAN GRILL

License Type: Food

19752 NW 27 AVE , MIAMI GARDENS 33056

Insp Date: 09/15/2025

Inspection Number: 3622244

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a grease fryer on top of the reach in cooler with no hood suppression system over it.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334748

DUNKIN DONUTS

License Type: Food

2360 W 68 ST #101 , HIALEAH 33016

Insp Date: 09/17/2025

Inspection Number: 3629638

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked by a tray cart. Operator removed it on site. For reporting purposes only. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Dade

License Number: 2332140

MONDRIAN CAFFE

License Type: Food

1100 WEST AVE , MIAMI BEACH 33139

Insp Date: 09/15/2025

Inspection Number: 3632519

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boiler certificate expired, already inspected. ****Corrective Action Taken****

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337178

BFF BURGERS

License Type: Food

9420 NW 41 ST #110 , DORAL 33178

Insp Date: 09/12/2025

Inspection Number: 3621050

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. ****Repeat Violation****

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Dade

License Number: 2334885

NAUTILUS SONESTA MIAMI BEACH

License Type: Food

1825 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 09/17/2025

Inspection Number: 3612095

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed jurisdiction numbers 133321; 133322 both expired on 05-18-2024.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337175

SHIMUJA

License Type: Food

9420 NW 41 S UNIT 102 , DORAL 33178

Insp Date: 09/12/2025

Inspection Number: 3641759

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Report Date: 09/20/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2337032

MR PORK BELLY

License Type: Food

9420 NW 41 ST UNIT 105 , DORAL 33178

Insp Date: 09/12/2025

Inspection Number: 3591397

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. **Repeat Violation**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337181

FOOD JOINT

License Type: Food

9420 NW 41 S UNIT 108 , DORAL 33178

Insp Date: 09/12/2025

Inspection Number: 3620222

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Dade

License Number: 2333189

CAFE

License Type: Food

1801 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 09/15/2025

Inspection Number: 3600276

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed jurisdiction numbers 053400 08/18/23- 055333 08/18/2023 are both expired.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2301749

PAULINE

License Type: Food

1801 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 09/16/2025

Inspection Number: 3606459

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed jurisdiction 053400 055333 expired on 08/18/2023

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Dade

License Number: 2338358

License Type: Food

BASEMENT KITCHEN AND WARM UP KITCHEN

1801 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 09/16/2025

Inspection Number: 3605268

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Both expired 053400 08/18/23- 055333 08/18/2023.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2330429

License Type: Food

CADILLAC HOTEL & BEACH CLUB

3925 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 09/19/2025

Inspection Number: 3637841

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

48-01-5

Observation

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2025-09-19: **Time Extended**

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Dade

License Number: 2312526

SHORTY'S BAR-B-QUE

License Type: Food

9200 S DIXIE HWY , MIAMI 62930

Insp Date: 09/19/2025

Inspection Number: 3618607

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed mini flat top used for cooking across steam table. - From follow-up inspection 2025-09-19: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2338232

SNDWCH SUNSET

License Type: Food

1573 SUNSET DR , CORAL GABLES 33143

Insp Date: 09/17/2025

Inspection Number: 3616836

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed miniature fryer at front counter with no hood system. **Repeat Violation** - From follow-up inspection 2025-09-17: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Dade

License Number: 2318666

LACARRETA RESTAURANT

License Type: Food

10633 NW 12 ST , MIAMI 22730

Insp Date: 09/12/2025

Inspection Number: 3601471

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2025-09-12: At time of callback inspection observed No current insurance inspector boiler report or boiler certificate available for boiler. **Time Extended**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2317295

BISTRO 103

License Type: Food

7707 NW 103 ST , HIALEAH GARDENS 33016

Insp Date: 09/16/2025

Inspection Number: 3562603

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2025-09-16: **Time Extended**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Dade

License Number: 2330048

VALE FOOD CO

License Type: Food

9537 S DIXIE HWY , MIAMI 33156

Insp Date: 09/12/2025

Inspection Number: 3664400

Insp Type: Complaint Full

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed cooking with no hood system next to dry food storage rack. - From follow-up inspection 2025-09-12: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613336

DAVOLI'S CATERING JAX

License Type: Food

3305 PARENTAL HOME RD , JACKSONVILLE 32216

Insp Date: 09/16/2025

Inspection Number: 1132076

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator has multiple propane tanks stored in garage storage area in building

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2652334

COSTENITO PESCADOR

License Type: Food

4815 SWEETGRASS PL UNIT 105 & 107 , JACKSONVILLE 32224

Insp Date: 09/19/2025

Inspection Number: 1318155

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Single tank propane stored inside food trailer

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Duval

License Number: 2600201

KRYSTAL RESTAURANT

License Type: Food

5707 UNIVERSITY BLVD W , JACKSONVILLE 32216

Insp Date: 09/19/2025

Inspection Number: 3622159

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher near back kitchen door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2616120

UNDERGROUND MARKET

License Type: Food

1352 N MAIN ST , JACKSONVILLE 32206

Insp Date: 09/19/2025

Inspection Number: 3617763

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Bratwurst, Philly cheese steaks, hot dogs and bacon cooked on a flat top grill, Small double table top fryer used to fry food items with no hood suppression system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Duval

License Number: 2615306

LE PETIT PARIS

License Type: Food

9965 SAN JOSE BLVD STE 46 , JACKSONVILLE 32257

Insp Date: 09/15/2025

Inspection Number: 3626102

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by stacked boxes. Moved by manager. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613108

DUNKIN & BASKIN ROBBINS STORE 336447

License Type: Food

5150 UNIVERSITY BLVD W , JACKSONVILLE 32216

Insp Date: 09/19/2025

Inspection Number: 3606142

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Back kitchen exit door blocked with trash can bins in front of it

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Duval

License Number: 2609881

ISLAND BREEZE CAFE

License Type: Food

3000 DUNN AVE STE 14 , JACKSONVILLE 32218

Insp Date: 09/17/2025

Inspection Number: 3643292

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In kitchen, 30# LP tank stored in hallway to back door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2616303

CENTY WAY

License Type: Food

10663 MONACO DR #105 , JACKSONVILLE 32218

Insp Date: 09/19/2025

Inspection Number: 3643482

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In back storage room across from men's restroom, 30# LP tank.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Escambia

License Number: 2706010

License Type: Food

COURTYARD BY MARRIOTT PENSACOLA DOWNTOWN

700 E CHASE ST , PENSACOLA 32502

Insp Date: 09/12/2025

Inspection Number: 3609786

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expired boiler certificate. Operator stated that they have had an inspection but have not yet received the update certificate.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2800736

License Type: Food

DUNKIN DONUTS/BASKIN ROBBINS

5290 E HWY 100 101 , PALM COAST 32164

Insp Date: 09/19/2025

Inspection Number: 3634521

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Exit door blocked by garbage cans. Person in charge moved garbage cans. **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Gadsden

License Number: 3050127

KESHA KRAZY KREATIONS

License Type: Food

31300 BLUE STAR HWY , MIDWAY 32343

Insp Date: 09/17/2025

Inspection Number: 1320200

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3600492

HOLIDAY INN EXPRESS HOTEL & SUITES

License Type: Food

1024 W SUGARLAND HWY , CLEWISTON 33440

Insp Date: 09/19/2025

Inspection Number: 3632355

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Jurisdiction FL136106 7/12/25

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Hernando

License Number: 3750482

PAPAS 1 GRILL

License Type: Food

12505 SPRING HILL DR , SPRING HILL 34609

Insp Date: 09/17/2025

Inspection Number: 1329167

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

45-01-4

Observation

No portable fire extinguisher present. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800799

MCDONALD'S RESTAURANTS OF FLORIDA INC

License Type: Food

3115 HWY 27 S , SEBRING 33870

Insp Date: 09/12/2025

Inspection Number: 3630640

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only.Observed boxes and a bin of garbage blocking the back exit door with no path to get through, employee moved. **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/20/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hillsborough

License Number: 3918774

LOS CHAPOS TACOS

License Type: Food

951 E 7 AVE , TAMPA 33605

Insp Date: 09/17/2025

Inspection Number: 3598178

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer in prep area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3910773

WHA GWAAN JAMAICA JAMAICA

License Type: Food

13910 W HILLSBOROUGH AVE , TAMPA 33635

Insp Date: 09/17/2025

Inspection Number: 3614212

Insp Type: Routine - Food

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 propane tanks stored in back kitchen adjacent to walkin cooler. - From follow-up inspection 2025-09-17: LP tanks remain in back hall way **Time Extended**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 4502282

CRACKER BARREL #489

License Type: Food

1520 E HWY 50 , CLERMONT 34711

Insp Date: 09/15/2025

Inspection Number: 3627338

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. -back door, operator corrected. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Lee

License Number: 4607253

KITCHEN SHARE BY CARDOOS

License Type: Food

4529 BAYSHORE RD , N FT MYERS 33917

Insp Date: 09/16/2025

Inspection Number: 3596173

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed speed rack and some crates blocking marked exit in back of building adjacent to unisex bathrooms. Operator moved items. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4603804

MARISCOS BAHIAS

License Type: Food

3651 EVANS AVE , FORT MYERS 33901

Insp Date: 09/19/2025

Inspection Number: 3594131

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed rear exit door locked. Operator unlocked door. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Lee

License Number: 4607953

SB BAR

License Type: Food

23111 FASHION DRIVE STE 105/K07A , ESTERO 33928

Insp Date: 09/16/2025

Inspection Number: 3595215

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

49-05-4

Observation

Flammables stored near a source of ignition. For reporting purposes only. Observed propane tank stored inside kitchen area.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4703265

WENDY'S #158

License Type: Food

3451 BANNERMAN RD , TALLAHASSEE 32312

Insp Date: 09/15/2025

Inspection Number: 3596929

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

49-05-4

Observation

Flammables stored near a source of ignition. For reporting purposes only. Cardboard boxes on water heater. Removed during inspection. **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/20/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Monroe

License Number: 5401508

HOG HEAVEN

License Type: Food

85361 OVERSEAS , ISLAMORADA 63415

Insp Date: 09/12/2025

Inspection Number: 3634933

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. The fire extinguisher by the back door where the smoker is located.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5401810

ARBY'S #5580

License Type: Food

101377 OVERSEAS HWY , KEY LARGO 33037

Insp Date: 09/12/2025

Inspection Number: 3631231

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed smoke coming from fryers, as per operator hood suppression system is not working.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5812949

KREMBO

License Type: Food

8015 TURKEY LAKE RD STE 200 , ORLANDO 32819

Insp Date: 09/12/2025

Inspection Number: 3636063

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Located on the floor in dry storage.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/20/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5815267

License Type: Food

NEIGHBORS

3201 CORRINE DR STE 201 , ORLANDO 32803

Insp Date: 09/15/2025

Inspection Number: 3587369

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.FL 136487 expired on 12/28/23

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5814183

License Type: Food

OLD CUBAN CAFÉ

12014 E COLONIAL DR STE 180 , ORLANDO 32826

Insp Date: 09/15/2025

Inspection Number: 3592199

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.2 25 lbs tanks **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Osceola

License Number: 5908782

SONIC DRIVE-IN #4175

License Type: Food

4350 W 13 ST , SAINT CLOUD 34769

Insp Date: 09/18/2025

Inspection Number: 3607670

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Back door blocked by hose

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Palm Beach

License Number: 6007687

RICE KING

License Type: Food

1225 45 ST #503 , WEST PALM BEACH 33407

Insp Date: 09/17/2025

Inspection Number: 3609326

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. At the entrance to the kitchen, the silver extinguisher is in the recharge zone.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6022738

REGGAE JERK OF THE PALM BEACHES

License Type: Food

1225 45 ST UNIT 508 , MANGONIA PARK 33407

Insp Date: 09/17/2025

Inspection Number: 3641416

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. At the entrance to the kitchen, the silver extinguisher is in the red area.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Pasco

License Number: 6151104

BEE COFFEE 2

License Type: Food

2205 COLLIER PKWY , LAND O' LAKES 34639

Insp Date: 09/17/2025

Inspection Number: 1317122

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Grill flat top cooking eggs and bacon not under hood system. - From follow-up inspection 2025-09-17: No food cooking **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216232

CHIPOTLE MEXICAN GRILL-1041

License Type: Food

1418 66 ST N , ST. PETERSBURG 33710

Insp Date: 09/16/2025

Inspection Number: 3664402

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Back exit blocked with empty boxes.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Sarasota

License Number: 6805106

LITTLE CAESARS PIZZA

License Type: Food

2866 RINGLING BLVD , SARASOTA 34237

Insp Date: 09/16/2025

Inspection Number: 3628472

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed their marked fire exit door from their office blocked. Operator unblocked it. **Corrected On-Site** **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6804340

HUNGRY HOWIES

License Type: Food

1085-B N TAMIAMI TRL , NOKOMIS 34275

Insp Date: 09/18/2025

Inspection Number: 3608115

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

46-04-4

- From initial inspection : Rear exit door locked. For reporting purposes only. - From follow-up inspection 2025-09-18: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6500724

CARRIAGEWAY FLORIDA LLC

License Type: Food

70 CUNA ST , ST AUGUSTINE 32084

Insp Date: 09/15/2025

Inspection Number: 3610880

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Electrical outlet above dish machine needs to be covered.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/20/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

St. Lucie

License Number: 6602915

COSTA AZUL MEXICAN RESTAURANT AND CATERING

License Type: Food

2311 OKEECHOBEE RD , FORT PIERCE 34950

Insp Date: 09/16/2025

Inspection Number: 3619886

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Gray exit door blocked by decor and table. Operator removed. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602856

WASABI THAI SUSHI

License Type: Food

217 ORANGE AVE , FORT PIERCE 34950

Insp Date: 09/15/2025

Inspection Number: 3637732

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. 2 tier shelf holding plates blocking black door. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406045

HIBACHI GRILL SUPREME BUFFET

License Type: Food

1312 W INTERNATIONAL SPEEDWAY BLVD , DAYTONA BEACH 32114

Insp Date: 09/15/2025

Inspection Number: 3665145

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-exit next to sushi bar partially blocked by floor cleaner **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Volusia

License Number: 7407333

WINGSTOP

License Type: Food

1344 W INTERNATIONAL SPEEDWAY BLVD , DAYTONA BEACH 32114

Insp Date: 09/15/2025

Inspection Number: 3639296

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.- box with cooler partial blocking rear exit - hose holder partial blocking rear exit

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407273

MR CHEF INDIAN CUISINE INC

License Type: Food

1200 DELTONA BLVD SUITE 59A, DELTONA 32725

Insp Date: 09/16/2025

Inspection Number: 3593263

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-mop bucket and large pots stored on the floor in front of rear exit door in hallway near bathrooms

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/20/2025

Volusia

License Number: 7407833

MAMA KITCHEN

License Type: Food

2200 W INTERNATIONAL SPWY BLVD STE 5B, DAYTONA BEACH 32114

Insp Date: 09/16/2025

Inspection Number: 3642639

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only.-electric bike

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.