



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Alachua

License Number: 1102617

HOOK FISH & CHICKEN

License Type: Food

1340 E UNIVERSITY AVE , GAINESVILLE 32641

Insp Date: 10/06/2025

Inspection Number: 3661764

Insp Type: Complaint Partial

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Hood system not working per person in charge, establishment open with fryers turned on no ventilation system turned on.
Warning

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1101104

BURGER KING #2314

License Type: Food

3902 SW 40TH BLVD , GAINESVILLE 32608

Insp Date: 10/07/2025

Inspection Number: 3605122

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed : the fire extinguisher by the back door, charge indicator is in the red zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Alachua

License Number: 1102576

PAPA JOHN'S PIZZA #498

License Type: Food

3605 SW ARCHER RD , GAINESVILLE 32608

Insp Date: 10/07/2025

Inspection Number: 3619517

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only. Observed cardboard box less than six inches from the gas fired hot water heater. The box and rack were moved away. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305943

HOMewood SUITES

License Type: Food

47 CHIP SEAL PKWY , PANAMA CITY BEACH 32407

Insp Date: 10/10/2025

Inspection Number: 3627831

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed water heaters with max input BTU of 751,000.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Brevard

License Number: 1505545

BELLA LUNA RESTAURANT AND PIZZA

License Type: Food

7155 N WICKHAM RD , MELBOURNE 32940

Insp Date: 10/10/2025

Inspection Number: 3598542

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver extinguisher meter boarder line is reading between green and red

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506550

TRACY'S LOUNGE

License Type: Food

6979 N WICKHAM RD , MELBOURNE 32940

Insp Date: 10/10/2025

Inspection Number: 3611415

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver extinguisher in kitchen is boarding line meter between green and red

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621115

PAL RANCHO

License Type: Food

5637 CORAL RIDGE DR , CORAL SPRINGS 33076

Insp Date: 10/08/2025

Inspection Number: 3591639

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Back exit door near bakery prep area blocked by boxes and equipment.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 10/11/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1626298

BLU' STEAKHOUSE

License Type: Food

1900 HARRISON ST , HOLLYWOOD 33020

Insp Date: 10/09/2025

Inspection Number: 3618945

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at fire extinguisher next to back door. Operator replaced ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621906

THIRTY1 LOUNGE INC

License Type: Food

1931 HOLLYWOOD BLVD , HOLLYWOOD 33020

Insp Date: 10/10/2025

Inspection Number: 3671904

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

47-02-4

- From initial inspection : Observed scorch marks around electrical outlet. For reporting purposes only. Observed at electrical outlet above three compartment sink - From follow-up inspection 2025-10-10: Observed same

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621906

THIRTY1 LOUNGE INC

License Type: Food

1931 HOLLYWOOD BLVD , HOLLYWOOD 33020

Insp Date: 10/09/2025

Inspection Number: 3671904

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only. Observed at electrical outlet above three compartment sink

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 10/11/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Clay

License Number: 2001448

SUBWAY

License Type: Food

756 PARK AVENUE SUITE 111 , ORANGE PARK 32073

Insp Date: 10/06/2025

Inspection Number: 3630954

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher missing from designated hook at front door. Operator states it is out of date and is getting a new one.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2103286

AL CARBON Y MAS

License Type: Food

6002 RADIO RD , NAPLES 34104

Insp Date: 10/06/2025

Inspection Number: 3598674

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone at bar area and kitchen entrance. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2101883

ROMA IN LIMA PIZZA & CUISINE LLC

License Type: Food

1025 W MAIN ST , IMMOKALEE 34142

Insp Date: 10/10/2025

Inspection Number: 3607042

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed chairs stored in the hallway leading to the fire exit. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Collier

License Number: 2101883

ROMA IN LIMA PIZZA & CUISINE LLC

License Type: Food

1025 W MAIN ST , IMMOKALEE 34142

Insp Date: 10/10/2025

Inspection Number: 3607042

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed rear exit door locked. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2102261

AQUA SEAFOOD & STEAKS

License Type: Food

862 5 AVE S , NAPLES 34102

Insp Date: 10/10/2025

Inspection Number: 3611245

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone near cook line. For reporting purposes only.
- From follow-up inspection 2025-10-10: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2103286

AL CARBON Y MAS

License Type: Food

6002 RADIO RD , NAPLES 34104

Insp Date: 10/10/2025

Inspection Number: 3598674

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone at bar area and kitchen entrance. For reporting purposes only. - From follow-up inspection 2025-10-10: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Dade

License Number: 2334894

PRETTY HEALTHY

License Type: Food

17560 NW 27 AVE STE 123 , MIAMI 33056

Insp Date: 10/10/2025

Inspection Number: 3633425

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed 4 electrical stove to cook shrimp, salmon and chicken stored in the back prep area.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337568

SADELLE'S / KITH

License Type: Food

69 NE 41 ST , MIAMI 33137

Insp Date: 10/10/2025

Inspection Number: 3639413

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-06-4

Observation

Portable fire extinguisher is inaccessible. For reporting purposes only. Observed fire extinguisher stored on floor by mop sink area.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Dade

License Number: 2334007

LITTLE CAESARS PIZZA

License Type: Food

15457 SW 137 AVE , MIAMI 33177

Insp Date: 10/08/2025

Inspection Number: 3620225

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Observed path to marked exit blocked with trash bin.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335330

TOWNEPLACE SUITES MIAMI HOMESTEAD

License Type: Food

935 NE 30TH TERRACE , HOMESTEAD 33033

Insp Date: 10/10/2025

Inspection Number: 3613537

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL 132462 expired on 06/06/2025 FL 132463 expired on 06/06/2025

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Dade

License Number: 2335732

TOPGOLF USA MIAMI GARDENS

License Type: Food

17321 NW 7 AVE , MIAMI GARDENS 33169

Insp Date: 10/03/2025

Inspection Number: 3626265

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. At the time of the inspection observed water heating device with a maximum input of 499990 btu. Observed establishment submitted inspection request. No boiler certificate provided.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2322855

FRITANGA LA GATA

License Type: Food

2175 SW 1 ST , MIAMI 33135

Insp Date: 10/06/2025

Inspection Number: 3658141

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. By the restrooms: child chairs and pressure cleaner blocking the door - From follow-up inspection 2025-10-06: By the restrooms: child chairs and pressure cleaner blocking the door **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Dade

License Number: 2337151

SHOMA BAZAAR

License Type: Food

9420 NW 41 ST , DORAL 33178

Insp Date: 10/03/2025

Inspection Number: 3633737

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. **Repeat Violation** - From follow-up inspection 2025-10-03: **Time Extended**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Duval

License Number: 2613975

SUBWAY

License Type: Food

1440 DUNN AVE STE 12A , JACKSONVILLE 32218

Insp Date: 10/07/2025

Inspection Number: 3607583

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only.Back exit blocked by large wooden bar.
Repeat Violation

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2607904

PIER 1515

License Type: Food

1515 PRUDENTIAL DR , JACKSONVILLE 32207

Insp Date: 10/08/2025

Inspection Number: 3606512

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.Boiler certificate expired on 10/4/25, inspector is coming soon to inspect

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Flagler

License Number: 2800484

BURGER KING

License Type: Food

6115 E HWY 100 , FLAGLER BEACH 32136

Insp Date: 10/06/2025

Inspection Number: 3612489

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-05-4

Observation

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on ground next to ice machine. **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800507

TACO BELL 26462

License Type: Food

1020 PALM COAST PKWY , PALM COAST 32137

Insp Date: 10/06/2025

Inspection Number: 3606355

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by trash cans and boxes. Person in charge moved all. **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Flagler

License Number: 2800794

MCDONALD'S #36363

License Type: Food

4851 BELLE TERRE PKWY , PALM COAST 32137

Insp Date: 10/03/2025

Inspection Number: 3636092

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Exit blocked by cart. Person in charge moved cart. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800542

ORIENTAL GARDEN OF PALM COAST

License Type: Food

115 FLAGLER PLAZA DR , PALM COAST 32137

Insp Date: 10/08/2025

Inspection Number: 3605048

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Boxes blocking entry into back door from outside.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3500270

RESTAURANT EL MESQUITE

License Type: Food

825 SR 66 , ZOLFO SPRINGS 33890

Insp Date: 10/08/2025

Inspection Number: 3591945

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Observed a table blocking the exit door in the dining room.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Highlands

License Number: 3801041

PIZZANOS PIZZA

License Type: Food

4141 US HWY 27 N STE# 10 , SEBRING 33870

Insp Date: 10/06/2025

Inspection Number: 3643675

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher next to the bathroom in the red.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3801041

PIZZANOS PIZZA

License Type: Food

4141 US HWY 27 N STE# 10 , SEBRING 33870

Insp Date: 10/06/2025

Inspection Number: 3643675

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Observed one of the exit doors is blocked, owner stated the door is in disrepair and does not work.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Hillsborough**

License Number: 3906539

SMOKIN ACES STEAKHOUSE

License Type: Food

2509 N PARK RD , PLANT CITY 33563

Insp Date: 10/07/2025

Inspection Number: 3599283

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed left fryer on cook line extended beyond hood system by approximately 6 inches

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918458

WENDY'S #11662

License Type: Food

3906 S US HWY 301 , RIVERVIEW 33578

Insp Date: 10/08/2025

Inspection Number: 3617385

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Back exit near dry storage blocked by garbage cart.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906539

SMOKIN ACES STEAKHOUSE

License Type: Food

2509 N PARK RD , PLANT CITY 33563

Insp Date: 10/08/2025

Inspection Number: 3599283

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed left fryer on cook line extended beyond hood system by approximately 6 inches
- From follow-up inspection 2025-10-08: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Lake

License Number: 4508431

CHINA GOURMET

License Type: Food

1714 US HWY 27 STE 20 , CLERMONT 34714

Insp Date: 10/03/2025

Inspection Number: 3618055

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only.-by back door

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4607133

JONESEZ

License Type: Food

3802 DR MARTIN LUTHER KING JR BLVD , FORT MYERS 33916

Insp Date: 10/08/2025

Inspection Number: 3667775

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone at kitchen. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Lee

License Number: 4651099

TAQUITOS TIERRA CALIENTE

License Type: Food

1400 COLONIAL BLVD STE 35 , FORT MYERS 33907

Insp Date: 10/08/2025

Inspection Number: 1318253

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4607472

ZEN DELI

License Type: Food

15880 SAN CARLOS BLVD #130 & 135 , FORT MYERS 33908

Insp Date: 10/03/2025

Inspection Number: 3644465

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Fryers in back food preparation area without hood suppression system. Notified Fire AHJ. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Lee

License Number: 4607781

License Type: Food

FILAMENT RESTAURANT HOTEL BANYAN FORT MYERS

1520 BROADWAY #104 , FORT MYERS 33901

Insp Date: 10/06/2025

Inspection Number: 3615250

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Observed fryers located in kitchen with no hood system. Notified Fire AHJ. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4607037

License Type: Food

MOES SOUTHWEST GRILL #100499

3405 FORUM BLVD STE 102 , FORT MYERS 33905

Insp Date: 10/09/2025

Inspection Number: 3644504

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Observed marked exit door in rear of kitchen blocked by trash can and empty box. Operator moved items. **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Lee

License Number: 4607781

FILAMENT RESTAURANT HOTEL BANYAN FORT MYERS

License Type: Food

1520 BROADWAY #104 , FORT MYERS 33901

Insp Date: 10/06/2025

Inspection Number: 3615250

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed boxes blocking fire exit door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605779

APPLEBEE'S NEIGHBORHOOD GRILL AND BAR

License Type: Food

8243 DANI DR , FORT MYERS 33966

Insp Date: 10/09/2025

Inspection Number: 3625933

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked by a cart with boxes. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Lee

License Number: 4607768

LICENSE TO CHILL

License Type: Food

251 CRESCENT ST , FORT MYERS BEACH 33931

Insp Date: 10/09/2025

Inspection Number: 3638080

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only. At GFIC outlet next to hand sink at cooks line.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5105855

DUNKIN DONUTS 346802

License Type: Food

14405 SR 70 EAST , BRADENTON 34211

Insp Date: 10/09/2025

Inspection Number: 3601991

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed the fire extinguisher on the floor next to the back door. It needs to be secured on the wall.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Marion

License Number: 5202132

OMALLY'S ALLEY

License Type: Food

24 S MAGNOLIA , OCALA 34471

Insp Date: 10/06/2025

Inspection Number: 3640653

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher across from back door.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5250851

LUPITAS TAQUERIA

License Type: Food

809 N MAGNOLIA AVE , OCALA 34475

Insp Date: 10/03/2025

Inspection Number: 1325318

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher next to back door.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Orange

License Number: 5812689

ALEX GYRO AND CHEESESTEAKS

License Type: Food

7310 E COLONIAL DR , ORLANDO 32807

Insp Date: 10/06/2025

Inspection Number: 3599651

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

49-05-4

Observation

Flammables stored near a source of ignition. For reporting purposes only. 15.lb propane tank, burner stored in kitchen area.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911975

CHIPOTLE MEXICAN GRILL 4810

License Type: Food

890 E IRLO BRONSON MEMORIAL HWY , ST. CLOUD 34769

Insp Date: 10/06/2025

Inspection Number: 3638384

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by trash cans and boxes Operator moved to the side to make exit accessible **Corrected On -Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Palm Beach

License Number: 6009269

JERK ISLAND TAKE OUT REST

License Type: Food

1739 W 45 ST , WEST PALM BEACH 72165

Insp Date: 10/07/2025

Inspection Number: 3619185

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Red extinguisher at the rear door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6051736

TACOS Y ANTOJITOS EMANUEL INC

License Type: Food

8110 MONETARY DR , RIVIERA BEACH 33404

Insp Date: 10/06/2025

Inspection Number: 1322707

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. The silver extinguisher at the rear of the truck.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Pinellas

License Number: 6217048

MARY MARGARET'S OLDE IRISH TAVERN

License Type: Food

29 3 ST N , ST. PETERSBURG 33701

Insp Date: 10/03/2025

Inspection Number: 3637380

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguishers located near back door next to bathrooms.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211181

WATER COLOUR STEAK HOUSE AND GRILL

License Type: Food

1201 GULF BLVD , CLEARWATER BEACH 33767

Insp Date: 10/10/2025

Inspection Number: 3624449

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL139985, FL139984, FL137613, FL137614, all exp 9/21/2025 - From follow-up inspection 2025-10-10: **Time Extended**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Putnam

License Number: 6400926

NEXT DOOR SUBS

License Type: Food

103 CHEYENNE AVE UNIT 1 AND 2 , INTERLACHEN 32148

Insp Date: 10/03/2025

Inspection Number: 3668246

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Flat top griddles used for cooking, produce grease laden vapors. Called local fire authority during inspection. No answer, will reattempt.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/11/2025

Sarasota

License Number: 6804774

BOB EVANS RESTAURANT 463

License Type: Food

5903 BROOKHILL BLVD , SARASOTA 26302

Insp Date: 10/03/2025

Inspection Number: 3645175

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed their sanitizer the back exit fire extinguisher in the red.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6801728

PHILLIPPI CREEK VILLAG OYS BAR

License Type: Food

5353 S TAMIAMI TRL , SARASOTA 14200

Insp Date: 10/07/2025

Inspection Number: 3612349

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone at the server station in front of the oyster bar. For reporting purposes only. - From follow-up inspection 2025-10-07: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.