



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Alachua

License Number: 1102958

WOODSPRING SUITES

License Type: Lodging

5505 SW 41ST BLVD , GAINESVILLE 32608

Insp Date: 01/06/2025

Inspection Number: 1176385

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed: the gentex hearing impaired smoke detector does not have any wires for connection. - From follow-up inspection 2025-01-06: The gentex hearing impaired smoke detectors lack any connecting wires.
Time Extended

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1612914

THE_TERRACES JACARANDA CLUB LUXURY RENTALS

License Type: Lodging

8101 NW 14 ST , PLANTATION 33322

Insp Date: 01/08/2025

Inspection Number: 1582957

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.Observed next to apartment 1385.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Broward

License Number: 1616673

FAIRWAYS OF CAROLINA

License Type: Lodging

2701 ROCK ISLAND RD , MARGATE 33063

Insp Date: 01/09/2025

Inspection Number: 1593281

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.Observed at unit 112 building 2551

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1613659

PINEBROOK POINTE

License Type: Lodging

3495 PINEWALK DRIVE NORTH , MARGATE 33063

Insp Date: 01/08/2025

Inspection Number: 1588312

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.Observed at building 3445 unit 103, building 3425 unit 109

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Broward

License Number: 1620897

EXTENDED STAY AMERICA SUITES 8021

License Type: Lodging

1400 SW 11TH WAY , DEERFIELD BEACH 33441

Insp Date: 01/03/2025

Inspection Number: 1179351

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. Observed at fire extinguisher by front office. For reporting purposes only.
Repeat Violation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1616673

FAIRWAYS OF CAROLINA

License Type: Lodging

2701 ROCK ISLAND RD , MARGATE 33063

Insp Date: 01/09/2025

Inspection Number: 1593281

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at unit 304 building 2601

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Broward

License Number: 1605690

WILTON HOUSE APARTMENTS

License Type: Lodging

2727 N ANDREWS AVE , WILTON MANORS 33311

Insp Date: 01/06/2025

Inspection Number: 1583851

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed in building B 210- 206.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1613659

PINEBROOK POINTE

License Type: Lodging

3495 PINEWALK DRIVE NORTH , MARGATE 33063

Insp Date: 01/08/2025

Inspection Number: 1588312

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at building 3485 unit 102, Building 3445 unit 107, building 3405 unit 102

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Broward

License Number: 1618409

EXTENDED STAY AMERICA SUITES #328

License Type: Lodging

1200 FAU RESEARCH PARK BLVD , DEERFIELD BEACH 33441

Insp Date: 01/03/2025

Inspection Number: 1179352

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit 137 and 313. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2200606

FAIRFIELD INN

License Type: Lodging

538 SW CORPORATE DR , LAKE CITY 32024

Insp Date: 01/06/2025

Inspection Number: 1178505

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Needle in recharge red area of extinguisher at room 318 .

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329342

COURTNEY REALTY LLC

License Type: Lodging

576 NE 63 ST , MIAMI 33138

Insp Date: 01/10/2025

Inspection Number: 1599298

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher is in need of recharge at entrance of building first floor.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Dade

License Number: 2316403

CUTLER MANOR APARTMENTS

License Type: Lodging

10875 SW 216 ST , MIAMI 03103

Insp Date: 01/10/2025

Inspection Number: 1623187

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed throughout the property. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2311837

NORTH MIAMI BEACH GARDEN INN & SUITE

License Type: Lodging

148 NW 167 ST , MIAMI 33169

Insp Date: 01/07/2025

Inspection Number: 1240911

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. In the office.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329342

COURTNEY REALTY LLC

License Type: Lodging

576 NE 63 ST , MIAMI 33138

Insp Date: 01/10/2025

Inspection Number: 1599298

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. Observed no power at FACP located at back exit door entrance of the building.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Dade

License Number: 2329276

BEST WESTERN MIAMI EXECUTIVE AIRPORT

License Type: Lodging

13700 SW 139 CT , MIAMI 33186

Insp Date: 01/06/2025

Inspection Number: 1183234

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expired boiler certificate for 124631 and 124632 02/11/2024. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329452

GIRASOLE APARTMENTS

License Type: Lodging

5445 COLLINS AVENUE CU 10 , MIAMI BEACH 33140

Insp Date: 01/03/2025

Inspection Number: 1183215

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Extinguisher located in front of the office at the lower lobby. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Dade

License Number: 2329336

KL FLORIDA, LLC

License Type: Lodging

418 MERIDIAN AVE , MIAMI BEACH 33139

Insp Date: 01/10/2025

Inspection Number: 1183228

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329463

DCROSS MANAGEMENT

License Type: Lodging

5445 COLLINS AVENUE UNIT C17 , MIAMI BEACH 33140

Insp Date: 01/03/2025

Inspection Number: 1178694

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-01-4

Observation

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. observed fire extinguisher at the lower lobby without breaking device. Extinguisher is located in front of Girasol Apartments office . **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Dade

License Number: 2303471

RAINBOW MOTEL

License Type: Lodging

835 SW 24 AVE , MIAMI 33135

Insp Date: 01/03/2025

Inspection Number: 1237171

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-06-4

Observation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By door 27

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306182

DAYS II APTS

License Type: Lodging

7760 TATEM WATERWAY DR , MIAMI BEACH 11858

Insp Date: 01/07/2025

Inspection Number: 1582358

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-06-4

Observation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed by units 3 and 7. **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Dade

License Number: 2329307

AC HOTEL MIAMI BEACH

License Type: Lodging

2912 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 01/06/2025

Inspection Number: 1178253

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed on the main panel.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317199

INTERCONTINENTAL HOTEL MIAMI

License Type: Lodging

100 CHOPIN PLAZA , MIAMI 33131

Insp Date: 01/10/2025

Inspection Number: 1178880

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Dade

License Number: 2329442

WYNDHAM GARDEN MIAMI INTERNATIONAL AIRPORT

License Type: Lodging

4909 NW 36 ST , MIAMI SPRINGS 33166

Insp Date: 01/10/2025

Inspection Number: 1178156

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329463

DCROSS MANAGEMENT

License Type: Lodging

5445 COLLINS AVENUE UNIT C17 , MIAMI BEACH 33140

Insp Date: 01/03/2025

Inspection Number: 1178694

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light flashing (main panel at the lobby) ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Dade

License Number: 2322655

SONESTA SELECT MIAMI LAKES

License Type: Lodging

15700 NW 77 CT , MIAMI LAKES 33016

Insp Date: 01/07/2025

Inspection Number: 1239712

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329509

ALDEN HOTEL

License Type: Lodging

2925 INDIAN CREEK DR , MIAMI BEACH 33140

Insp Date: 01/06/2025

Inspection Number: 1178875

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

05-02-5

Observation

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Maintenance employee is conducting innovations to fix the issue. ****Corrective Action Taken** **Repeat Violation****

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Dade

License Number: 2322655

SONESTA SELECT MIAMI LAKES

License Type: Lodging

15700 NW 77 CT , MIAMI LAKES 33016

Insp Date: 01/07/2025

Inspection Number: 1239712

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL 134455 expired 8/12/2023, FL 124009 expired 8/12/2023. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329276

BEST WESTERN MIAMI EXECUTIVE AIRPORT

License Type: Lodging

13700 SW 139 CT , MIAMI 33186

Insp Date: 01/07/2025

Inspection Number: 1183234

Insp Type: Complaint Full

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expired boiler certificate for 124631 and 124632 02/11/2024. **Repeat Violation** - From follow-up inspection 2025-01-07: Observed for 124631 Expiration date 02/21/2026. **Time Extended**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Dade

License Number: 2322655

SONESTA SELECT MIAMI LAKES

License Type: Lodging

15700 NW 77 CT , MIAMI LAKES 33016

Insp Date: 01/07/2025

Inspection Number: 1235096

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-01-07: ****Time Extended****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327515

EXTENDED STAY AMERICA

License Type: Lodging

6605 NW 7 ST , MIAMI 33126

Insp Date: 01/09/2025

Inspection Number: 1177896

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boilers FL055351 expired on 08/12/22, FL 055350 expired 08/12/22 - From follow-up inspection 2024-12-30: Observed boilers FL055351 expired on 08/12/22, FL 055350 expired 08/12/22 ****Time Extended**** - From follow-up inspection 2025-01-09: Observed boilers FL055351 expired on 08/12/22, FL 055350 expired 08/12/22 - From follow-up inspection 2024-12-30: Observed boilers FL055351 expired on 08/12/22, FL 055350 expired 08/12/22 ****Time Extended****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Duval

License Number: 2612318

SONESTA SIMPLY SUITES JACKSONVILLE

License Type: Lodging

4990 BELFORT RD , JACKSONVILLE 32256

Insp Date: 01/06/2025

Inspection Number: 1177348

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Hammer missing from locked fire extinguisher in gazebo to left of building.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612318

SONESTA SIMPLY SUITES JACKSONVILLE

License Type: Lodging

4990 BELFORT RD , JACKSONVILLE 32256

Insp Date: 01/06/2025

Inspection Number: 1177348

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. Only expired boiler certificate posted in boiler room.

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Duval

License Number: 2600595

REGENCY INN

License Type: Lodging

6237 ARLINGTON EXPY , JACKSONVILLE 32211

Insp Date: 01/06/2025

Inspection Number: 1240835

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2600571

NINORA LLC

License Type: Lodging

4565 LEXINGTON AVE , JACKSONVILLE 32210

Insp Date: 01/08/2025

Inspection Number: 1601381

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-05-4

Observation

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed fire extinguisher on second floor of units 3 and 4 inaccessible.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Duval

License Number: 2608853

EMBASSY SUITES JACKSONVILLE

License Type: Lodging

9300 BAYMEADOWS RD , JACKSONVILLE 32256

Insp Date: 01/03/2025

Inspection Number: 1176107

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher by 528, 515 missing hammer.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608853

EMBASSY SUITES JACKSONVILLE

License Type: Lodging

9300 BAYMEADOWS RD , JACKSONVILLE 32256

Insp Date: 01/03/2025

Inspection Number: 1176107

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate expired 11.16.24. Was reinspected 12.2024 per person in charge has yet to issue new certificate.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Duval

License Number: 2609173

STAYABLE SUITES JACKSONVILLE

License Type: Lodging

812 DUNN AVE , JACKSONVILLE 32218

Insp Date: 01/03/2025

Inspection Number: 1240899

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.Unable to access fire extinguisher, by laundry room, by 112, 318, 218, 219, 227,

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912245

EXTENDED STAY AMERICA #1569

License Type: Lodging

4811 MEMORIAL HWY , TAMPA 33634

Insp Date: 01/07/2025

Inspection Number: 1183238

Insp Type: Complaint Full

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.By room 210.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Hillsborough

License Number: 3900300

KELLYS PLACE

License Type: Lodging

2821 NEBRASKA AVE , TAMPA 21727

Insp Date: 01/09/2025

Inspection Number: 1588473

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Unable to determine if the extinguishers are in each unit, due to external inspection only. No office.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3907679

OASIS BAY SUITES

License Type: Lodging

3001 UNIVERSITY CENTER DR , TAMPA 33612

Insp Date: 01/03/2025

Inspection Number: 1177737

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Hillsborough

License Number: 3912329

HILTON GARDEN INN TAMPA NORTH

License Type: Lodging

13305 TAMPA OAKS BLVD , TEMPLE TERRACE 33637

Insp Date: 01/09/2025

Inspection Number: 1176255

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2025-01-09: Manager stated that they are waiting on the company Brennick Brothers to send out an inspector but the company is currently backed up. **Time Extended**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4502678

HOME2 SUITES BY HILTON

License Type: Lodging

1450 CHAMPIONS WAY , CLERMONT 34711

Insp Date: 01/10/2025

Inspection Number: 1178918

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Levy

License Number: 4800383

License Type: Lodging

QUALITY INN

1125 N YOUNG BLVD , CHIEFLAND 32626

Insp Date: 01/03/2025

Inspection Number: 1239855

Insp Type: Complaint Partial

Disposition: Call Back - Admin. complaint recommended

Violation Code

04-02-4

Observation

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Smoke alarm removed from wall and sitting on towel rack inside room #208. Smoke alarm is not functioning. **Warning** - From follow-up inspection 2025-01-03: Manager stated room #208 was occupied. Smoke detector missing from wall with wires hanging inside room #102. **Admin Complaint**

Violation Citation

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Monroe

License Number: 5403173

FAIRFIELD INN & SUITES

License Type: Lodging

13201 OVERSEAS HWY , MARATHON 33050

Insp Date: 01/03/2025

Inspection Number: 1182444

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5403173

FAIRFIELD INN & SUITES

License Type: Lodging

13201 OVERSEAS HWY , MARATHON 33050

Insp Date: 01/03/2025

Inspection Number: 1182444

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-06-4

In laundry area the lint room has an alarm emitting an audible alarm. For reporting purposes only. This alarm is. This audible alarm is coming from a water heating device in lint room

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 01/11/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Nassau

License Number: 5500967

SPRINGHILL SUITES AMELIA ISLAND

License Type: Lodging

2700 ATLANTIC AVE STE 2 , AMELIA ISLAND 32034

Insp Date: 01/09/2025

Inspection Number: 1177380

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. Boiler certificates kept in office. Manager states boiler certificates will be moved by boilers.
Corrective Action Taken

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500968

COURTYARD AMELIA ISLAND

License Type: Lodging

2700 ATLANTIC AVE STE 1 , AMELIA ISLAND 32034

Insp Date: 01/09/2025

Inspection Number: 1177656

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. Boiler certificates kept in office. Manager states boiler certificates will be moved by boilers.
Corrective Action Taken

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Orange

License Number: 5811135

AVANTI RESORT

License Type: Lodging

8738 INTERNATIONAL DR , ORLANDO 32819

Insp Date: 01/07/2025

Inspection Number: 1183199

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. All boiler certificates expired 12/14/2024. 133041, 137034, 133040, 135984, 130602, 133038, 135343, 133139, 133215.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811179

COURTYARD LAKE BUENA VISTA

License Type: Lodging

8501 PALM PKWY , ORLANDO 32836

Insp Date: 01/09/2025

Inspection Number: 1178407

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate 134332 12/13/2024 expired

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Osceola

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 01/07/2025

Inspection Number: 1183236

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. Operator has signage throughout lobby saying system is out of order, a fire watch is patrolling affected areas of the building, and in case of fire call 911
Repeat Violation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 01/07/2025

Inspection Number: 1183236

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Osceola

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 01/09/2025

Inspection Number: 1183236

Insp Type: Complaint Full

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power. For reporting purposes only.Operator has signage throughout lobby saying system is out of order, a fire watch is patrolling affected areas of the building, and in case of fire call 911 ****Repeat Violation**** - From follow-up inspection 2025-01-09: ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 01/10/2025

Inspection Number: 1183236

Insp Type: Complaint Full

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power. For reporting purposes only.Operator has signage throughout lobby saying system is out of order, a fire watch is patrolling affected areas of the building, and in case of fire call 911 ****Repeat Violation**** - From follow-up inspection 2025-01-09: ****Time Extended**** - From follow-up inspection 2025-01-10: ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Osceola

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 01/09/2025

Inspection Number: 1183236

Insp Type: Complaint Full

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-01-09: ****Time Extended****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 01/10/2025

Inspection Number: 1183236

Insp Type: Complaint Full

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-01-09: ****Time Extended**** - From follow-up inspection 2025-01-10: ****Time Extended****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Palm Beach

License Number: 6014086

AMRIT OCEAN

License Type: Lodging

3100 N OCEAN DR , RIVIERA BEACH 33404

Insp Date: 01/03/2025

Inspection Number: 1183216

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6011442

ROYAL ST GEORGE

License Type: Lodging

1651 BRANDYWINE RD , WEST PALM BEACH 33409

Insp Date: 01/03/2025

Inspection Number: 1623111

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. At building 400; audible alarm/trouble light illuminated on control panel. **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Pinellas

License Number: 6201477

GATEWAY MOTEL

License Type: Lodging

4990 34 ST N , ST. PETERSBURG 33714

Insp Date: 01/03/2025

Inspection Number: 1234163

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near unit 24

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6800625

NOKOMIS GULF COAST INN

License Type: Lodging

119 N TAMIAMI TRAIL , NOKOMIS 34275

Insp Date: 01/08/2025

Inspection Number: 1089688

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher between rooms 102 and 103. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Seminole

License Number: 6903650

EXTENDED STAY AMERICA #9634

License Type: Lodging

302 NORTHLAKE BLVD , ALTAMONTE SPRINGS 32701

Insp Date: 01/07/2025

Inspection Number: 1183183

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406406

1500 SAN MARCO DRIVE (FL) OWNER LLC

License Type: Lodging

1500 SAN MARCO DR , ORMOND BEACH 32174

Insp Date: 01/03/2025

Inspection Number: 1623120

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-fire panel in building 1511 has trouble light.-no power at fire panel in building 1515.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 01/11/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7403613

SPRUCEWOOD APARTMENT

License Type: Lodging

1450 SOUTH PALMETTO AVE , DAYTONA BEACH 32114

Insp Date: 01/10/2025

Inspection Number: 1623186

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.-per operator it has been disconnected and that it was connected prior to his ownership-FACP located second floor in small storage room

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403718

HOLIDAY INN EXPRESS AND SUITES

License Type: Lodging

3301 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 01/09/2025

Inspection Number: 1239653

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403718

HOLIDAY INN EXPRESS AND SUITES

License Type: Lodging

3301 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 01/09/2025

Inspection Number: 1239653

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-manager stated contacted fire insurance company over issue

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Volusia

License Number: 7405603

SLEEP INN ORMOND BEACH

License Type: Lodging

170 WILLIAMSON BOULEVARD , ORMOND BEACH 32174

Insp Date: 01/03/2025

Inspection Number: 1235091

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406406

1500 SAN MARCO DRIVE (FL) OWNER LLC

License Type: Lodging

1500 SAN MARCO DR , ORMOND BEACH 32174

Insp Date: 01/07/2025

Inspection Number: 1623120

Insp Type: Complaint Full

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-fire panel in building 1511 has trouble light.-no power at fire panel in building 1515. - From follow-up inspection 2025-01-07: **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/11/2025

Volusia

License Number: 7401228

COVE MOTEL

License Type: Lodging

1306 N ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 01/07/2025

Inspection Number: 1235407

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Recent report showed 12/2023 as most recent inspection attempt to gain certificate of boiler inspection. Per division of boilers/state fire marshall database. - From follow-up inspection 2025-01-07: **Time Extended**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400778

SURFSIDE EXECUTIVE APTS

License Type: Lodging

421 AUBURN DR , DAYTONA BCH 83254

Insp Date: 01/07/2025

Inspection Number: 1582117

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.-glass panel box in front of unit 4 missing breaking device - From follow-up inspection 2025-01-07: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.