



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Brevard

License Number: 1505378

COCOA BEACH HOTEL

License Type: Lodging

3655 N ATLANTIC AVE , COCOA BCH 32931

Insp Date: 01/17/2025

Inspection Number: 1176380

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

05-02-5	- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Detector chimes and flashes once plugged in. No idle function **Warning** - From follow-up inspection 2025 -01-17: No change **Admin Complaint**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 1620940

DOLCE BY WYNDHAM HOLLYWOOD

License Type: Lodging

5530 S STATE ROAD 7 , HOLLYWOOD 33314

Insp Date: 01/14/2025

Inspection Number: 1182358

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In electric room	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 1621340

RESERVE AT CORAL SPRINGS

License Type: Lodging

3591 NW 88 DRIVE , CORAL SPRINGS 33065

Insp Date: 01/14/2025

Inspection Number: 1591557

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at unit 302, 303, 103 building 3571	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Broward

License Number: 1622045

ARTHUR STREET APARTMENTS OF HOLLYWOOD FLORIDA, LLC

License Type: Lodging

6151 EATON ST , HOLLYWOOD 33024

Insp Date: 01/15/2025

Inspection Number: 1623034

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Extinguisher in courtyard opposite of 525 building by unit 2 reading overcharged.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1615547

NORTHLAND CYPRESS SHORES LLC

License Type: Lodging

1901 LYONS RD , COCONUT CREEK 33063

Insp Date: 01/16/2025

Inspection Number: 1589446

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed unit 305 building 1961

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Broward

License Number: 1604550

SOL 3741 LLC

License Type: Lodging

3741 SW 1 ST , FORT LAUDERDALE 33312

Insp Date: 01/16/2025

Inspection Number: 1587766

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 12 **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1600444

MARVIN GARDEN APT

License Type: Lodging

3815 SW 16 ST , FORT LAUDERDALE 33312

Insp Date: 01/15/2025

Inspection Number: 1584552

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Broward

License Number: 1603352

SKY MOTEL

License Type: Lodging

1531 SW 26 ST , FORT LAUDERDALE 52214

Insp Date: 01/15/2025

Inspection Number: 1239884

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.Observed no smoke alarm in room 31.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620911

LAUDERDALE BOUTIQUE HOTEL

License Type: Lodging

505 SE 16 ST , FORT LAUDERDALE 33316

Insp Date: 01/16/2025

Inspection Number: 1235664

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room 11. For reporting purposes only.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Broward

License Number: 1620520

RENAISSANCE FORT LAUDERDALE-PLANTATION HOTEL

License Type: Lodging

1230 S PINE ISLAND RD , PLANTATION 33324

Insp Date: 01/17/2025

Inspection Number: 1182394

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate expired 9/15/2024. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618593

EXTENDED STAY AMERICA SUITES 9808

License Type: Lodging

1401 SW 15 ST , POMPAÑO BEACH 33060

Insp Date: 01/15/2025

Inspection Number: 1182258

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Broward

License Number: 1604995

HARRY'S APTS

License Type: Lodging

2318 NW 4 CT , POMPAN0 BEACH 92617

Insp Date: 01/15/2025

Inspection Number: 1601671

Insp Type: Routine - Lodging

Disposition: Administrative complaint
recommended

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside Apt 4

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2102708

GREAT WOLF LODGE SOUTHWEST FLORIDA

License Type: Lodging

3900 CITY GATE BLVD N , NAPLES 34117

Insp Date: 01/17/2025

Inspection Number: 1178914

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. Observed boiler certificates available but not posted. Observed certificates posted before end of inspection. **Corrected On-Site**

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Dade

License Number: 2329342

COURTNEY REALTY LLC

License Type: Lodging

576 NE 63 ST , MIAMI 33138

Insp Date: 01/10/2025

Inspection Number: 1599298

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher is in need of recharge at entrance of building first floor.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2316403

CUTLER MANOR APARTMENTS

License Type: Lodging

10875 SW 216 ST , MIAMI 03103

Insp Date: 01/10/2025

Inspection Number: 1623187

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed throughout the property. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329342

COURTNEY REALTY LLC

License Type: Lodging

576 NE 63 ST , MIAMI 33138

Insp Date: 01/10/2025

Inspection Number: 1599298

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. Observed no power at FACP located at back exit door entrance of the building.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Dade

License Number: 2304635

MALIBU HOTEL

License Type: Lodging

2936 SW 37 CT , MIAMI 47342

Insp Date: 01/13/2025

Inspection Number: 1178513

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329275

NOTEBOOK MIAMI BEACH

License Type: Lodging

216 43 STREET , MIAMI BEACH 33140

Insp Date: 01/16/2025

Inspection Number: 1178683

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. Observed fire alarm panel with no power. Fire alarm is located at the lobby entrance.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304635

MALIBU HOTEL

License Type: Lodging

2936 SW 37 CT , MIAMI 47342

Insp Date: 01/13/2025

Inspection Number: 1178513

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Dade

License Number: 2311837

NORTH MIAMI BEACH GARDEN INN & SUITE

License Type: Lodging

148 NW 167 ST , MIAMI 33169

Insp Date: 01/16/2025

Inspection Number: 1240958

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. In the office.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329336

KL FLORIDA, LLC

License Type: Lodging

418 MERIDIAN AVE , MIAMI BEACH 33139

Insp Date: 01/10/2025

Inspection Number: 1183228

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Dade

License Number: 2329481

KOMPOSE BOUTIQUE HOTEL MIAMI AIRPORT

License Type: Lodging

3401 NW 25 ST , MIAMI 33142

Insp Date: 01/16/2025

Inspection Number: 1183251

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329211

MIAMI MANSION MOTEL

License Type: Lodging

611 E OKEECHOBEE RD , HIALEAH 33010

Insp Date: 01/17/2025

Inspection Number: 1178303

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Dade

License Number: 2314753

HILTON MIAMI DOWNTOWN

License Type: Lodging

1601 BISCAYNE BLVD , MIAMI 33132

Insp Date: 01/14/2025

Inspection Number: 1178144

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328235

HOMEWOOD SUITES MIAMI AIRPORT BLUE LAGOON

License Type: Lodging

5500 WATERFORD DISTRICT DR , MIAMI 33126

Insp Date: 01/17/2025

Inspection Number: 1178945

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed in orange,. Technician coming to reset breaker. **Corrective Action Taken**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Dade

License Number: 2329100

SETAI HOTEL

License Type: Lodging

2001 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 01/14/2025

Inspection Number: 1178424

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325791

COURTYARD MIAMI AIRPORT

License Type: Lodging

1201 NW 42 AVE , MIAMI 33126

Insp Date: 01/17/2025

Inspection Number: 1178406

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Dade

License Number: 2317199

INTERCONTINENTAL HOTEL MIAMI

License Type: Lodging

100 CHOPIN PLAZA , MIAMI 33131

Insp Date: 01/10/2025

Inspection Number: 1178880

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329442

WYNDHAM GARDEN MIAMI INTERNATIONAL AIRPORT

License Type: Lodging

4909 NW 36 ST , MIAMI SPRINGS 33166

Insp Date: 01/10/2025

Inspection Number: 1178156

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Dade

License Number: 2319921

COURTYARD BY MARRIOTT HOTEL

License Type: Lodging

3929 NW 79 AVE , MIAMI 33166

Insp Date: 01/17/2025

Inspection Number: 1178358

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed Jurisdiction #058983, 058984, expired 9/8/2024.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2314753

HILTON MIAMI DOWNTOWN

License Type: Lodging

1601 BISCAYNE BLVD , MIAMI 33132

Insp Date: 01/14/2025

Inspection Number: 1178144

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler report Exp. 06-23-2024. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 01/18/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329358

FOUR POINTS BY SHERATON MIAMI AIRPORT

License Type: Lodging

3570 NW 74 AVE , MIAMI 33122

Insp Date: 01/13/2025

Inspection Number: 1178762

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-01-13: Trouble/alarm light illuminated on the fire alarm control panel. ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612297

EXTENDED STAY AMERICA

License Type: Lodging

8300 WESTERN WAY , JACKSONVILLE 32256

Insp Date: 01/17/2025

Inspection Number: 1176121

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher in locked box by room 214, 237, 242, 142, 114. ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2609384

COMFORT SUITES

License Type: Lodging

8277 WESTERN WAY , JACKSONVILLE 32256

Insp Date: 01/17/2025

Inspection Number: 1176094

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble light illuminated on fire panel. Person in charge states due to unable to reset. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 01/18/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2613288

WOODSPRING SUITES JACKSONVILLE

License Type: Lodging

7125 BONNEVAL RD , JACKSONVILLE 32216

Insp Date: 01/13/2025

Inspection Number: 1177093

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power. For reporting purposes only.No power to panel due to water damage per person in charge. Person in charge states due to be serviced tomorrow. Waiting for part. - From follow-up inspection 2024-11-12: No charge, fire panel still has no power. **Time Extended** - From follow-up inspection 2024-12-16: No change. **Time Extended** - From follow-up inspection 2025-01-13: Fire panel still has no power. Person in charge states tomorrow a new panel is scheduled to be installed. **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612092

MOTEL 6/STUDIO 6 JACKSONVILLE SOUTH

License Type: Lodging

8285 PHILIPS HWY , JACKSONVILLE 32256

Insp Date: 01/15/2025

Inspection Number: 1240959

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.Fire extinguisher by room 132, 360 in locked box.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Duval

License Number: 2608575

RAMADA BAYMEADOWS HOTEL

License Type: Lodging

9150 BAYMEADOWS RD , JACKSONVILLE 32256

Insp Date: 01/16/2025

Inspection Number: 1178106

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher by unit 426,301, 226 in locked box.
Repeat Violation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613288

WOODSPRING SUITES JACKSONVILLE

License Type: Lodging

7125 BONNEVAL RD , JACKSONVILLE 32216

Insp Date: 01/13/2025

Inspection Number: 1179068

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. Fire panel has no power to unit, per person in charge a new panel is due to be installed tomorrow.
Repeat Violation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Flagler

License Number: 2800590

License Type: Lodging

FAIRFIELD INN & SUITES

400 OLD KINGS RD , PALM COAST 32137

Insp Date: 01/13/2025

Inspection Number: 1178612

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No
Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Both certificates have expired. Date expired is 8.4.24. Boilers #'s 132881 and 132882.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Hillsborough

License Number: 3911502

EXTENDED STAY AMERICA #9643

License Type: Lodging

330 GRAND REGENCY BLVD , BRANDON 33510

Insp Date: 01/15/2025

Inspection Number: 1240967

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3911434

FAIRFIELD INN & SUITES TAMPA BRANDON

License Type: Lodging

10150 PALM RIVER RD , TAMPA 33619

Insp Date: 01/16/2025

Inspection Number: 1178732

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Lake

License Number: 4502678

HOME2 SUITES BY HILTON

License Type: Lodging

1450 CHAMPIONS WAY , CLERMONT 34711

Insp Date: 01/10/2025

Inspection Number: 1178918

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301449

COURTYARD BY MARRIOTT - STUART

License Type: Lodging

7615 SW LOST RIVER RD , STUART 34997

Insp Date: 01/15/2025

Inspection Number: 1181912

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Monroe

License Number: 5402819

HYATT WINDWARD POINTE

License Type: Lodging

3675 S ROOSEVELT BLVD , KEY WEST 33040

Insp Date: 01/15/2025

Inspection Number: 1176588

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500358

PINE TREE APTS

License Type: Lodging

37083 PINE TREE DR , HILLIARD 32046

Insp Date: 01/17/2025

Inspection Number: 1599257

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Exterior extinguisher for unit 37209-803.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Orange

License Number: 5811144

DOUBLETREE BY HILTON ORLANDO AT SEAWORLD

License Type: Lodging

10100 INTERNATIONAL DR , ORLANDO 32821

Insp Date: 01/16/2025

Inspection Number: 1183285

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 139650 & 093513 expire 1/9/25. 134449, 134491, 093512 expire 12/3/22
Repeat Violation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809868

EMBASSY SUITES ORLANDO DOWNTOWN

License Type: Lodging

191 E PINE ST , ORLANDO 32801

Insp Date: 01/13/2025

Inspection Number: 1178430

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Osceola

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 01/10/2025

Inspection Number: 1183236

Insp Type: Complaint Full

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power. For reporting purposes only. Operator has signage throughout lobby saying system is out of order, a fire watch is patrolling affected areas of the building, and in case of fire call 911 ****Repeat Violation**** - From follow-up inspection 2025-01-09: ****Time Extended**** - From follow-up inspection 2025-01-10: ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 01/10/2025

Inspection Number: 1183236

Insp Type: Complaint Full

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-01-09: ****Time Extended**** - From follow-up inspection 2025-01-10: ****Time Extended****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Osceola**

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 01/13/2025

Inspection Number: 1183236

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power. For reporting purposes only. Operator has signage throughout lobby saying system is out of order, a fire watch is patrolling affected areas of the building, and in case of fire call 911 **Repeat Violation** - From follow-up inspection 2025-01-09: **Time Extended** - From follow-up inspection 2025-01-10: **Time Extended** - From follow-up inspection 2025-01-13: **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 01/13/2025

Inspection Number: 1183236

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2025-01-09: **Time Extended** - From follow-up inspection 2025-01-10: **Time Extended** - From follow-up inspection 2025-01-13: **Time Extended**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Palm Beach

License Number: 6012746

SOUTHERN PALM BED & BREAKFAST

License Type: Lodging

15130 SOUTHERN PALM WAY , LOXAHATCHEE 33470

Insp Date: 01/16/2025

Inspection Number: 1096286

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Operator fixed.
Corrected On-Site

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6012369

TOWNEPLACE SUITES

License Type: Lodging

5110 NW 8 AVE , BOCA RATON 33487

Insp Date: 01/17/2025

Inspection Number: 1182307

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Palm Beach

License Number: 6013464

YACHT CLUB AT THE BOCA RATON

License Type: Lodging

501 E CAMINO REAL , BOCA RATON 33432

Insp Date: 01/15/2025

Inspection Number: 1182410

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 7/12/24 **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014087

BELGROVE

License Type: Lodging

2020 BANYAN RESORT WAY , WEST PALM BEACH 33401

Insp Date: 01/16/2025

Inspection Number: 1179322

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Palm Beach

License Number: 6007616

**LA QUINTA INN BY WYNDHAM WEST PALM BEACH -
FLORIDA TURNPIKE**

License Type: Lodging

5981 OKEECHOBEE BLVD , WEST PALM BEACH 33417

Insp Date: 01/16/2025

Inspection Number: 1240151

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Operator provided no boiler certificate

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6007478

SUPER 8

License Type: Lodging

1255 HYPOLUXO RD , LANTANA 33462

Insp Date: 01/14/2025

Inspection Number: 1239861

Insp Type: Routine - Lodging

Disposition: Administrative complaint
recommended

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Next to room 113 and 407
Repeat Violation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 01/18/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6006320

OPAL GRAND OCEAN FRONT RESORT & SPA

License Type: Lodging

10 N OCEAN BLVD , DELRAY BEACH 36913

Insp Date: 01/15/2025

Inspection Number: 1177029

Insp Type: Routine - Lodging

Disposition: Administrative complaint
recommended

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201655

ALTA MAR AT BRODWATER

License Type: Lodging

3901 38 AVE S , ST. PETERSBURG 33711

Insp Date: 01/17/2025

Inspection Number: 1623206

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-06-4

Smoke detectors in unit 28b reported sounding

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 01/18/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7400503

BAYMONT BY WYNDHAM

License Type: Lodging

2725 W INTERNATIONAL SPWY BLVD , DAYTONA BEACH 32114

Insp Date: 01/17/2025

Inspection Number: 1240971

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Manager reset
Corrected On-Site

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403613

SPRUCEWOOD APARTMENT

License Type: Lodging

1450 SOUTH PALMETTO AVE , DAYTONA BEACH 32114

Insp Date: 01/10/2025

Inspection Number: 1623186

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.-per operator it has been disconnected and that it was connected prior to his ownership-FACP located second floor in small storage room

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400039

BLEU BEACH CLUB

License Type: Lodging

1503 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 01/15/2025

Inspection Number: 1240964

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only.- fire escape at south west stairway barricaded

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Volusia

License Number: 7400039

BLEU BEACH CLUB

License Type: Lodging

1503 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 01/15/2025

Inspection Number: 1240964

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet/box damaged to indicate a malfunction. For reporting purposes only.-wires visible between north west side of structure and box

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400039

BLEU BEACH CLUB

License Type: Lodging

1503 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 01/15/2025

Inspection Number: 1240964

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

11-03-4

Gas water heater in disrepair/not properly installed. For reporting purposes only.-across from unit 24

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Volusia

License Number: 7403413

ARYA INTERNATIONAL REALTY LLC

License Type: Lodging

709 ORA ST , DAYTONA BEACH 32118

Insp Date: 01/16/2025

Inspection Number: 1585579

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

02-08-4

Motorcycle stored under a stairwell. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406521

DAYTONA GRANDE HOTEL

License Type: Lodging

422 N. ATLANTIC AVE. , DAYTONA BEACH 32118

Insp Date: 01/14/2025

Inspection Number: 1178222

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only.-racks of clothes place in front of door marked ****Corrected On-Site****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Volusia

License Number: 7406660

KMTM ENTERPRISES, LLC

License Type: Lodging

4999 S. RIDGEWOOD AVE , PORT ORANGE 32127

Insp Date: 01/16/2025

Inspection Number: 1595499

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

06-03-4

Observation

Fire escape exit is obstructed. For reporting purposes only.-stairway egress partially blocked/obstructed by items on ground between units and stairway access

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406521

DAYTONA GRANDE HOTEL

License Type: Lodging

422 N. ATLANTIC AVE. , DAYTONA BEACH 32118

Insp Date: 01/14/2025

Inspection Number: 1178222

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

06-06-4

Observation

Door marked as an exit locked with a lock that requires a key. For reporting purposes only.-service door marked with fire exit from hallway on 23rd floorPath to door marked as an exit is blocked. For reporting purposes only.-racks of clothes place in front of door marked

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Volusia

License Number: 7406521

DAYTONA GRANDE HOTEL

License Type: Lodging

422 N. ATLANTIC AVE. , DAYTONA BEACH 32118

Insp Date: 01/14/2025

Inspection Number: 1178222

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406406

1500 SAN MARCO DRIVE (FL) OWNER LLC

License Type: Lodging

1500 SAN MARCO DR , ORMOND BEACH 32174

Insp Date: 01/15/2025

Inspection Number: 1623120

Insp Type: Complaint Full

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-fire panel in building 1511 has trouble light.-no power at fire panel in building 1515. - From follow-up inspection 2025-01-07: **Time Extended** - From follow-up inspection 2025-01-15:

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 01/18/2025

Volusia

License Number: 7405449

ROYAL INN OF RIDGEWOOD

License Type: Lodging

810 S RIDGEWOOD AVE , DAYTONA BEACH 32114

Insp Date: 01/13/2025

Inspection Number: 1235575

Insp Type: Routine - Lodging

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

02-04-4

- From initial inspection : Scooter stored inside the large water heater room/storage room.Gas can can in storage room/water heater room.For reporting purposes only. - From follow-up inspection 2025-01-13: Scooter in water heater room

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.