



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Bay

License Number: 1305150

HOWARD JOHNSON

License Type: Lodging

301 E 23 ST , PANAMA CITY 32405

Insp Date: 01/24/2025

Inspection Number: 1236502

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside room 209.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1616492

SUNSET MOTEL

License Type: Lodging

140 N FEDERAL HWY , DANIA 42804

Insp Date: 01/30/2025

Inspection Number: 1239587

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Next to room #108

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Broward

License Number: 1618593

EXTENDED STAY AMERICA SUITES 9808

License Type: Lodging

1401 SW 15 ST , POMPAN0 BEACH 33060

Insp Date: 01/27/2025

Inspection Number: 1183328

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1604426

9 SOUTH LLC

License Type: Lodging

325 NW 25TH STREET , FORT LAUDERDALE 33311

Insp Date: 01/27/2025

Inspection Number: 1589969

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. Located on west side of building. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Broward

License Number: 1604982

COLONY APARTMENTS

License Type: Lodging

709 SE 15 ST , FORT LAUDERDALE 62667

Insp Date: 01/31/2025

Inspection Number: 1586813

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. Located at bldg 711 between units 2 and 3. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1605178

732 TRAC APARTMENTS

License Type: Lodging

732 SE 15TH ST , FORT LAUDERDALE 33316

Insp Date: 01/27/2025

Inspection Number: 1593125

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed between units 2 and 3.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Broward

License Number: 1620918

FORT LAUDERDALE TRU/HOMES2

License Type: Lodging

315 NW 1 AVE , FORT LAUDERDALE 33301

Insp Date: 01/31/2025

Inspection Number: 1181907

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2102690

SPRINGHILL SUITES NAPLES

License Type: Lodging

3798 WHITE LAKE BLVD , NAPLES 34117

Insp Date: 01/29/2025

Inspection Number: 1176656

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Per operator, a work order for repair has been created. **Corrective Action Taken**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/01/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2305082

GABLES INN

License Type: Lodging

730 S DIXIE HWY , CORAL GABLES 62602

Insp Date: 01/28/2025

Inspection Number: 1241019

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.Observed next to room 103. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330471

IVY COVE HOMES 2018 LLC

License Type: Lodging

6805 SW 88 ST , PINECREST 33156

Insp Date: 01/24/2025

Inspection Number: 1599031

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.Observed no hammer to break glass next to laundry room.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329365

WINGATE BY WYNDHAM MIAMI AIRPORT

License Type: Lodging

3755 NW 78 AVE , DORAL 33166

Insp Date: 01/29/2025

Inspection Number: 1183337

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on 5th floor near room 505.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Dade

License Number: 2320542

MIAMI PRINCESS HOTEL

License Type: Lodging

4251 NW 11 ST , MIAMI 62630

Insp Date: 01/24/2025

Inspection Number: 1239706

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. By 116.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327840

BAYMONT INN & SUITES

License Type: Lodging

3805 NW 107 AVE , MIAMI 33178

Insp Date: 01/29/2025

Inspection Number: 1178678

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Dade

License Number: 2329221

SOHO HOUSE

License Type: Lodging

4385 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 01/28/2025

Inspection Number: 1178596

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed main panel with trouble light.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329270

GRAND BEACH HOTEL SURFSIDE

License Type: Lodging

9449 COLLINS AVE , SURFSIDE 33154

Insp Date: 01/27/2025

Inspection Number: 1179234

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Dade

License Number: 2329397

CANDLEWOOD SUITES MIAMI EXEC AIRPORT - KENDALL

License Type: Lodging

13600 SW 139 CT , MIAMI 33186

Insp Date: 01/30/2025

Inspection Number: 1178837

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Observed in lobby area.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328084

INTER CONTINENTAL DORAL MIAMI

License Type: Lodging

2505 NW 87 AVE , MIAMI 21610

Insp Date: 01/30/2025

Inspection Number: 1178221

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 059615 11/17/24. 021243 01/09/25. As per chief engineer units has been inspected and waiting for the state to issue current certificates.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Dade

License Number: 2329221

SOHO HOUSE

License Type: Lodging

4385 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 01/28/2025

Inspection Number: 1178596

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed FL 099975, 121860, 099980, 099979, exp 10/21/24 004874, 004875 exp 10/21/23

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329242

COURTYARD BY MARRIOTT SOUTH HOMESTEAD

License Type: Lodging

2905 NE 9 ST , HOMESTEAD 33033

Insp Date: 01/28/2025

Inspection Number: 1178825

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expired certificate 12/13/2024.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Dade

License Number: 2329338

HILTON GARDEN INN MIAMI DOLPHIN MALL

License Type: Lodging

1695 NW 111 AVE , SWEETWATER 33172

Insp Date: 01/31/2025

Inspection Number: 1178321

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 4 boiler certificates expire 08/22/2024. As per chief engineering inspection for all four units performed on 09/06/2024 by Hartford steam boiler and certificates has been delayed.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329339

HOMEWOOD SUITES BY HILTON MIAMI DOLPHIN MALL

License Type: Lodging

1695 NW 111 AVE , SWEETWATER 33172

Insp Date: 01/24/2025

Inspection Number: 1178234

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 4 boiler certificates expire 08/22/2024. As per chief engineering inspection for all four units performed on 09/06/2024 by Hartford steam boiler and certificates has been delayed.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Dade

License Number: 2329470

**HOTEL INDIGO MIAMI BRICKELL / ATWELL SUITES MIAMI
BRICKELL**

License Type: Lodging

145 SW 11 ST , MIAMI 33130

Insp Date: 01/27/2025

Inspection Number: 1178496

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed 700 BTU boiler and no certificate provided. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305082

GABLES INN

License Type: Lodging

730 S DIXIE HWY , CORAL GABLES 62602

Insp Date: 01/29/2025

Inspection Number: 1241019

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.Observed next to room 103. **Repeat Violation** - From follow-up inspection 2025-01-29: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Dade

License Number: 2322395

6055 CORP APTS

License Type: Lodging

6345 W 22 CT , HIALEAH 63995

Insp Date: 01/30/2025

Inspection Number: 1578518

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed located unit 203.
- From follow-up inspection 2025-01-30: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320327

FAIRWAY INN

License Type: Lodging

100 U S 1 , FLORIDA CITY 33034

Insp Date: 01/30/2025

Inspection Number: 1235158

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2025-01-30: Observed Trouble/alarm light illuminated on the fire alarm control panel. **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322395

6055 CORP APTS

License Type: Lodging

6345 W 22 CT , HIALEAH 63995

Insp Date: 01/30/2025

Inspection Number: 1578518

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2025-01-30: **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Dade

License Number: 2310047

BISCAYNE HOTEL

License Type: Lodging

6730 BISCAYNE BLVD BISCAYNE BLVD, MIAMI 33138

Insp Date: 01/27/2025

Inspection Number: 1236579

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

01-01-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.Observed located at entrance of room 102. - From follow-up inspection 2025-01-27: Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.Still Observed located at entrance of room 102.
Time Extended

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2500001

PUTNAM LODGE

License Type: Lodging

15487 NW HWY 19 , CROSS CITY 32628

Insp Date: 01/27/2025

Inspection Number: 1179022

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.Gauge on fire extinguisher near exterior bathrooms in red.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/01/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2613256

FINLEY

License Type: Lodging

9541 103 ST , JACKSONVILLE 32210

Insp Date: 01/28/2025

Inspection Number: 1623153

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.Observed missing fire extinguisher between unit 307 and 308. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613371

BROXTON BAY APARTMENTS

License Type: Lodging

12900 BROXTON BAY DR , JACKSONVILLE 32218

Insp Date: 01/30/2025

Inspection Number: 1623289

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.At building 1400, trouble light and audible alarm on fire alarm control panel.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2800155

OCEAN SHORE VILLA

License Type: Lodging

6287 N OCEAN SHORE BLVD , PALM COAST 72412

Insp Date: 01/27/2025

Inspection Number: 1236841

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.Whelan smoke detector sounds alarm but does not flash. **Warning**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Glades

License Number: 3200011

ANGLER'S WATERFRONT MOTEL

License Type: Lodging

1010 6 ST RT-4 , OKEECHOBEE 49206

Insp Date: 01/30/2025

Inspection Number: 1235735

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge at backside unit 10. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906561

SHERATON TAMPA EAST

License Type: Lodging

10221 PRINCESS PALM AVE , TAMPA 33610

Insp Date: 01/27/2025

Inspection Number: 1178824

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Hillsborough

License Number: 3913664

HAMPTON INN/HOME 2 TAMPA CHANNELSIDE

License Type: Lodging

1155 E KENNEDY BLVD , TAMPA 33602

Insp Date: 01/28/2025

Inspection Number: 1182511

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Operator is aware, states it is because of the CO2 detectors that will be getting replaced soon.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913633

FAIRFIELD INN AND SUITES LAKELAND PLANT CITY

License Type: Lodging

4307 STERLING COMMERCE DR , PLANT CITY 33566

Insp Date: 01/24/2025

Inspection Number: 1179247

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Photo sensor light on. Manager stated they have the parts and are in process of repairing

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Leon

License Number: 4700410

MOTEL 6 TALLAHASSEE

License Type: Lodging

1027 APALACHEE PKWY , TALLAHASSEE 32301

Insp Date: 01/28/2025

Inspection Number: 1241009

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5202244

FAIRFIELD INN AND SUITES OCALA

License Type: Lodging

4101 SW 38 CT , OCALA 34474

Insp Date: 01/30/2025

Inspection Number: 1183305

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Boiler 058207 and 058208

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Nassau

License Number: 5500961

SEASIDE AMELIA INN

License Type: Lodging

2900 ATLANTIC AVE , AMELIA ISLAND 32034

Insp Date: 01/27/2025

Inspection Number: 1175810

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire panel shows trouble lights.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500837

OMNI AMELIA ISLAND RESORT

License Type: Lodging

41 BEACH LAGOON RD , FERNANDINA BEACH 32034

Insp Date: 01/24/2025

Inspection Number: 1176316

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Two boiler certificates on property are expired - jurisdiction 089935 and 131446 expired 12/02/2024. Manager states inspection has been performed and establishment is awaiting certificates.
Corrective Action Taken

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/01/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Nassau

License Number: 5500837

OMNI AMELIA ISLAND RESORT

License Type: Lodging

41 BEACH LAGOON RD , FERNANDINA BEACH 32034

Insp Date: 01/24/2025

Inspection Number: 1176316

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Boiler at off site laundry facility does not have boiler certification (specifications for boiler max temperature of 425F, capacity 412 gallons, BTU input 2.4 million/hr). Person in Charge states the unit is regulated as a hot water heater by the State Fire Marshall, but no paperwork could be provided.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811114

EXTENDED STAY AMERICA SELECT SUITES #8084

License Type: Lodging

216 S GOLDENROD RD , ORLANDO 32807

Insp Date: 01/24/2025

Inspection Number: 1181934

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

07-03-4

Scorch marks around an electrical outlet. For reporting purposes only. Room 431 scorch marks around outlet by bed

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Orange

License Number: 5811129

WYNDHAM GRAND ORLANDO RESORT BONNET CREEK

License Type: Lodging

14651 CHELONIA PKWY , ORLANDO 32821

Insp Date: 01/30/2025

Inspection Number: 1178808

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher have expired 9/2022 on the 12th floor. For reporting purposes only. The fire extinguisher is expired 9/2022 spoke with Engineering Manager, must notify company immediately.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811220

PESTANA ORLANDO SUITES LAKE BUENA VISTA

License Type: Lodging

11942 RAVALLLO RESORT DR , ORLANDO 32836

Insp Date: 01/31/2025

Inspection Number: 1178290

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed no copy of boiler certificates or inspection report. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Orange

License Number: 5810234

PALMS CLUB

License Type: Lodging

5584 METROWEST BLVD , ORLANDO 32811

Insp Date: 01/30/2025

Inspection Number: 1600387

Insp Type: Routine - Lodging

Disposition: Administrative complaint
recommended

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. In apartment 204 building 14

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Lodging

5678 W IRLO BRONSON MEMORIAL HWY , KISSIMMEE 34746

Insp Date: 01/27/2025

Inspection Number: 1183327

Insp Type: Complaint Full

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Palm Beach

License Number: 6014088

PALM HOUSE

License Type: Lodging

160 ROYAL PALM WAY , PALM BEACH 33480

Insp Date: 01/27/2025

Inspection Number: 1182717

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6009050

FOUR SEASONS RESORT PALM BEACH

License Type: Lodging

2800 S OCEAN BLVD , PALM BEACH 05540

Insp Date: 01/24/2025

Inspection Number: 1178264

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Operator stated that new. Boiler inspection was done on 1/7/25 but has yet to receive the certificate.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Pinellas

License Number: 6215809

EDGE HOTEL

License Type: Lodging

505 S GULFVIEW BLVD , CLEARWATER BEACH 33767

Insp Date: 01/24/2025

Inspection Number: 1178602

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215840

CY CLEARWATER BEACH

License Type: Lodging

455 E SHORE DR , CLEARWATER BEACH 33767

Insp Date: 01/29/2025

Inspection Number: 1178930

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Pinellas

License Number: 6203729

TRADEWINDS ISLAND GRAND JACARANDA

License Type: Lodging

5500 GULF BLVD , ST. PETE BEACH 33706

Insp Date: 01/28/2025

Inspection Number: 1236456

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 131371 7/20/2024 expired certificate observed.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203219

SIRATA BEACH RESORT

License Type: Lodging

5300 GULF BLVD , ST.PETE BEACH 33706

Insp Date: 01/28/2025

Inspection Number: 1235373

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 138901 6-21-2024, 138902 6-21-2024

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Pinellas

License Number: 6214461

SONESTA SIMPLY SUITES CLEARWATER

License Type: Lodging

13231 49 ST N , CLEARWATER 33762

Insp Date: 01/29/2025

Inspection Number: 1235066

Insp Type: Routine - Lodging

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Gentex installed hearing impaired smoke detector inside room 111, not functioning properly when tested. - From follow-up inspection 2025-01-29: Super Arbor Ordered 12-28-25. Per Supervisor Christine C. Ok to time extend. Waiting for Oder. **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903989

DEVELOPER INN ORLANDO NORTH A BAYMONT BY WYNDDHAM

License Type: Lodging

235 WYMORE RD , ALTAMONTE SPRINGS 32714

Insp Date: 01/29/2025

Inspection Number: 1236957

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7406496

COUNTRY INN AND SUITES

License Type: Lodging

5802 JOURNEYS END WAY , PORT ORANGE 32127

Insp Date: 01/29/2025

Inspection Number: 1178770

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.-extinguisher on wall next to 422 indicates unit is overcharged

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406496

COUNTRY INN AND SUITES

License Type: Lodging

5802 JOURNEYS END WAY , PORT ORANGE 32127

Insp Date: 01/29/2025

Inspection Number: 1178770

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.-box on wall next to 327 missing extenguisher

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406509

BEACH HOUSE INN

License Type: Lodging

1601 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 01/30/2025

Inspection Number: 1236943

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation CodeObservationViolation Citation

02-07-4

Flammable material stored near a source of ignition. For reporting purposes only.-lint allowed to build up under vent stack inside laundry room water heater

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Volusia

License Number: 7406513

HARD ROCK HOTEL

License Type: Lodging

918 N ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 01/29/2025

Inspection Number: 1178786

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401632

HOLIDAY INN RESORT DAYTONA BEACH OCEAN FRONT

License Type: Lodging

1615 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 01/28/2025

Inspection Number: 1236635

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-level 2 FACP

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405788

EXTENDED STAY AMERICA #1564

License Type: Lodging

255 BILL FRANCE BLVD , DAYTONA BEACH 32114

Insp Date: 01/28/2025

Inspection Number: 1183335

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-supervisory,system trouble ,signals silenced

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Volusia

License Number: 7406516

COMFORT SUITES SPEEDWAY

License Type: Lodging

2900 W. INTERNATIONAL SPEEDWAY BLVD , DAYTONA BEACH 32124

Insp Date: 01/31/2025

Inspection Number: 1178465

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.-fire extinguisher across from room 415

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401092

QUALITY INN

License Type: Lodging

700 N ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 01/24/2025

Inspection Number: 1235831

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.Level 2

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/01/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7400503

BAYMONT BY WYNDHAM

License Type: Lodging

2725 W INTERNATIONAL SPWY BLVD , DAYTONA BEACH 32114

Insp Date: 01/31/2025

Inspection Number: 1240971

Insp Type: Complaint Full

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Manager reset **Corrected On-Site** - From follow-up inspection 2025-01-31:	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 7400746

CHATEAU MAR BEACH RESORT

License Type: Lodging

507 S ATLANTIC AVE , ORMOND BEACH 32176

Insp Date: 01/27/2025

Inspection Number: 1235411

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2025-01-27:	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Volusia**

License Number: 7405218

EXTENDED STAY OF ORMOND

License Type: Lodging

1608 N US HWY 1 , ORMOND BEACH 32174

Insp Date: 01/24/2025

Inspection Number: 1234214

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

04-02-4

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only.-room 140.
- From follow-up inspection 2025-01-24:

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400746

CHATEAU MAR BEACH RESORT

License Type: Lodging

507 S ATLANTIC AVE , ORMOND BEACH 32176

Insp Date: 01/27/2025

Inspection Number: 1235411

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

04-02-4

- From initial inspection : No smoke detector provided in guest room/unit 104. For reporting purposes only. -
From follow-up inspection 2025-01-27:

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/01/2025

Washington

License Number: 7700111

RED ROOF INN CHIPLEY

License Type: Lodging

1593 MAIN ST , CHIPLEY 32428

Insp Date: 01/27/2025

Inspection Number: 1235289

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Observed smoke detector missing in room 108.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.