



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Alachua**

License Number: 1102323

**HIGH SPRINGS INN**

License Type: Lodging

15920 NW US HWY 441 , ALACHUA 32615

Insp Date: 02/05/2025

Inspection Number: 1236790

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-03-4

Observation

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke alarm missing from room 114.

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620840

**ELLIOT COCOPLUM**

License Type: Lodging

3884 COCOPLUM CIR , COCONUT CREEK 33063

Insp Date: 02/07/2025

Inspection Number: 1623345

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

01-02-4

Observation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed by unit 3518 building 2, by unit 3632 building 5 \*\*Repeat Violation\*\*

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Broward**

License Number: 1607221

**FORT LAUDERDALE GRAND HOTEL**

License Type: Lodging

4900 POWERLINE ROAD , OAKLAND PARK 33309

Insp Date: 02/07/2025

Inspection Number: 1183373

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1604982

**COLONY APARTMENTS**

License Type: Lodging

709 SE 15 ST , FORT LAUDERDALE 62667

Insp Date: 01/31/2025

Inspection Number: 1586813

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. Located at bldg 711 between units 2 and 3. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Broward**

License Number: 1620918

**FORT LAUDERDALE TRU/HOMES2**

License Type: Lodging

315 NW 1 AVE , FORT LAUDERDALE 33301

Insp Date: 01/31/2025

Inspection Number: 1181907

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620877

**CHATEAU MAR GOLF RESORT**

License Type: Lodging

3501 INVERRARY BLVD , LAUDERHILL 33319

Insp Date: 02/05/2025

Inspection Number: 1183362

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher at end of the hall next to room 730

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/08/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Broward**

License Number: 1607305

**PLAZA HOTEL FORT LAUDERDALE**

License Type: Lodging

5100 N SR 7 , FORT LAUDERDALE 33319

Insp Date: 02/06/2025

Inspection Number: 1183372

Insp Type: Complaint Full

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Manager still in process of getting boiler inspected \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1801529

**HOLIDAY INN EXPRESS AND SUITES PUNTA GORDA**

License Type: Lodging

9075 MAC DR , PUNTA GORDA 33950

Insp Date: 02/05/2025

Inspection Number: 1182037

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No  
Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Jurisdiction No. 134468; 134477. Expiration Date: 01/19/2023. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Dade**

License Number: 2329452

**BOUTIQUE APARTMENTS**

License Type: Lodging

5445 COLLINS AVENUE CU 10 , MIAMI BEACH 33140

Insp Date: 02/06/2025

Inspection Number: 1183361

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed main panel with trouble light flashing .

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310858

**MARINA DEL MAR**

License Type: Lodging

100 KING POINT DR , MIAMI BEACH 33160

Insp Date: 02/07/2025

Inspection Number: 1623380

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310858

**MARINA DEL MAR**

License Type: Lodging

100 KING POINT DR , MIAMI BEACH 33160

Insp Date: 02/07/2025

Inspection Number: 1623380

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Dade**

License Number: 2329294

**HOME2 SUITES BY HILTON FLORIDA CITY**

License Type: Lodging

77 NE 3RD ST , FLORIDA CITY 33034

Insp Date: 02/06/2025

Inspection Number: 1179277

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at the first floor.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329293

**6345 ACTIVATE MB LLC**

License Type: Lodging

6345 COLLINS AVE , MIAMI BEACH 33141

Insp Date: 02/03/2025

Inspection Number: 1182478

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329394

**CASITA 76**

License Type: Lodging

7610 HARDING AV , MIAMI BEACH 33141

Insp Date: 02/04/2025

Inspection Number: 1182528

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher near unit 3 missing breaking utensil. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Dade**

License Number: 2329193

**SOUTH RIVER SUITES**

License Type: Lodging

12484 NW SOUTH RIVER DR , MEDLEY 33178

Insp Date: 02/07/2025

Inspection Number: 1178919

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2321514

**HOLIDAY INN EXPRESS & SUITES - MIAMI/HIALEAH**

License Type: Lodging

6650 W 20 AVE , HIALEAH 33016

Insp Date: 02/04/2025

Inspection Number: 1178920

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Dade**

License Number: 2317880

**COMFORT INN AND SUITES DOWNTOWN/BRICKELL**

License Type: Lodging

100 SE 4TH ST , MIAMI 33131

Insp Date: 02/06/2025

Inspection Number: 1179178

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304345

**HOLIDAY INN MIAMI BEACH OCEANFRONT**

License Type: Lodging

4333 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 02/04/2025

Inspection Number: 1181956

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed one hearing impaired device not functioning correctly ( light is not flashing when testing ) .

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Report Date: 02/08/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2328328

**RITZ CARLTON HOTEL CO**

License Type: Lodging

455 GRAND BAY DR , KEY BISCAYNE 33149

Insp Date: 02/07/2025

Inspection Number: 1178194

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed FI 095056; 095057; 095045; 095044 all expired on 12/09/24.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329338

**HILTON GARDEN INN MIAMI DOLPHIN MALL**

License Type: Lodging

1695 NW 111 AVE , SWEETWATER 33172

Insp Date: 01/31/2025

Inspection Number: 1178321

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 4 boiler certificates expire 08/22/2024.As per chief engineering inspection for all four units performed on 09/06/2024 by Hartford steam boiler and certificates has been delayed.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Dade**

License Number: 2321990

**QUALITY INN MIAMI AIRPORT**

License Type: Lodging

3959 NW 79 AVE , MIAMI 33166

Insp Date: 02/06/2025

Inspection Number: 1177013

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed #123868 11/27/2020, #080920 10/28/2023, #123866 10/28/2023. EXPIRED.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317880

**COMFORT INN AND SUITES DOWNTOWN/BRICKELL**

License Type: Lodging

100 SE 4TH ST , MIAMI 33131

Insp Date: 02/06/2025

Inspection Number: 1179178

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/08/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2329193

**SOUTH RIVER SUITES**

License Type: Lodging

12484 NW SOUTH RIVER DR , MEDLEY 33178

Insp Date: 02/07/2025

Inspection Number: 1178919

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327849

**SONESTA SIMPLY SUITES MIAMI AIRPORT**

License Type: Lodging

8855 NW 27TH ST , MIAMI 33172

Insp Date: 02/04/2025

Inspection Number: 1181986

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-04-4

Observation

Boiler certificate not posted in the boiler room. For reporting purposes only. On not current boiler certificates at boiler room, manager printed certificates and placed it inside boiler room. \*\*Corrected On-Site\*\*

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/08/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2329331

**RESIDENCE INN MIAMI BEACH SURFSIDE**

License Type: Lodging

9200 COLLINS AVE , SURFSIDE 33154

Insp Date: 02/04/2025

Inspection Number: 1182601

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310669

**DOMINION TOWER**

License Type: Lodging

1400 NW 10 AVE , MIAMI 61000

Insp Date: 02/04/2025

Inspection Number: 1586380

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

40-06-4

No child labor law poster and at least one person under 18 years old is employed. For reporting purposes only.  
\*\*Corrected On-Site\*\*

Reporting: Proof of age; posting of notices.--(1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.



Report Date: 02/08/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Duval**

License Number: 2613280

**TOWNEPLACE SUITES BY MARRIOTT**

License Type: Lodging

13741 BEACH BLVD , JACKSONVILLE 32224

Insp Date: 02/03/2025

Inspection Number: 1178494

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Hearing impaired smoke detector in ADA room #514 not functioning when tested/ when door bell pressed for 5 seconds as instructed on ADA room doorbell.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2609221

**BAYMONT INN AND SUITES**

License Type: Lodging

8555 BLANDING BLVD , JACKSONVILLE 32244

Insp Date: 02/06/2025

Inspection Number: 1241060

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate posted in boiler room expired on 11-16-2024. Person in charge states inspection is scheduled. \*\*Corrective Action Taken\*\* \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Duval**

License Number: 2613249

**TOWNEPLACE SUITES**

License Type: Lodging

4801 LENOIR AVE , JACKSONVILLE 32216

Insp Date: 02/06/2025

Inspection Number: 1179010

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Information of boiler was found on boiler website showing operator has 3 boilers active & but expired \*\*Repeat Violation\*\*

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/08/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Hillsborough**

License Number: 3913864

**FITZGERALD**

License Type: Lodging

1211 E KENNEDY BLVD , TAMPA 33602

Insp Date: 02/05/2025

Inspection Number: 1623313

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. Operator is aware and has quote to have repairs completed scheduled to be performed within the next 2 weeks.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912467

**RESIDENCE INN TAMPA DOWNTOWN**

License Type: Lodging

101 E TYLER ST , TAMPA 33602

Insp Date: 02/03/2025

Inspection Number: 1182697

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4503089

**INTEGRA HEIGHTS APARTMENTS**

License Type: Lodging

2100 OLYMPUS BLVD , CLERMONT 34714

Insp Date: 02/07/2025

Inspection Number: 1590088

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.-unit 4110

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/08/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Lee**

License Number: 4602884

**DOUBLETREE HOTEL FORT MYERS**

License Type: Lodging

13051 BELL TOWER DR , FORT MYERS 75927

Insp Date: 02/04/2025

Inspection Number: 1177779

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Insurance inspector's boiler report expired on 09/13/2022. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811138

**ALOFT ORLANDO DOWNTOWN HOTEL**

License Type: Lodging

500 S ORANGE AVE , ORLANDO 32801

Insp Date: 02/05/2025

Inspection Number: 1178384

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Operator has completed boiler inspection and is waiting to receive certificates

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Orange**

License Number: 5801516

**ROSEN INN**

License Type: Lodging

6327 INTERNATIONAL DR , ORLANDO 32819

Insp Date: 02/04/2025

Inspection Number: 1178520

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.FL 139455, FL 139454 expired 1/31/25Chief engineer stated company coming this week for inspection

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811220

**PESTANA ORLANDO SUITES LAKE BUENA VISTA**

License Type: Lodging

11942 RAVALLO RESORT DR , ORLANDO 32836

Insp Date: 01/31/2025

Inspection Number: 1178290

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.Observed no copy of boiler certificates or inspection report. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/08/2025

Osceola

License Number: 5900617

RODEWAY INN

License Type: Lodging

7455 W IRLO BRONSON HWY , KISSIMMEE 34747

Insp Date: 02/06/2025

Inspection Number: 1236067

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Expired 9/20/24 - From follow-up inspection 2025-02-05: \*\*Time Extended\*\* - From follow-up inspection 2025-02-06: \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900617

RODEWAY INN

License Type: Lodging

7455 W IRLO BRONSON HWY , KISSIMMEE 34747

Insp Date: 02/06/2025

Inspection Number: 1236067

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-04-4

- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2025-02-05: \*\*Time Extended\*\* - From follow-up inspection 2025-02-06: \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/08/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Osceola**

License Number: 5900617

**RODEWAY INN**

License Type: Lodging

7455 W IRLO BRONSON HWY , KISSIMMEE 34747

Insp Date: 02/06/2025

Inspection Number: 1236067

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-06-4

- From initial inspection : Combustibles stored in boiler room. For reporting purposes only. Gas can and cardboard boxes in boiler room - From follow-up inspection 2025-02-05: \*\*Time Extended\*\* - From follow-up inspection 2025-02-06: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900617

**RODEWAY INN**

License Type: Lodging

7455 W IRLO BRONSON HWY , KISSIMMEE 34747

Insp Date: 02/05/2025

Inspection Number: 1236067

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 9/20/24 - From follow-up inspection 2025-02-05: \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Osceola**

License Number: 5900617

**RODEWAY INN**

License Type: Lodging

7455 W IRLO BRONSON HWY , KISSIMMEE 34747

Insp Date: 02/05/2025

Inspection Number: 1236067

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

08-04-4

- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2025-02-05: \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900617

**RODEWAY INN**

License Type: Lodging

7455 W IRLO BRONSON HWY , KISSIMMEE 34747

Insp Date: 02/05/2025

Inspection Number: 1236067

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

08-06-4

- From initial inspection : Combustibles stored in boiler room. For reporting purposes only. Gas can and cardboard boxes in boiler room - From follow-up inspection 2025-02-05: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Palm Beach**

License Number: 6014278

**LUCAYA DELRAY INC**

License Type: Lodging

1541 CATHERINE DR STE #1 , DELRAY BEACH 33445

Insp Date: 02/05/2025

Inspection Number: 1596996

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only...fire extinguisher at 1550

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6804777

**HOLIDAY INN EXPRESS NOKOMIS SARASOTA SOUTH**

License Type: Lodging

206 ALBEE RD W , NOKOMIS 34275

Insp Date: 02/07/2025

Inspection Number: 1178883

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

06-02-4

Door marked as an exit is blocked. For reporting purposes only.Observed the South stairwell level 1 exit blocked by rolling carts.The operator had the carts moved allowing access to the exit. \*\*Corrected On-Site\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/08/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Seminole**

License Number: 6901069

License Type: Lodging

**QUALITY INN & SUITES**

150 S WESTMONTE DR , ALTAMONTE SPRINGS 32714

Insp Date: 02/03/2025

Inspection Number: 1236179

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.-empty fire extinguisher boxes by rooms 112 and 113, in breezeway by room 123. - From follow-up inspection 2025-02-03: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 6602521

License Type: Lodging

**RESIDENCE INN BY MARRIOTT PORT ST LUCIE**

1920 SW FOUNTAINVIEW BLVD , PORT ST LUCIE 34986

Insp Date: 02/06/2025

Inspection Number: 1181903

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Map fault data card 2. Management has called to be serviced. **Corrective Action Taken**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**St. Lucie**

License Number: 6602521

License Type: Lodging

**RESIDENCE INN BY MARRIOTT PORT ST LUCIE**

1920 SW FOUNTAINVIEW BLVD , PORT ST LUCIE 34986

Insp Date: 02/06/2025

Inspection Number: 1181903

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 130519 6/27/24, 138687 6/21/24

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602260

License Type: Lodging

**SPRINGHILL SUITES BY MARRIOTT**

2000 NW COURTYARD CIR , PORT ST LUCIE 34986

Insp Date: 02/07/2025

Inspection Number: 1181947

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Banquet PS Trouble. Per Front desk staff, company has been notified about trouble message.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/08/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**St. Lucie**

License Number: 6602529

**TRU BY HILTON PORT ST LUCIE**

License Type: Lodging

11560 SW VILLAGE PKWY , PORT ST LUCIE 34987

Insp Date: 02/04/2025

Inspection Number: 1181973

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire panel reads Ground fault loop 2. Operator stated fire alarm company came out recently and tried to reset and will come back to fix ground fault sensor.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401253

**PATRICIAN APARTMENTS 2**

License Type: Lodging

147 BOYNTON BLVD , DAYTONA BEACH SHORES 32118

Insp Date: 02/04/2025

Inspection Number: 1599779

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.-breakaway panel box missing breaking device, 2nd floor on wall mounted unit

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406498

**CASTAWAYS BEACH RESORT**

License Type: Lodging

2043 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 02/04/2025

Inspection Number: 1181928

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.-south side of building near side fire exit towards pool

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 02/08/2025

**Volusia**

License Number: 7406516

**COMFORT SUITES SPEEDWAY**

License Type: Lodging

2900 W. INTERNATIONAL SPEEDWAY BLVD , DAYTONA BEACH 32124

Insp Date: 01/31/2025

Inspection Number: 1178465

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.-fire extinguisher across from room 415

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406522

**OCEAN WALK SOUTH TOWER RESORT**

License Type: Lodging

300 N ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 02/06/2025

Inspection Number: 1179193

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/08/2025

Volusia

License Number: 7400503

**BAYMONT BY WYNDHAM**

License Type: Lodging

2725 W INTERNATIONAL SPWY BLVD , DAYTONA BEACH 32114

Insp Date: 01/31/2025

Inspection Number: 1240971

Insp Type: Complaint Full

Disposition: Call Back - Extension given,  
pending

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Manager reset \*\*Corrected On-Site\*\* - From follow-up inspection 2025-01-31:

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.