



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Alachua

License Number: 1100015

QUALITY INN

License Type: Lodging

7516 W NEWBERRY RD , GAINESVILLE 32606

Insp Date: 02/11/2025

Inspection Number: 1236273

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher in front of room 127. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1100155

CLASSIC INN

License Type: Lodging

14925 NE US HWY 301 S , WALDO 32694

Insp Date: 02/10/2025

Inspection Number: 1240309

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

06-06-4

Door marked as an exit locked with a lock that requires a key. For reporting purposes only. Units 20/21 and 11 with exterior door locks only accessible only from the outside. **Admin Complaint**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Alachua

License Number: 1100155

CLASSIC INN

License Type: Lodging

14925 NE US HWY 301 S , WALDO 32694

Insp Date: 02/10/2025

Inspection Number: 1240309

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only. Multiple damaged wires with electrical tape.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1612422

LAQUINTA INN & SUITES

License Type: Lodging

351 W HILLSBORO BLVD , DEERFIELD BEACH 33441

Insp Date: 02/10/2025

Inspection Number: 1623314

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Observed in guest room 207.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Broward

License Number: 1612878

HOTOLOS HOLLYWOOD

License Type: Lodging

2520 STIRLING RD , HOLLYWOOD 33020

Insp Date: 02/14/2025

Inspection Number: 1239582

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Observed in room 328

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620840

ELLIOT COCOPLUM

License Type: Lodging

3884 COCOPLUM CIR , COCONUT CREEK 33063

Insp Date: 02/07/2025

Inspection Number: 1623345

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed by unit 3518 building 2, by unit 3632 building 5 **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1607221

FORT LAUDERDALE GRAND HOTEL

License Type: Lodging

4900 POWERLINE ROAD , OAKLAND PARK 33309

Insp Date: 02/07/2025

Inspection Number: 1183373

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1607305

PLAZA HOTEL FORT LAUDERDALE

License Type: Lodging

5100 N SR 7 , FORT LAUDERDALE 33319

Insp Date: 02/11/2025

Inspection Number: 1183386

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Broward

License Number: 1606529

TIRANA APARTMENTS

License Type: Lodging

2930 NW 29 ST , FORT LAUDERDALE 11235

Insp Date: 02/10/2025

Inspection Number: 1584754

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on ground floor. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1600334

RIVERSIDE HOTEL

License Type: Lodging

620 E LAS OLAS BLVD , FORT LAUDERDALE 33301

Insp Date: 02/13/2025

Inspection Number: 1182784

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Dade

License Number: 2310858

MARINA DEL MAR

License Type: Lodging

100 KING POINT DR , MIAMI BEACH 33160

Insp Date: 02/07/2025

Inspection Number: 1623380

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310858

MARINA DEL MAR

License Type: Lodging

100 KING POINT DR , MIAMI BEACH 33160

Insp Date: 02/07/2025

Inspection Number: 1623380

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329441

DUNNS JOSEPHINE HOTEL

License Type: Lodging

1028 N.W. 3RD AVE , MIAMI 33136

Insp Date: 02/10/2025

Inspection Number: 1182197

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. First floor in the lobby and on the second floor inside the fire panel room. **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Dade

License Number: 2304248

DECO MODE HOTEL

License Type: Lodging

411 WASHINGTON AVE , MIAMI BEACH 33139

Insp Date: 02/11/2025

Inspection Number: 1183383

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327558

LOEWS MIAMI BCH HOTEL

License Type: Lodging

1601 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 02/11/2025

Inspection Number: 1178476

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Dade

License Number: 2328417

ROYAL PALM

License Type: Lodging

1545 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 02/13/2025

Inspection Number: 1178279

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329193

SOUTH RIVER SUITES

License Type: Lodging

12484 NW SOUTH RIVER DR , MEDLEY 33178

Insp Date: 02/07/2025

Inspection Number: 1178919

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Dade

License Number: 2329208

GRAND BEACH HOTEL

License Type: Lodging

4835 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 02/10/2025

Inspection Number: 1179185

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed in the main panel .

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330719

BEZEL MIAMI

License Type: Lodging

650 NE 2ND AVE , MIAMI 33132

Insp Date: 02/10/2025

Inspection Number: 1593574

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Dade

License Number: 2328328

RITZ CARLTON HOTEL CO

License Type: Lodging

455 GRAND BAY DR , KEY BISCAINE 33149

Insp Date: 02/07/2025

Inspection Number: 1178194

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed FI 095056; 095057; 095045; 095044 all expired on 12/09/24.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326874

EXTENDED STAY AMERICA #9639

License Type: Lodging

8720 NW 33RD ST , MIAMI 33172

Insp Date: 02/13/2025

Inspection Number: 1182088

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificates 055352 expired 07/14/2024 055353 expired 07/14/2024.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Dade

License Number: 2317292

HOLIDAY INN

License Type: Lodging

7707 NW 103 ST , HIALEAH GARDENS 33016

Insp Date: 02/11/2025

Inspection Number: 1182090

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326398

HAMPTON INN MIAMI - AIRPORT WEST

License Type: Lodging

3620 NW 79 AVE , DORAL 33166

Insp Date: 02/10/2025

Inspection Number: 1178878

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed Boiler Jurisdiction 055306, 1/5/2025. EXPIRED.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Dade

License Number: 2329193

SOUTH RIVER SUITES

License Type: Lodging

12484 NW SOUTH RIVER DR , MEDLEY 33178

Insp Date: 02/07/2025

Inspection Number: 1178919

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304248

DECO MODE HOTEL

License Type: Lodging

411 WASHINGTON AVE , MIAMI BEACH 33139

Insp Date: 02/11/2025

Inspection Number: 1176774

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

04-01-4

Observation

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2025-02-11: **Time Extended**

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2331139

ALEA MIAMI

License Type: Lodging

230 NE 4TH STREET , MIAMI 33132

Insp Date: 02/13/2025

Inspection Number: 1623397

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612227

LA QUINTA INN AND SUITES

License Type: Lodging

4686 LENOIR AVE S , JACKSONVILLE 32216

Insp Date: 02/13/2025

Inspection Number: 1181949

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Jurisdiction #133177 expiration 03/9/2024 & Jurisdiction #135340 expiration 06/29/2024 as per boiler website **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Hillsborough

License Number: 3913670

SAILPORT RESORT

License Type: Lodging

2506 ROCKY POINT RD , TAMPA 33607

Insp Date: 02/11/2025

Inspection Number: 1183336

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4100126

HSP UNITED LLC

License Type: Lodging

2022 US HWY 1 , VERO BEACH 32960

Insp Date: 02/14/2025

Inspection Number: 1236976

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.#19

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lake

License Number: 4503089

INTEGRA HEIGHTS APARTMENTS

License Type: Lodging

2100 OLYMPUS BLVD , CLERMONT 34714

Insp Date: 02/07/2025

Inspection Number: 1590088

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.-unit 4110

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4702734

CANYON PARK APARTMENTS

License Type: Lodging

1325 W THARPE ST , TALLAHASSEE 32303

Insp Date: 02/11/2025

Inspection Number: 1623147

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only. Open electrical panels on ac units at 12, and 7.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5202445

MICROTEL INN & SUITES

License Type: Lodging

1770 SW 134 ST , OCALA 34473

Insp Date: 02/13/2025

Inspection Number: 1183392

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.Extinguisher near door in dining area in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Nassau

License Number: 5500978

BEACH HOUSE AT AMELIA

License Type: Lodging

85041 CHRISTIAN WAY , YULEE 32097

Insp Date: 02/10/2025

Inspection Number: 1589323

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by garage #1913.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803638

AC HOTEL ORLANDO LAKE BUENA VISTA

License Type: Lodging

12799 APOPKA VINELAND RD , ORLANDO 32836

Insp Date: 02/10/2025

Inspection Number: 1178811

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificates expired 122058, 135762 9/2/2024. General Manager notify insurance company **Corrective Action Taken**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Osceola

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 02/13/2025

Inspection Number: 1183389

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 02/13/2025

Inspection Number: 1183389

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Pinellas

License Number: 6205242

CANTERBURY VILLAS APTS

License Type: Lodging

1200 S SEMINOLE BLVD , LARGO 08401

Insp Date: 02/12/2025

Inspection Number: 1623273

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

07-01-4

The operator has filed for a permit to replace the entire electrical panel for building 16. The permit was recently approved and now the operator is in process of coordinating Duke energy and the electrical repair company for replacement. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203064

TRADEWINDS SANDPIPER BEACH RESORT

License Type: Lodging

6000 GULF BLVD , ST. PETE BEACH 33706

Insp Date: 02/10/2025

Inspection Number: 1240081

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow trouble light illuminated on fire panel in lobby.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203064

TRADEWINDS SANDPIPER BEACH RESORT

License Type: Lodging

6000 GULF BLVD , ST. PETE BEACH 33706

Insp Date: 02/10/2025

Inspection Number: 1240081

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate on file 131350 exp. 8-2-2024

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Pinellas

License Number: 6215855

OPAL SOL

License Type: Lodging

400 CORONADO DR , CLEARWATER BEACH 33767

Insp Date: 02/11/2025

Inspection Number: 1183365

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. New units. No certificates available at this time.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6207593

HILTON CLEARWATER BEACH RESORT

License Type: Lodging

400 MANDALAY AVE , CLEARWATER 33767

Insp Date: 02/13/2025

Inspection Number: 1178842

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FI 098791,098793,098795,098786,056656 all expire 11/10/2024

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Sarasota

License Number: 6804777

HOLIDAY INN EXPRESS NOKOMIS SARASOTA SOUTH

License Type: Lodging

206 ALBEE RD W , NOKOMIS 34275

Insp Date: 02/07/2025

Inspection Number: 1178883

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

06-02-4

Door marked as an exit is blocked. For reporting purposes only. Observed the South stairwell level 1 exit blocked by rolling carts. The operator had the carts moved allowing access to the exit. ****Corrected On-Site****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602260

SPRINGHILL SUITES BY MARRIOTT

License Type: Lodging

2000 NW COURTYARD CIR , PORT ST LUCIE 34986

Insp Date: 02/07/2025

Inspection Number: 1181947

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Banquet PS Trouble. Per Front desk staff, company has been notified about trouble message.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602521

RESIDENCE INN BY MARRIOTT PORT ST LUCIE

License Type: Lodging

1920 SW FOUNTAINVIEW BLVD , PORT ST LUCIE 34986

Insp Date: 02/12/2025

Inspection Number: 1181903

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Map fault data card 2. Management has called to be serviced. ****Corrective Action Taken**** - From follow-up inspection 2025-02-12: ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

St. Lucie

License Number: 6602521

RESIDENCE INN BY MARRIOTT PORT ST LUCIE

License Type: Lodging

1920 SW FOUNTAINVIEW BLVD , PORT ST LUCIE 34986

Insp Date: 02/12/2025

Inspection Number: 1181903

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 130519 6/27/24, 138687 6/21/24 - From follow-up inspection 2025-02-12: **Time Extended**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400039

BLEU BEACH CLUB

License Type: Lodging

1503 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 02/12/2025

Inspection Number: 1241020

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.- inside storage room under stairway near unit 110

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403560

NAUTILUS INN

License Type: Lodging

1515 S ATLANTIC AVE , DAYTONA BEACH 84954

Insp Date: 02/12/2025

Inspection Number: 1182757

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.-glass panel breakaway box with no breaking device, mounted next to fire escape on level 7, and across from employee lounge on level 2

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 02/15/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7403560

NAUTILUS INN

License Type: Lodging

1515 S ATLANTIC AVE , DAYTONA BEACH 84954

Insp Date: 02/12/2025

Inspection Number: 1182757

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-trouble lights, units and 408, 607, 1007, 1008

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405753

ECONOLODGE

License Type: Lodging

1614 N US 1 , ORMOND BEACH 32174

Insp Date: 02/10/2025

Inspection Number: 1234478

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401304

LABELLA INN

License Type: Lodging

1400 N ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 02/13/2025

Inspection Number: 1237293

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

06-01-4

Path to fire escape exit is blocked/obstructed. For reporting purposes only.-several bicycles obstructing platform egress in front of unit 128-129

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 02/15/2025

Volusia

License Number: 7400147

KONA KAI DB LLC

License Type: Lodging

19 S HOLLYWOOD AVE 19-23 , DAYTONA BEACH 32118

Insp Date: 02/10/2025

Inspection Number: 1582854

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

07-01-4

Disrepair in electrical wire(s). For reporting purposes only.- underneath structure at building 23

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406498

CASTAWAYS BEACH RESORT

License Type: Lodging

2043 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 02/10/2025

Inspection Number: 1181928

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

07-04-4

- From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only.-south side of building near side fire exit towards pool - From follow-up inspection 2025-02-10: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.