



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Alachua

License Number: 1100099

QUALITY INN OF ALACHUA

License Type: Lodging

15960 NW US 441 , ALACHUA 32615

Insp Date: 03/04/2025

Inspection Number: 1240329

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher outside of room 241.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1100249

COLLEGE MANOR

License Type: Lodging

1216 SW 2 AVE , GAINESVILLE 16160

Insp Date: 02/28/2025

Inspection Number: 1582332

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. In hallway across from apartment 64.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Alachua

License Number: 1102962

AC HOTEL BY MARRIOTT GAINESVILLE

License Type: Lodging

151 NW 14 ST , GAINESVILLE 32603

Insp Date: 03/05/2025

Inspection Number: 1179113

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed 3 trouble alerts showing on the control panel at the front desk.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1619988

BRIDGEPLACE APARTMENTS

License Type: Lodging

2800 NW 44 ST , OAKLAND PARK 33309

Insp Date: 03/05/2025

Inspection Number: 1590729

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 1st floor Outside apt 113, 109, 103, 101 building 2nd floor located by apt 202 building 2750

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Broward

License Number: 1619988

BRIDGEPLACE APARTMENTS

License Type: Lodging

2800 NW 44 ST , OAKLAND PARK 33309

Insp Date: 03/05/2025

Inspection Number: 1590729

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. 3rd floor located by apt 314 building 2750

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1610480

OCEAN MANOR RESORT

License Type: Lodging

4040 GALT OCEAN DR , FORT LAUDERDALE 33308

Insp Date: 02/28/2025

Inspection Number: 1175757

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel located at the front office. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/08/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1620712

HOLLYWOOD BEACH MARRIOTT

License Type: Lodging

2501 N OCEAN DR , HOLLYWOOD 33019

Insp Date: 02/28/2025

Inspection Number: 1182374

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 1/31/2025.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621802

KADY PROPERTIES LLC 1616

License Type: Lodging

1616 NE 11 ST , FORT LAUDERDALE 33304

Insp Date: 03/05/2025

Inspection Number: 1597803

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.Observed by unit 3
- From follow-up inspection 2025-03-05: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/08/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1607305

PLAZA HOTEL FORT LAUDERDALE

License Type: Lodging

5100 N SR 7 , FORT LAUDERDALE 33319

Insp Date: 03/07/2025

Inspection Number: 1183471

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Per manager, expired, inspection appointment is I. Process **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328390

SAGAMORE MIAMI BEACH

License Type: Lodging

1671 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 03/03/2025

Inspection Number: 1178743

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Dade

License Number: 2319933

EMBASSY SUITES HOTEL MIAMI AIRPORT

License Type: Lodging

3974 NW SOUTH RIVER DR , MIAMI 33142

Insp Date: 03/04/2025

Inspection Number: 1183465

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed Boiler 075518 Expired 11-18-2020, Boiler 120328 Expired 11-18-2020, Boiler 123961 Expired 11-18-2020. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317880

COMFORT INN AND SUITES DOWNTOWN/BRICKELL

License Type: Lodging

100 SE 4TH ST , MIAMI 33131

Insp Date: 02/28/2025

Inspection Number: 1183438

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Corrected On-Site**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Dade

License Number: 2331301

WYNWOOD WORKS MANAGER LLC

License Type: Lodging

2035 N MIAMI AVE , MIAMI 33127

Insp Date: 02/28/2025

Inspection Number: 1623554

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2316920

AMERICAN MANAGEMENT & INVESTMENT LLC

License Type: Lodging

10933 SW 4 ST , SWEETWATER 33174

Insp Date: 03/03/2025

Inspection Number: 1596874

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed in between of apt 4 and 5.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Dade

License Number: 2324635

APARTMENTS

License Type: Lodging

606 NW 1 AVE , HOMESTEAD 33030

Insp Date: 02/28/2025

Inspection Number: 1582668

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed portable fire extinguisher between unit #2 and #3.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310019

9TH STREET HOMESTEAD LLC

License Type: Lodging

183 NW 9 ST UNIT 1-6 , HOMESTEAD 33030

Insp Date: 03/03/2025

Inspection Number: 1597141

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable ext to meter room.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Dade

License Number: 2309610

9TH STREET HOMESTEAD LLC

License Type: Lodging

190 NW 9 ST , HOMESTEAD 33030

Insp Date: 03/03/2025

Inspection Number: 1591252

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-06-4

Observation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to the laundry room.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309749

EDEN ROC

License Type: Lodging

4525 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 03/06/2025

Inspection Number: 1176214

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Dade

License Number: 2329461

MINT HOUSE FLORIDA MUZE

License Type: Lodging

340 SE 3 ST FLR 21 , MIAMI 33131

Insp Date: 03/04/2025

Inspection Number: 1175886

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329315

HYATT PLACE MIAMI AIRPORT EAST

License Type: Lodging

3549 NW LEJEUNE RD , MIAMI SPRINGS 33142

Insp Date: 03/07/2025

Inspection Number: 1178790

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Dade

License Number: 2310182

YELLOW KING APARTMENTS

License Type: Lodging

12890 NE 6 AVE , NORTH MIAMI 33161

Insp Date: 03/04/2025

Inspection Number: 1592533

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327573

EXTENDED STAY AMERICA #9641

License Type: Lodging

101 FAIRWAY DR , MIAMI 33166

Insp Date: 02/28/2025

Inspection Number: 1178599

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed in Room 309.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Dade

License Number: 2329244

EXTENDED STAY AMERICA #1760

License Type: Lodging

298 SW 15 RD , MIAMI 33129

Insp Date: 02/28/2025

Inspection Number: 1179285

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate 097115 097116 expired on 08-12-2022
Repeat Violation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320005

MIAMI MARRIOTT DADELAND

License Type: Lodging

9090 S DADELAND BLVD , MIAMI 67825

Insp Date: 03/07/2025

Inspection Number: 1182054

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. FL98799, FL98798, FL 123243, FL123244 with not boiler certification.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Dade

License Number: 2329271

HOLIDAY INN EXPRESS MIAMI AIRPORT- BLUE LAGOON

License Type: Lodging

6750 NW 7 ST , MIAMI 33126

Insp Date: 03/04/2025

Inspection Number: 1182145

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed no boiler certificate for FL 134828, 131332

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2316403

CUTLER MANOR APARTMENTS

License Type: Lodging

10875 SW 216 ST , MIAMI 03103

Insp Date: 03/04/2025

Inspection Number: 1623187

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

01-06-4

Observation

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed throughout the property. ****Repeat Violation**** - From follow-up inspection 2025-03-04: Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to unit #118.. ****Repeat Violation** **Time Extended****

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/08/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2311837

NORTH MIAMI BEACH GARDEN INN & SUITE

License Type: Lodging

148 NW 167 ST , MIAMI 33169

Insp Date: 03/07/2025

Inspection Number: 1241121

Insp Type: Complaint Partial

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. In the office. ****Repeat Violation**** - From follow-up inspection 2025-03-07: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. In the office. ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329231

BREAKWATER HOTEL

License Type: Lodging

940 - 960 OCEAN DR , MIAMI BEACH 33139

Insp Date: 03/06/2025

Inspection Number: 1178653

Insp Type: Complaint Full

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2024-11-12: ****Time Extended**** - From follow-up inspection 2025-03-06: ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613281

STUDIO 6 BAYMEADOWS

License Type: Lodging

8765 BAYMEADOWS RD , JACKSONVILLE 32256

Insp Date: 02/28/2025

Inspection Number: 1183414

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher in locked box by unit 151, 201. ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Duval

License Number: 2613281

STUDIO 6 BAYMEADOWS

License Type: Lodging

8765 BAYMEADOWS RD , JACKSONVILLE 32256

Insp Date: 02/28/2025

Inspection Number: 1183414

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.Unable to test hearing impaired smoke alarm during inspection. **Repeat Violation** **Warning**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2602613

SAMSON EQUITIES

License Type: Lodging

6455 SAN JUAN AVE , JACKSONVILLE 32210

Insp Date: 02/28/2025

Inspection Number: 1601492

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.Observed missing fire extinguisher at designated location near;Unit 49.Unit 33.Unit 31.Near laundry room.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613292

SPRINGHILL SUITES

License Type: Lodging

465 NORTH 1ST ST , JACKSONVILLE BEACH 32250

Insp Date: 03/06/2025

Inspection Number: 1179099

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.Observed room #255 hearing impaired Smoke detector/alarm not operable during inspection. **Warning**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Duval

License Number: 2613268

COMFORT SUITES

License Type: Lodging

1180 AIRPORT RD , JACKSONVILLE 32218

Insp Date: 03/03/2025

Inspection Number: 1182923

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. On third floor, extinguisher next to room 302 has needle in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2610282

DELTA HOTELS BY MARRIOTT JACKSONVILLE DEERWOOD

License Type: Lodging

4700 SALISBURY RD , JACKSONVILLE 32256

Insp Date: 02/28/2025

Inspection Number: 1177761

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Observed propane tank stored inside room adjoining boiler room.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/08/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Glades

License Number: 3200090

LITTLE BIG MAN MARINA

License Type: Lodging

3100 CR 721 LOOP , LAKEPORT 33471

Insp Date: 03/06/2025

Inspection Number: 1234826

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged in unit two. For reporting purposes only .

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3200090

LITTLE BIG MAN MARINA

License Type: Lodging

3100 CR 721 LOOP , LAKEPORT 33471

Insp Date: 03/06/2025

Inspection Number: 1234826

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable in unit two, with no cover. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3600462

AZTEC TOWNHOMES LLC

License Type: Lodging

100 AZTEC AVE , CLEWISTON 33440

Insp Date: 03/06/2025

Inspection Number: 1623574

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only. Sliding glass lass door on back of unit 2 broken and covered with plywood..

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Hillsborough

License Number: 3913674 **EXTENDED STAY AMERICA 9506**

License Type: Lodging 8940 E SLIGH AVE , TAMPA 33610

Insp Date: 03/05/2025 Inspection Number: 1179074 Insp Type: Routine - Lodging Disposition: Inspection Completed - No Further Action

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3905670

EMBASSY SUITES BY HILTON TAMPA AIRPORT WESTSHORE

License Type: Lodging 555 N WESTSHORE BLVD , TAMPA 33609

Insp Date: 03/06/2025 Inspection Number: 1179313 Insp Type: Routine - Lodging Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Jurisdiction: 052000, 131389, 051996 expiration:1/25/20251

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/08/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Leon

License Number: 4702292

SOUTHGATE CAMPUS CENTER

License Type: Lodging

675 W JEFFERSON ST , TALLAHASSEE 32304

Insp Date: 02/28/2025

Inspection Number: 1623445

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed six boilers and all were expired. 6 different Boilers: 056674 7/21/24, 05890 7/21/24, 056676 7/21/2024, 092868 7/21/24, 057891 3/15/2020, 057890 3/15/2020.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5403195

MARRIOTT COURTYARD

License Type: Lodging

2146 OVERSEAS HWY , MARATHON 33050

Insp Date: 03/04/2025

Inspection Number: 1178699

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Monroe

License Number: 5403212

BLUE WATER RESORT HOSPITALITY LLC

License Type: Lodging

2222 OVERSEAS HWY , MARATHON 33050

Insp Date: 03/04/2025

Inspection Number: 1178701

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5400459

HAVANA CABANA

License Type: Lodging

3420 N ROOSEVELT BLVD , KEY WEST 33040

Insp Date: 03/04/2025

Inspection Number: 1235769

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed in the office behind the front desk.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Monroe

License Number: 5403195

License Type: Lodging

MARRIOTT COURTYARD

2146 OVERSEAS HWY , MARATHON 33050

Insp Date: 03/04/2025

Inspection Number: 1178699

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-04-4

Observation

Boiler certificate not posted in the boiler room. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5403212

License Type: Lodging

BLUE WATER RESORT HOSPITALITY LLC

2222 OVERSEAS HWY , MARATHON 33050

Insp Date: 03/04/2025

Inspection Number: 1178701

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-04-4

Observation

Boiler certificate not posted in the boiler room. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Monroe

License Number: 5403212

BLUE WATER RESORT HOSPITALITY LLC

License Type: Lodging

2222 OVERSEAS HWY , MARATHON 33050

Insp Date: 03/04/2025

Inspection Number: 1178701

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-06-4

Combustibles stored in boiler room. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500875

HAMPTON INN & SUITES

License Type: Lodging

19 SOUTH 2 STREET , FERNANDINA BEACH 32034

Insp Date: 02/28/2025

Inspection Number: 1181963

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Both boiler certificates are expired - 03/01/2020. Manager states both were recently inspected, and establishment is awaiting certifications. **Corrective Action Taken** **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/08/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Okaloosa

License Number: 5603610

TOWNEPLACE SUITES BY MARRIOTT

License Type: Lodging

843 EGLIN PKWY , FORT WALTON BEACH 32547

Insp Date: 03/04/2025

Inspection Number: 1178700

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only: 130385, 11/27/2019; 130386, 11/27/2019; 130387, 11/27/2019. One boiler inoperative.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811193

TRYP ORLANDO SOUTH I-DRIVE

License Type: Lodging

11539 INTERNATIONAL DR , ORLANDO 32821

Insp Date: 03/06/2025

Inspection Number: 1183486

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Orange

License Number: 5808899

LA QUINTA ORLANDO AIRPORT NORTH

License Type: Lodging

7160 N FRONTAGE RD , ORLANDO 32812

Insp Date: 03/03/2025

Inspection Number: 1182250

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.(265291 expired 2-27-2025)-(265290 expired 2-27-2025).

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810888

DISNEY'S POP CENTURY RESORT

License Type: Lodging

1050 CENTURY DRIVE , LAKE BUENA VISTA 32830

Insp Date: 03/04/2025

Inspection Number: 1237183

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Observed boiler certificate 137667 expired 2/28/2025 Building #10 Manager notify engineering at time of inspection.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Osceola

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 03/05/2025

Inspection Number: 1183456

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 03/07/2025

Inspection Number: 1183456

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-03-07: ****Time Extended****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Palm Beach

License Number: 6011917

RESIDENCE INN WEST PALM BEACH

License Type: Lodging

2461 METROCENTRE BLVD , WEST PALM BEACH 33407

Insp Date: 02/28/2025

Inspection Number: 1181930

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler Certificate Expired 10/07/2023 - From follow-up inspection 2025-02-28: **Time Extended**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014088

PALM HOUSE

License Type: Lodging

160 ROYAL PALM WAY , PALM BEACH 33480

Insp Date: 03/03/2025

Inspection Number: 1182717

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2025-03-03: **Time Extended**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/08/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6200043

ORANGE MOTEL

License Type: Lodging

1736 GULF TO BAY BLVD , CLEARWATER 33755

Insp Date: 03/06/2025

Inspection Number: 1237072

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning- cord missing . For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6309178

STREAMSONG RESORT

License Type: Lodging

1000 STREAMSONG DR , STREAMSONG 33834

Insp Date: 03/06/2025

Inspection Number: 1182438

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.22-001836139850 Active01/26/202522-001837139849Active01/26/2025

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Sarasota

License Number: 6804889

CYPRESS SQUARE

License Type: Lodging

1671 21 ST , SARASOTA 34234

Insp Date: 03/05/2025

Inspection Number: 1581422

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.Observed in building 3

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6804889

CYPRESS SQUARE

License Type: Lodging

1671 21 ST , SARASOTA 34234

Insp Date: 03/05/2025

Inspection Number: 1581422

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.Observed missing in building 2

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/08/2025

Volusia

License Number: 7406520

EXTENDED STAY AMERICA #9512

License Type: Lodging

275 INTERCHANGE BLVD , ORMOND BEACH 32174

Insp Date: 03/05/2025

Inspection Number: 1176790

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406424

NEWPORT SOUND

License Type: Lodging

10101 NEWPORT SOUND PLACE , NEW SMYRNA BEACH 32168

Insp Date: 03/07/2025

Inspection Number: 1593497

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/08/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7406280

SUNSET INN

License Type: Lodging

544 S RIDGEWOOD AVE , DAYTONA BCH 32114

Insp Date: 03/04/2025

Inspection Number: 1237191

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400503

BAYMONT BY WYNDHAM

License Type: Lodging

2725 W INTERNATIONAL SPWY BLVD , DAYTONA BEACH 32114

Insp Date: 03/03/2025

Inspection Number: 1240971

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Manager reset **Corrected On-Site** - From follow-up inspection 2025-01-31: - From follow-up inspection 2025-03-03:

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401357

DAYTONA OCEAN BREEZE APARTMENTS LLC

License Type: Lodging

140 CASCADE TERR , DAYTONA BEACH SHORES 32118

Insp Date: 03/06/2025

Inspection Number: 1593848

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

06-01-4

Path to door unit door/marked as an exit is blocked. For reporting purposes only.-unit 116 obstructed by multiple bicycles

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.