



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/29/2025

Dade

License Number: 2329308

GATES HOTEL SOUTH BEACH

License Type: Lodging

2360 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 03/21/2025

Inspection Number: 1182121

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329308

GATES HOTEL SOUTH BEACH

License Type: Lodging

2360 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 03/21/2025

Inspection Number: 1182121

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed Laundry room 138177, expires on 09-06-2024, In 501-1134 and IN 501-1145 newly installed. 499,999 BTU's water temperature 210°F. Expires on 09-06-24.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 03/29/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2600158

SOUTHSIDE COMMONS APARTMENTS

License Type: Lodging

9801 OLD BAYMEADOWS RD , JACKSONVILLE 32256

Insp Date: 03/21/2025

Inspection Number: 1583781

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only. Smoke alarm missing from unit 24.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605655

VENETIAN

License Type: Lodging

4051 REGATA WAY , FORT MYERS 33916

Insp Date: 03/21/2025

Inspection Number: 1623669

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed no fire extinguisher in designated location in Building 12 1st Floor.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203962

PINK FLAMINGO MOTEL

License Type: Lodging

1800 N FT HARRISON AVE , CLEARWATER 33755

Insp Date: 03/21/2025

Inspection Number: 1240820

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 03/29/2025

Volusia

License Number: 7406509

BEACH HOUSE INN

License Type: Lodging

1601 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 03/21/2025

Inspection Number: 1236943

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

02-07-4

- From initial inspection : Flammable material stored near a source of ignition. For reporting purposes only.-lint allowed to build up under vent stack inside laundry room water heater - From follow-up inspection 2025-03-17: **Time Extended** - From follow-up inspection 2025-03-21: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.