



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Bay

License Number: 1300013

CHATEAU BY THE SEA

License Type: Lodging

12525 W FRONT BEACH RD , PANAMA CITY BEACH 32407

Insp Date: 07/24/2025

Inspection Number: 1244016

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing extinguisher in box outside 307, 338, and 426

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505672

HAMPTON INN BY HILTON MELBOURNE-VIERA

License Type: Lodging

130 SHERIFF DR. , MELBOURNE 32940

Insp Date: 07/24/2025

Inspection Number: 1185435

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. First floor fire extinguisher on the East side closer to ice machine is meter is in the red

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1607221

FORT LAUDERDALE GRAND HOTEL

License Type: Lodging

4900 POWERLINE ROAD , OAKLAND PARK 33309

Insp Date: 07/25/2025

Inspection Number: 1186609

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Broward

License Number: 1607221

FORT LAUDERDALE GRAND HOTEL

License Type: Lodging

4900 POWERLINE ROAD , OAKLAND PARK 33309

Insp Date: 07/25/2025

Inspection Number: 1186609

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621345

QUEUE APARTMENTS

License Type: Lodging

817 SE 2 AVE , FORT LAUDERDALE 33316

Insp Date: 07/23/2025

Inspection Number: 1644766

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated on fire panel located inside fire alarm control panel room.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Broward

License Number: 1620947

NOA STAY LLC

License Type: Lodging

3003 N UNIVERSITY DR , SUNRISE 33322

Insp Date: 07/21/2025

Inspection Number: 1186386

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.-Observed establishment using boiler, no certificate available at this time.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1612723

TRAVEL BUDGET INN

License Type: Lodging

2000 N FEDERAL HWY , HOLLYWOOD 33020

Insp Date: 07/18/2025

Inspection Number: 1241869

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

02-04-4

Observation

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Observed in laundry area. Operator removed **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1619051

HOMETOWNE STUDIOS - FORT LAUDERDALE 3512

License Type: Lodging

3031 W COMMERCIAL BLVD , FORT LAUDERDALE 33309

Insp Date: 07/21/2025

Inspection Number: 1183760

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-07-21: At time of callback inspection still observed ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1619051

HOMETOWNE STUDIOS - FORT LAUDERDALE 3512

License Type: Lodging

3031 W COMMERCIAL BLVD , FORT LAUDERDALE 33309

Insp Date: 07/21/2025

Inspection Number: 1183779

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-07-21: At time of callback inspection still observed ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2300489

GENESIS PROPERTY INVESTMENTS

License Type: Lodging

1442 SW 3 ST , MIAMI 33135

Insp Date: 07/24/2025

Inspection Number: 1644846

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 5.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2302263 **430 SW 3RD ST APARTMENTS**
License Type: Lodging 430 SW 3 ST , MIAMI 33130

Insp Date: 07/21/2025 Inspection Number: 1634130 Insp Type: Routine - Lodging Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed missing fire extinguisher on first level at building 436.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309799 **HOTEL NORMAN**
License Type: Lodging 6770 COLLINS AVE , MIAMI BEACH 33141

Insp Date: 07/24/2025 Inspection Number: 1184046 Insp Type: Routine - Lodging Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher near room 24 missing breaking utensils.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329415 **SIXTY80 DESIGN HOTEL**
License Type: Lodging 6080 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 07/24/2025 Inspection Number: 1185016 Insp Type: Routine - Lodging Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed main panel in trouble.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2321970

DORAL INN AND SUITES

License Type: Lodging

1212 NW 82 AVE , MIAMI 33126

Insp Date: 07/25/2025

Inspection Number: 1186000

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304248

DECO MODE HOTEL

License Type: Lodging

411 WASHINGTON AVE , MIAMI BEACH 33139

Insp Date: 07/25/2025

Inspection Number: 1185483

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305990

BCC APARTMENTS

License Type: Lodging

21160 SW 112 AVE , CUTLER BAY 33189

Insp Date: 07/22/2025

Inspection Number: 1642489

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2320229

LA QUINTA INN & SUITES MIAMI LAKES

License Type: Lodging

7925 NW 154 ST , MIAMI LAKES 33016

Insp Date: 07/18/2025

Inspection Number: 1186593

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310045

GARDENS OF HOMESTEAD

License Type: Lodging

110 NE 10 ST , HOMESTEAD 33030

Insp Date: 07/21/2025

Inspection Number: 1637152

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher in between units 108 and 109 in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2329463

DCROSS MANAGEMENT

License Type: Lodging

5445 COLLINS AVENUE UNIT C17 , MIAMI BEACH 33140

Insp Date: 07/23/2025

Inspection Number: 1186179

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. observed fire extinguisher at the lower lobby without breaking device. Extinguisher is located in front of Girasol Apartments office **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312425

MINOR HOLDINGS LLC

License Type: Lodging

2620 NW 22 AVE , MIAMI 33142

Insp Date: 07/25/2025

Inspection Number: 1640457

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher next to unit #102.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2327558

LOEWS MIAMI BCH HOTEL

License Type: Lodging

1601 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 07/22/2025

Inspection Number: 1183990

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329434

GREYSTONE HOTEL

License Type: Lodging

1920 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 07/24/2025

Inspection Number: 1185802

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2329437

SANTA BARBARA HOTEL

License Type: Lodging

230 20 ST , MIAMI BEACH 33139

Insp Date: 07/24/2025

Inspection Number: 1185434

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329447

TOWNEPLACE SUITES MIAMI KENDALL WEST

License Type: Lodging

9055 SW 162 AVE , MIAMI 33196

Insp Date: 07/22/2025

Inspection Number: 1185318

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2305664

CLIFTON HOTEL

License Type: Lodging

1343 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 07/23/2025

Inspection Number: 1185269

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329538

W SOUTH BEACH

License Type: Lodging

2201 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 07/25/2025

Inspection Number: 1185163

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2306976

RAMADA MIAMI AIRPORT

License Type: Lodging

5001 NW 36 ST , MIAMI SPRINGS 33166

Insp Date: 07/21/2025

Inspection Number: 1241694

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330565

IMPERIAL APARTMENTS, LLC

License Type: Lodging

1052 NW 6 ST , MIAMI 33136

Insp Date: 07/24/2025

Inspection Number: 1641768

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only.
Observed Furniture on hallway, second floor.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2325923

HAMPTON INN HOTEL

License Type: Lodging

2800 SW 28 TERR , MIAMI 33713

Insp Date: 07/21/2025

Inspection Number: 1184593

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate expired 5/17/2025.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329277

HILTON CABANA MIAMI BEACH

License Type: Lodging

6261 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 07/21/2025

Inspection Number: 1183991

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL 130895, 142921 and 132922 , 139824 exp 3/31/2025.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2329005

HOTEL AKA BRICKELL

License Type: Lodging

1395 BRICKELL AVE , MIAMI 33131

Insp Date: 07/18/2025

Inspection Number: 1184176

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 3-3-23

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305664

CLIFTON HOTEL

License Type: Lodging

1343 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 07/23/2025

Inspection Number: 1185269

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2304248

DECO MODE HOTEL

License Type: Lodging

411 WASHINGTON AVE , MIAMI BEACH 33139

Insp Date: 07/25/2025

Inspection Number: 1183768

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-07-25: ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310197

141 SW 14 AVE APTS

License Type: Lodging

141 SW 14 AVE , MIAMI 52365

Insp Date: 07/22/2025

Inspection Number: 1599179

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no hammer; unit 15. Observed no hammer; outside elevator 1st floor. Observed no hammer; across unit 3. - From follow-up inspection 2025-07-22: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2329342

COURTNEY REALTY LLC

License Type: Lodging

576 NE 63 ST , MIAMI 33138

Insp Date: 07/22/2025

Inspection Number: 1599298

Insp Type: Complaint Full

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher is in need of recharge at entrance of building first floor. - From follow-up inspection 2025-07-22: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329342

COURTNEY REALTY LLC

License Type: Lodging

576 NE 63 ST , MIAMI 33138

Insp Date: 07/22/2025

Inspection Number: 1599298

Insp Type: Complaint Full

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power. For reporting purposes only. Observed no power at FACP located at back exit door entrance of the building. - From follow-up inspection 2025-07-22: **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Dade

License Number: 2329385

SLS LUX BRICKELL

License Type: Lodging

801 S MIAMI AVE , MIAMI 33130

Insp Date: 07/24/2025

Inspection Number: 1185787

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

08-01-4

Observed boiler certificate expired on 09-27-2024 for FL 135542 and FL 135543. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608324

RED ROOF INN

License Type: Lodging

1063 AIRPORT RD , JACKSONVILLE 32218

Insp Date: 07/22/2025

Inspection Number: 1243981

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Certificate for old boiler expired. Operator stated it was inspected but he never received certificate. New Second unit no longer a boiler. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Highlands

License Number: 3800122

BUDGET INN

License Type: Lodging

2803 US 27 S , SEBRING 33870

Insp Date: 07/18/2025

Inspection Number: 1241126

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-02-4

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only in unit 102.
- From follow-up inspection 2025-07-18: **Time Extended**

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3911434

FAIRFIELD INN & SUITES TAMPA BRANDON

License Type: Lodging

10150 PALM RIVER RD , TAMPA 33619

Insp Date: 07/25/2025

Inspection Number: 1184384

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 122068 8/15/24 122075 8/12/22 **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Lee

License Number: 4605264

HOMEWOOD SUITES BY HILTON BONITA SPRINGS

License Type: Lodging

8901 HIGHLAND WOODS BLVD , BONITA SPRINGS 34135

Insp Date: 07/22/2025

Inspection Number: 1184587

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Monroe

License Number: 5402759

COURTYARD BY MARRIOTT

License Type: Lodging

3031 N ROOSEVELT BLVD , KEY WEST 33040

Insp Date: 07/22/2025

Inspection Number: 1185598

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5400248

BLUE MARLIN MOTEL

License Type: Lodging

1320 SIMONTON ST , KEY WEST 03114

Insp Date: 07/22/2025

Inspection Number: 1243275

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805604

AMALFI APARTMENTS

License Type: Lodging

4860 CYPRESS WOODS DR , ORLANDO 32811

Insp Date: 07/18/2025

Inspection Number: 1644807

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-System Trouble on fire system panel in leasing office

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Orange

License Number: 5811230

MONUMENTAL MOVIELAND HOTEL

License Type: Lodging

6233 INTERNATIONAL DR , ORLANDO 32819

Insp Date: 07/22/2025

Inspection Number: 1186441

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 114 Replaced during inspection **Corrected On-Site**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811129

WYNDHAM GRAND ORLANDO RESORT BONNET CREEK

License Type: Lodging

14651 CHELONIA PKWY , ORLANDO 32821

Insp Date: 07/24/2025

Inspection Number: 1185402

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificates expired 3/13/2025 Spoke to Engineering Manager boiler inspections completed not able to find inspection reports.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Orange

License Number: 5809051

EMBASSY SUITES HOTEL

License Type: Lodging

5835 T G LEE BLVD , ORLANDO 32822

Insp Date: 07/25/2025

Inspection Number: 1184525

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. All 4-11-25 Operator had inspection done previous week **Corrective Action Taken**

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5801552

HOWARD JOHNSON BY WYNDHAM I DRIVE

License Type: Lodging

5858 INTERNATIONAL DR , ORLANDO 32819

Insp Date: 07/21/2025

Inspection Number: 1241357

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

04-03-4

Observation

- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Room 114 and room 112 - From follow-up inspection 2025-07-21: **Time Extended**

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5801552

HOWARD JOHNSON BY WYNDHAM I DRIVE

License Type: Lodging

5858 INTERNATIONAL DR , ORLANDO 32819

Insp Date: 07/21/2025

Inspection Number: 1241357

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

07-04-4

- From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Room 112 between beds. Outlet missing receptacle and cover. Wires exposed. - From follow-up inspection 2025-07-21: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Lodging

7769 W. IRLO BRONSON MEMORIAL HWY. , KISSIMMEE 34747

Insp Date: 07/25/2025

Inspection Number: 1186697

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Multiple boiler certificates expired

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Palm Beach

License Number: 6014061

RESIDENCE INN WEST PALM BEACH DOWNTOWN

License Type: Lodging

455 HIBISCUS ST , WEST PALM BEACH 33401

Insp Date: 07/23/2025

Inspection Number: 1184706

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observe next to room 803

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014061

RESIDENCE INN WEST PALM BEACH DOWNTOWN

License Type: Lodging

455 HIBISCUS ST , WEST PALM BEACH 33401

Insp Date: 07/23/2025

Inspection Number: 1184706

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Pinellas

License Number: 6208876

SAWGRASS APARTMENTS

License Type: Lodging

4150 78TH AVE N , PINELLAS PARK 33781

Insp Date: 07/21/2025

Inspection Number: 1587681

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-06-4

- From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only. Outside of leasing office. Beeping - From follow-up inspection 2025-06-11: **Time Extended** - From follow-up inspection 2025-07-21: **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 07/26/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Seminole

License Number: 6900385

ALTAMONTE SPRINGS HOTEL & SUITES

License Type: Lodging

450 DOUGLAS RD , ALTAMONTE SPRINGS 32714

Insp Date: 07/24/2025

Inspection Number: 1244005

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6902382

CASCADE HEIGHTS

License Type: Lodging

160 ISLANDER CT , LONGWOOD 32750

Insp Date: 07/23/2025

Inspection Number: 1583458

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.- Boiler 140077- Boiler 134183 - From follow-up inspection 2025-07-23: - Boiler 140077 - Boiler 134183
Time Extended

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***St. Lucie**

License Number: 6602527

GERMAN-AMERICAN TRADING & TOURISM

License Type: Lodging

2510 TAMARIND DR , FT PIERCE 34949

Insp Date: 07/22/2025

Inspection Number: 1644814

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

07-02-4

- From initial inspection : Frayed electrical wire(s). For reporting purposes only. Back of building #8 - From follow-up inspection 2025-07-22: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602527

GERMAN-AMERICAN TRADING & TOURISM

License Type: Lodging

2510 TAMARIND DR , FT PIERCE 34949

Insp Date: 07/21/2025

Inspection Number: 1644814

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation CodeObservationViolation Citation

07-02-4

Frayed electrical wire(s). For reporting purposes only. Back of building #8

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406116

HILTON GRDN INN DAYTONA AIRPRT

License Type: Lodging

189 MIDWAY AVE , DAYTONA BCH 32114

Insp Date: 07/25/2025

Inspection Number: 1184088

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-supervisor light,signal light . Per manager on fire watch.Tech is scheduled for 3:30

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Volusia

License Number: 7400500

PERRY'S OCEAN EDGE RESORT

License Type: Lodging

2209 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 07/18/2025

Inspection Number: 1240188

Insp Type: Routine - Lodging

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

07-01-4

- From initial inspection : Damaged electrical wire(s). For reporting purposes only.-wiring to electrical component attached to water heater in south meter/boiler/trash room
- From follow-up inspection 2025-07-18: Time extended
Unable to access on 7/18 **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400746

CHATEAU MAR BEACH RESORT

License Type: Lodging

507 S ATLANTIC AVE , ORMOND BEACH 32176

Insp Date: 07/23/2025

Inspection Number: 1243225

Insp Type: Routine - Lodging

Disposition: Administrative complaint
recommended

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit 204. For reporting purposes only.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 07/26/2025

Walton

License Number: 7601614

ECONO LODGE

License Type: Lodging

90 BUSINESS PARK RD , DEFUNIAK SPRINGS 32435

Insp Date: 07/25/2025

Inspection Number: 1241872

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-03-4

Observation

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.Observed fire extinguisher missing from designated location/holding cabinet between rooms 114 and 115.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.