



Report Date: 08/09/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Alachua**

License Number: 1102962

**AC HOTEL BY MARRIOTT GAINESVILLE**

License Type: Lodging

151 NW 14 ST , GAINESVILLE 32603

Insp Date: 08/08/2025

Inspection Number: 1183983

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed : the three boiler certificates expired on 6-30-2025.136410-136411-136412 all expired. Inspections were done on 6-23-2025 (Inspection reports were provided, waiting on the State to issue the certificates.)Per the manager, the renewals are in the works. \*\*Corrective Action Taken\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1619186

**EXTENDED STAY AMERICA SUITES #9638**

License Type: Lodging

3873 W COMMERCIAL BLVD , TAMARAC 33309

Insp Date: 08/01/2025

Inspection Number: 1244104

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Broward**

License Number: 1607221

**FORT LAUDERDALE GRAND HOTEL**

License Type: Lodging

4900 POWERLINE ROAD , OAKLAND PARK 33309

Insp Date: 08/06/2025

Inspection Number: 1186853

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1607221

**FORT LAUDERDALE GRAND HOTEL**

License Type: Lodging

4900 POWERLINE ROAD , OAKLAND PARK 33309

Insp Date: 08/06/2025

Inspection Number: 1186853

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **\*\*Repeat Violation\*\***

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Collier**

License Number: 2100275

**MOTEL 82**

License Type: Lodging

1700 STATE RD 82 , IMMOKALEE 34142

Insp Date: 08/08/2025

Inspection Number: 1242364

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke alarm missing in room 115.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330256

**735 SW2 LLC**

License Type: Lodging

735 SW 2 ST , MIAMI 33130

Insp Date: 08/04/2025

Inspection Number: 1638631

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329257

**ALOFT MARY BRICKELL**

License Type: Lodging

1001 SW 2 AVE , MIAMI 33130

Insp Date: 08/08/2025

Inspection Number: 1184895

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. Observed 3 199k BTUs tankless units connected to a 200 gallons water storage unit. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Dade**

License Number: 2320150

**CATALINA HOTEL / DORSET HOTEL / MAXINE HOTEL**

License Type: Lodging

1720-1756 COLLINS AVENUE BUILDINGS 1720,1732, 1756, MIAMI BEACH 33139

Insp Date: 08/08/2025

Inspection Number: 1186851

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326957

**CLARION INN 7 SUITES**

License Type: Lodging

5301 NW 36 ST , MIAMI SPRINGS 33166

Insp Date: 08/04/2025

Inspection Number: 1184844

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguishers missing braking devices located by Room 510 and 532 small tower.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Dade**

License Number: 2302132

**MERLIN APTS LLC**

License Type: Lodging

1245 NW 58 ST , MIAMI 33142

Insp Date: 08/08/2025

Inspection Number: 1631769

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-06-4

Observation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher on 2nd floor.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2302718

**1245 NW 60 ST**

License Type: Lodging

1245 NW 60 ST , MIAMI 33142

Insp Date: 08/04/2025

Inspection Number: 1632726

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-06-4

Observation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on both fire extinguisher's on property.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Dade**

License Number: 2323650

**PALMS HOTEL AND SPA**

License Type: Lodging

3025 COLLINS AVE , MIAMI BEACH 04106

Insp Date: 08/04/2025

Inspection Number: 1184014

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed lobby panel with illuminated trouble light.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326957

**CLARION INN 7 SUITES**

License Type: Lodging

5301 NW 36 ST , MIAMI SPRINGS 33166

Insp Date: 08/04/2025

Inspection Number: 1184844

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Dade**

License Number: 2321514

**HOLIDAY INN EXPRESS & SUITES - MIAMI/HIALEAH**

License Type: Lodging

6650 W 20 AVE , HIALEAH 33016

Insp Date: 08/04/2025

Inspection Number: 1185927

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated on the fire alarm control panel at electrical room in second floor.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317485

**SONESTA MIAMI AIRPORT**

License Type: Lodging

950 NW LEJEUNE RD , MIAMI 33126

Insp Date: 08/08/2025

Inspection Number: 1185148

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Dade**

License Number: 2326874      **EXTENDED STAY AMERICA #9639**  
License Type: Lodging      8720 NW 33RD ST , MIAMI 33172

Insp Date: 08/04/2025      Inspection Number: 1185364      Insp Type: Routine - Lodging      Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated on the fire alarm control panel.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2323650      **PALMS HOTEL AND SPA**  
License Type: Lodging      3025 COLLINS AVE , MIAMI BEACH 04106

Insp Date: 08/04/2025      Inspection Number: 1184014      Insp Type: Routine - Lodging      Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Dade**

License Number: 2329419

**LENNOX MIAMI**

License Type: Lodging

1900 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 08/08/2025

Inspection Number: 1185467

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Jurisdiction number 095921 and 095920 both expired on 12-03-2022.  
\*\*Repeat Violation\*\*

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2314619

**LIZ APARTMENT CORP**

License Type: Lodging

134 SW 17 CT , MIAMI 33135

Insp Date: 08/05/2025

Inspection Number: 1596485

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

01-06-4

Observation

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no hammer; unit 3.  
- From follow-up inspection 2025-08-05: \*\*Time Extended\*\*

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Dade**

License Number: 2301886

**GRAND FLAMINGO NORTH TOWER**

License Type: Lodging

1508 BAY RD #1 , MIAMI BEACH 33139

Insp Date: 08/07/2025

Inspection Number: 1595047

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2025-08-07: \*\*Time Extended\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613196

**QUALITY INN OF ORANGE PARK**

License Type: Lodging

6135 YOUNGERMAN CIR , JACKSONVILLE 32244

Insp Date: 08/01/2025

Inspection Number: 1241698

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Portable fire extinguisher missing from location near room #125 and room #107

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



## Division of Hotels &amp; Restaurants

**Fire Observations Reporting**

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE &amp; LODGING ESTABLISHMENTS

**Hillsborough**

License Number: 3914012

**BOULEVARD TOWER 1**

License Type: Lodging

1345 W MAIN ST , TAMPA 33607

Insp Date: 08/05/2025

Inspection Number: 1595597

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

01-01-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. At common area by office. - From follow-up inspection 2025-08-05: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3914055

**BOULEVARD TOWER 2**

License Type: Lodging

1350 W CHESTNUT STREET , TAMPA 33607

Insp Date: 08/05/2025

Inspection Number: 1587884

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. At common area by office. - From follow-up inspection 2025-08-05: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3902228

**COLUMBUS COURT APARTMENTS**

License Type: Lodging

2802 SATELLITE CT , TAMPA 33611

Insp Date: 08/05/2025

Inspection Number: 1584249

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2025-08-05:

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/09/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Monroe**

License Number: 5400316

**LARGO**

License Type: Lodging

101740 OVERSEAS HWY , KEY LARGO 33037

Insp Date: 08/08/2025

Inspection Number: 1244173

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402993

**BATES B & B**

License Type: Lodging

84791 OLD HWY , ISLAMORADA, VLG OF I 33036

Insp Date: 08/05/2025

Inspection Number: 1097094

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

03-01-4

No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only.

Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Monroe**

License Number: 5403191

**CASA MARINA A WALDORF ASTORIA RESORT**

License Type: Lodging

1500 REYNOLDS ST , KEY WEST 33040

Insp Date: 08/05/2025

Inspection Number: 1185621

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603607

**LA QUINTA INN & SUITES**

License Type: Lodging

3 SW MIRACLE STRIP PKWY , FORT WALTON BEACH 86612

Insp Date: 08/04/2025

Inspection Number: 1183826

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only: observed the establishment purchased a new water heating device in late 2022 early 2023. They were not aware that it is a boiler and the requirement for the Boiler Certificate (unit is 499900 BTUs).

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Orange**

License Number: 5809860

**HOMEWOOD SUITES BY HILTON MAITLAND**

License Type: Lodging

290 SOUTHHALL LN , MAITLAND 32751

Insp Date: 08/01/2025

Inspection Number: 1184670

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809417

**EXTENDED STAY AMERICA #1639**

License Type: Lodging

6443 WESTWOOD BLVD , ORLANDO 32821

Insp Date: 08/07/2025

Inspection Number: 1186911

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Orange**

License Number: 5809860

**HOMEWOOD SUITES BY HILTON MAITLAND**

License Type: Lodging

290 SOUTHHALL LN , MAITLAND 32751

Insp Date: 08/04/2025

Inspection Number: 1184670

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2025-08-04: \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6001654

**COLONY PALM BEACH**

License Type: Lodging

155 HAMMON AVE , PALM BEACH 33480

Insp Date: 08/07/2025

Inspection Number: 1186074

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/09/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**St. Lucie**

License Number: 6602529

**TRU BY HILTON PORT ST LUCIE**

License Type: Lodging

11560 SW VILLAGE PKWY , PORT ST LUCIE 34987

Insp Date: 08/05/2025

Inspection Number: 1184712

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Panel reads trouble room 208. \*\*Repeat Violation\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401000

**BEST WESTERN AKU TIKI INN**

License Type: Lodging

2225 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 08/01/2025

Inspection Number: 1244115

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. 1st fl hall east

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400194

**ATLANTIC BREEZE INN**

License Type: Lodging

1215 N ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 08/05/2025

Inspection Number: 1242506

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. -break panel box on wall next to 219 missing breaking device

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





## Division of Hotels &amp; Restaurants

**Fire Observations Reporting**

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE &amp; LODGING ESTABLISHMENTS

**Volusia**

License Number: 7405564

**HAMPTON INN DEBARY**

License Type: Lodging

308 SUNRISE BLVD , DEBARY 32713

Insp Date: 08/04/2025

Inspection Number: 1186819

Insp Type: Complaint Full

Disposition: Call Back - Extension given,  
pendingViolation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2025-08-04: \*\*Time Extended\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405564

**HAMPTON INN DEBARY**

License Type: Lodging

308 SUNRISE BLVD , DEBARY 32713

Insp Date: 08/08/2025

Inspection Number: 1186819

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2025-08-04: \*\*Time Extended\*\* - From follow-up inspection 2025-08-08: \*\*Time Extended\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401501

**MT CARMEL APARTMENTS**

License Type: Lodging

372 N LINCOLN ST , DAYTONA BCH 43088

Insp Date: 08/07/2025

Inspection Number: 1587614

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. Breaker device missing from fire extinguisher box in laundry room. For reporting purposes only. - From follow-up inspection 2025-08-07: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 08/09/2025

**Volusia**

License Number: 7405564

**HAMPTON INN DEBARY**

License Type: Lodging

308 SUNRISE BLVD , DEBARY 32713

Insp Date: 08/01/2025

Inspection Number: 1186819

Insp Type: Complaint Full

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.