



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Brevard**

License Number: 1505700

**MERI PALM BAY**

License Type: Lodging

1880 MOGRA CIRCLE , PALM BAY 32905

Insp Date: 09/10/2025

Inspection Number: 1645263

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

04-07-4

Observation

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. Scheduled to be repaired next week.

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618108

**PALM HAVEN**

License Type: Lodging

500 JEFFERSON DR , DEERFIELD BEACH 33442

Insp Date: 09/08/2025

Inspection Number: 1645246

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Alarm building 18Supervsry AR

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/13/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Clay**

License Number: 2000491

**ALEXANDER POINTE**

License Type: Lodging

2121 BURWICK AVE , ORANGE PARK 32073

Insp Date: 09/10/2025

Inspection Number: 1645282

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet/electrical pole damaged to indicate a malfunction. For reporting purposes only. Community light poles between buildings 26/27,25/24,23/22,17/18,16/17 and 14/15 are leaning. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2102708

**GREAT WOLF LODGE SOUTHWEST FLORIDA**

License Type: Lodging

3900 CITY GATE BLVD N , NAPLES 34117

Insp Date: 09/10/2025

Inspection Number: 1186553

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble alarm on fire panel. Operator stated new speakers being installed for system.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329254

**ROAMI**

License Type: Lodging

1701 SW 2ND AVE , MIAMI 33129

Insp Date: 09/12/2025

Inspection Number: 1185478

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed fire alarm located at pump equipment room

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Dade**

License Number: 2329214

**GRAYSON MIAMI**

License Type: Lodging

1100 BISCAYNE BLVD , MIAMI 33132

Insp Date: 09/05/2025

Inspection Number: 1185213

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329688

**EASYINVEST 4**

License Type: Lodging

136 NE 60 ST , MIAMI 33137

Insp Date: 09/11/2025

Inspection Number: 1644820

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2302407

**UHLENHAUT INC**

License Type: Lodging

265 E 7 ST , HIALEAH 33010

Insp Date: 09/05/2025

Inspection Number: 1645079

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Observed trouble alarm illuminated on the fire alarm control panel.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Dade**

License Number: 2329498

**TRU BY HILTON MIAMI WEST BRICKELL**

License Type: Lodging

1931 SW 3 AVE , MIAMI 33129

Insp Date: 09/05/2025

Inspection Number: 1184618

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed at third floor next to unit 318.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320410

**YES MOTEL**

License Type: Lodging

28475 S DIXIE HWY , HOMESTEAD 33033

Insp Date: 09/08/2025

Inspection Number: 1242982

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed by rooms 38 and 36.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Dade**

License Number: 2329200

**OCEAN REEF HOTEL**

License Type: Lodging

1130 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 09/11/2025

Inspection Number: 1185769

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304612

**SOUTH BEACH HOTEL**

License Type: Lodging

236 21 ST , MIAMI BEACH 33139

Insp Date: 09/09/2025

Inspection Number: 1184854

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Dade**

License Number: 2328390

**SAGAMORE MIAMI BEACH**

License Type: Lodging

1671 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 09/11/2025

Inspection Number: 1184195

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329373

**HAMPTON INN MIAMI AIRPORT EAST**

License Type: Lodging

3449 NW 42 AVE , MIAMI 33142

Insp Date: 09/12/2025

Inspection Number: 1184393

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Dade**

License Number: 2329295

**BOULAN HOTEL**

License Type: Lodging

220 21 ST , MIAMI BEACH 33139

Insp Date: 09/09/2025

Inspection Number: 1184458

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329303

**1 HOTEL SOUTH BEACH**

License Type: Lodging

2341 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 09/12/2025

Inspection Number: 1185309

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Dade**

License Number: 2312664

**13380 PORT SAID RD. APARTMENTS**

License Type: Lodging

13380 PORT SAID RD , OPA LOCKA 44895

Insp Date: 09/10/2025

Inspection Number: 1641292

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

06-06-4

Door marked as an exit locked with a lock that requires a key. For reporting purposes only. Backyard gate closed with padlock.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328390

**SAGAMORE MIAMI BEACH**

License Type: Lodging

1671 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 09/11/2025

Inspection Number: 1184195

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed the boiler certificate expired 09-07-2025.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Report Date: 09/13/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2329527

**GALE MIAMI HOTEL AND RESIDENCES**

License Type: Lodging

601 NE 1 AVE , MIAMI 33132

Insp Date: 09/10/2025

Inspection Number: 1185566

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2300489

**GENESIS PROPERTY INVESTMENTS**

License Type: Lodging

1442 SW 3 ST , MIAMI 33135

Insp Date: 09/05/2025

Inspection Number: 1644846

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

01-02-4

Observation

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.By unit 5. - From follow-up inspection 2025-08-29: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.By unit 5. **\*\*Time Extended\*\*** - From follow-up inspection 2025-09-05: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.By unit 5 **\*\*Time Extended\*\***

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/13/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**DeSoto**

License Number:

**OAK TREE HOTEL**

License Type: Lodging

6 WEST OAK ST STE 6 , ARCADIA 63912

Insp Date: 09/05/2025

Inspection Number: 1097248

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Observed: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.Observed two fire extinguishers, one by front desk and one by the front entrance.Priority: Reporting

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/13/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Duval**

License Number: 2613244

**MEZZA**

License Type: Lodging

11701 PALM LAKE DR , JACKSONVILLE 32218

Insp Date: 09/08/2025

Inspection Number: 1642696

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. In office, fire panel flashing trouble message.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2603661

**BAYMONT BY WYNDHAM JACKSONVILLE AIRPORT**

License Type: Lodging

1153 AIRPORT RD , JACKSONVILLE 32218

Insp Date: 09/10/2025

Inspection Number: 1241641

Insp Type: Complaint Full

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. In room 203, hearing impaired smoke detector does not activate when test button pushed. **\*\*Warning\*\*** - From follow-up inspection 2025-09-10: Room 203 occupied at time of callback. Manager stated occupants are checking out tomorrow. Inspector will return tomorrow, do not rent room until it has been inspected. **\*\*Time Extended\*\***

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/13/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Escambia**

License Number: 2705805

**COURTYARD BY MARRIOTT DOWNTOWN PENSACOLA**

License Type: Lodging

700 E CHASE ST , PENSACOLA 32502

Insp Date: 09/12/2025

Inspection Number: 1185274

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expired boiler certificates 3-10-25 and 3-10-25. Operator stated they have had an inspection but not yet received their updated certificate from the state.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3200101

**LAKEPORT HUNTING & FISHING LODGE**

License Type: Lodging

1077 LAKEPORT PLAZA , LAKEPORT 33471

Insp Date: 09/05/2025

Inspection Number: 1243004

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only: between units 107 and 106, also at unit 126 **\*\*Repeat Violation\*\*** - From follow-up inspection 2025-09-05: Operator has contacted them to recharge but it has not been recharged. **\*\*Time Extended\*\*** **\*\*Corrective Action Taken\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Hillsborough**

License Number: 3905679

**WESTSHORE GRAND**

License Type: Lodging

4860 W KENNEDY BLVD , TAMPA 33609

Insp Date: 09/11/2025

Inspection Number: 1184150

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-01-4

Observation

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4100202

**OCEAN BREEZE INN VERO BEACH**

License Type: Lodging

3384 OCEAN DR , VERO BEACH 32963

Insp Date: 09/05/2025

Inspection Number: 1243277

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-07-4

Observation

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. System trouble alerted- battery charger trouble

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/13/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Monroe**

License Number: 5400696

**HAWKS CAY RESORT**

License Type: Lodging

61 HAWKS CAY BLVD , DUCK KEY 33050

Insp Date: 09/10/2025

Inspection Number: 1184155

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5400075

**ANGLER (BLDG 1), ATLANTIC SUNRISE (BLDG 2), MIRAMAR (BLDG 3)**

License Type: Lodging

84001 OVERSEAS HWY , ISLAMORADA 33036

Insp Date: 09/05/2025

Inspection Number: 1242374

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Monroe**

License Number: 5400007

**THREE WATERS RESORT MARINA - SCARLET CORAL COTTAGES**

License Type: Lodging

84001 OVERSEAS HWY , ISLAMORADA 33036

Insp Date: 09/05/2025

Inspection Number: 1242325

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5400679

**THREE WATERS RESORT MARINA - ISLA (B4), WINDLEY (B5)**

License Type: Lodging

84001 OVERSEAS HWY , ISLAMORADA 33036

Insp Date: 09/05/2025

Inspection Number: 1243376

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Monroe**

License Number: 5400696

**HAWKS CAY RESORT**

License Type: Lodging

61 HAWKS CAY BLVD , DUCK KEY 33050

Insp Date: 09/10/2025

Inspection Number: 1184155

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810505

**DEBRA METROWEST**

License Type: Lodging

2450 LAKE DEBRA DR , ORLANDO 32835

Insp Date: 09/11/2025

Inspection Number: 1636691

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-panel in lobby

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Orange**

License Number: 5810943

**ESTATES AT PARK AVENUE**

License Type: Lodging

2801 BILTMORE PARK DR , ORLANDO 32835

Insp Date: 09/11/2025

Inspection Number: 1643330

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-panel in main lobby at front door

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810516

**COUNTRY INN & SUITES ORLANDO AIRPORT**

License Type: Lodging

5440 FORBES PL , ORLANDO 32812

Insp Date: 09/05/2025

Inspection Number: 1184603

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.(#133807 #133808#131555 expired 4-10-2025)

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Pinellas**

License Number: 6215803

**OPAL SANDS RESORT**

License Type: Lodging

430 S GULFVIEW BLVD , CLEARWATER 33767

Insp Date: 09/09/2025

Inspection Number: 1184477

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215810

**FAIRFIELD INN AND SUITES BY MARRIOTT**

License Type: Lodging

650 BAY ESPLANADE , CLEARWATER BEACH 33767

Insp Date: 09/11/2025

Inspection Number: 1184216

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/13/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Pinellas**

License Number: 6215851

**HIATUS CLEARWATER**

License Type: Lodging

385 S GULFVIEW BLVD , CLEARWATER 33767

Insp Date: 09/11/2025

Inspection Number: 1186215

Insp Type: Routine - Lodging

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Fl 136340, fl 136336, fl 136339, expired 4/3/2025

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6804748

**SLEEP INN**

License Type: Lodging

900 UNIVERSITY PKWY , SARASOTA 34234

Insp Date: 09/10/2025

Inspection Number: 1184903

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed the front desk extinguisher in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



## Division of Hotels &amp; Restaurants

**Fire Observations Reporting***FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Seminole**

License Number: 6903392

**COURTYARD LAKE MARY**

License Type: Lodging

135 INTERNATIONAL PKWY , LAKE MARY 32746

Insp Date: 09/05/2025

Inspection Number: 1185573

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406604

**RCH REALTY LLC**

License Type: Lodging

805 LOUISVILLE STREET , PORT ORANGE 32129

Insp Date: 09/12/2025

Inspection Number: 1629599

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.-breaking device missing from chain at glass panel box behind front building -breaking device missing from unit on backside id 2nd building-breaking device missing from unit on wall next to door to 8

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406606

**VIRGIL AND ELLEN ROSENFELD FAMILY TRUST**

License Type: Lodging

419 N WILD OLIVE AVE , DAYTONA BEACH 32118

Insp Date: 09/12/2025

Inspection Number: 1627419

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation CodeObservationViolation Citation

06-01-4

Path to fire escape exit is blocked. For reporting purposes only.-stairway obstructed by large refrigerator on steps

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Volusia**

License Number: 7401632

**HOLIDAY INN RESORT DAYTONA BEACH OCEAN FRONT**

License Type: Lodging

1615 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 09/10/2025

Inspection Number: 1242137

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405753

**ECONO LODGE**

License Type: Lodging

1614 N US 1 , ORMOND BEACH 32174

Insp Date: 09/05/2025

Inspection Number: 1241798

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet detached from wall. For reporting purposes only.-room 147.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 09/13/2025

**Volusia**

License Number: 7406520

**EXTENDED STAY AMERICA #9512**

License Type: Lodging

275 INTERCHANGE BLVD , ORMOND BEACH 32174

Insp Date: 09/09/2025

Inspection Number: 1186023

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406367

**100 CAROLINA LAKE DRIVE FL OWNER LLC**

License Type: Lodging

100 CAROLINA LAKE DR , DAYTONA BEACH 32114

Insp Date: 09/11/2025

Inspection Number: 1597959

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-03-4

- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.-132-206 detector beeping. - From follow-up inspection 2025-08-11: Currently occupied Per maintenance has been repaired \*\*Time Extended\*\*  
- From follow-up inspection 2025-09-11: Currently occupied \*\*Time Extended\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.