



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Alachua

License Number: 1102967

STAYBRIDGE SUITES/HOLIDAY INN EXPRESS

License Type: Lodging

3370 SW 42ND ST , GAINESVILLE 32608

Insp Date: 09/22/2025

Inspection Number: 1185171

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed the Fire extinguisher in laundry is not fully charged.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1303765

HOLIDAY INN SUNSPREE

License Type: Lodging

11127 W FRONT BCH RD , PANAMA CITY BCH 73529

Insp Date: 09/24/2025

Inspection Number: 1243665

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/27/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1619591

COMFORT INN

License Type: Lodging

3551 W COMMERCIAL BLVD , FORT LAUDERDALE 33309

Insp Date: 09/24/2025

Inspection Number: 1184759

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620651

FALL AT MARINA BAY APARTMENTS

License Type: Lodging

2600 MARINA BAY DR EAST , FORT LAUDERDALE 33312

Insp Date: 09/26/2025

Inspection Number: 1641323

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 4-103

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620651

FALL AT MARINA BAY APARTMENTS

License Type: Lodging

2600 MARINA BAY DR EAST , FORT LAUDERDALE 33312

Insp Date: 09/26/2025

Inspection Number: 1641323

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Outside stairwell near 4-110 First floor lobby 5-107

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Broward

License Number: 1603868

FLOYD AFFORDABLE RENTALS

License Type: Lodging

915 NW 5 ST , FORT LAUDERDALE 33311

Insp Date: 09/26/2025

Inspection Number: 1634844

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed two (2) missing, by Units# 5 & 4.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1800016

FLAMINGO MOTEL & APTS

License Type: Lodging

12420 TAMIAMI TRL , PUNTA GORDA 52401

Insp Date: 09/26/2025

Inspection Number: 1625094

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Observed no smoke detector at unit 8. Operator in the process of installing it.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/27/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Collier

License Number: 2100275

MOTEL 82

License Type: Lodging

1700 STATE RD 82 , IMMOKALEE 34142

Insp Date: 09/24/2025

Inspection Number: 1242364

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-03-4

- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke alarm missing in room 115. - From follow-up inspection 2025-09-24: Observed smoke detector missing in room 115. **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329375

RESIDENCE INN BY MARRIOTT (SUNNY ISLES)

License Type: Lodging

17700 COLLINS AVENUE , SUNNY ISLES 33160

Insp Date: 09/22/2025

Inspection Number: 1184911

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329486

ESMÈ MIAMI BEACH

License Type: Lodging

1434-1438 WASHINGTON AVE , MIAMI BEACH 33139

Insp Date: 09/24/2025

Inspection Number: 1185813

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 09/27/2025

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329428

VENEZIA AT MINE

License Type: Lodging

3865 INDIAN CREEK DR , MIAMI BEACH 33140

Insp Date: 09/24/2025

Inspection Number: 1186244

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. As per person in charge, there is a scheduled fire inspection next week.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331384

AVIDA

License Type: Lodging

19401 W DIXIE HWY , AVENTURA 33180

Insp Date: 09/23/2025

Inspection Number: 1622826

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331386

MAGNUS BRICKELL

License Type: Lodging

201 SW 10 ST , MIAMI 33130

Insp Date: 09/25/2025

Inspection Number: 1645135

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2331386

MAGNUS BRICKELL

License Type: Lodging

201 SW 10 ST , MIAMI 33130

Insp Date: 09/25/2025

Inspection Number: 1645135

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329526

BLU VACATION RENTAL

License Type: Lodging

5445 COLLINS AVE CU20 , MIAMI BEACH 33140

Insp Date: 09/25/2025

Inspection Number: 1185098

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-01-4

Observation

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. ort has been provided electronically as requested by the person in charge at the time of inspection.Observed fire extinguisher located at the side of the office with no means of access, no breaking device. **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2305718

UNIQUE MOTEL

License Type: Lodging

511-555 E OKEECHOBEE RD , HIALEAH 33010

Insp Date: 09/24/2025

Inspection Number: 1243320

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed fire extinguishers next to rooms 203, 209 and and ne t had been tapped making it unable to access. Operator removed the tapes. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329526

BLU VACATION RENTAL

License Type: Lodging

5445 COLLINS AVE CU20 , MIAMI BEACH 33140

Insp Date: 09/25/2025

Inspection Number: 1185098

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2300246

RALGO 3 APTS LLC

License Type: Lodging

6437 WEST FLAGLER ST , MIAMI 33144

Insp Date: 09/26/2025

Inspection Number: 1635565

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed on first floor across from unit #4.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328934

RESIDENCE INN AT AVENTURA MALL

License Type: Lodging

19900 W COUNTRY CLUB DR , AVENTURA 33180

Insp Date: 09/24/2025

Inspection Number: 1186090

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2305549

PLYMOUTH HOTEL

License Type: Lodging

336 21 ST , MIAMI BEACH 33139

Insp Date: 09/23/2025

Inspection Number: 1184473

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329270

GRAND BEACH HOTEL SURFSIDE

License Type: Lodging

9449 COLLINS AVE , SURFSIDE 33154

Insp Date: 09/23/2025

Inspection Number: 1184207

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2301413

CASA MATANZA

License Type: Lodging

506 ESPANOLA WAY , MIAMI BEACH 33139

Insp Date: 09/24/2025

Inspection Number: 1184987

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328942

FOUR SEASONS HOTEL MIAMI

License Type: Lodging

1435 BRICKELL AVE , MIAMI 33131

Insp Date: 09/19/2025

Inspection Number: 1184102

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2329331

RESIDENCE INN MIAMI BEACH SURFSIDE

License Type: Lodging

9200 COLLINS AVE , SURFSIDE 33154

Insp Date: 09/19/2025

Inspection Number: 1183964

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329509

FOUND HOTEL MIAMI BEACH

License Type: Lodging

2925 INDIAN CREEK DR , MIAMI BEACH 33140

Insp Date: 09/19/2025

Inspection Number: 1185578

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on in the panel located behind the front desk.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2329514

SONDER HOSPITALITY USA INC

License Type: Lodging

2925 INDIAN CREEK DR , MIAMI BEACH 33140

Insp Date: 09/19/2025

Inspection Number: 1186344

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329293

6345 ACTIVATE MB LLC

License Type: Lodging

6345 COLLINS AVE , MIAMI BEACH 33141

Insp Date: 09/26/2025

Inspection Number: 1184123

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2329896

MELODY TOWER

License Type: Lodging

245 NE 14 ST MANAGEMENT OFFICE , MIAMI 33132

Insp Date: 09/24/2025

Inspection Number: 1633483

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329388

MONTE CARLO

License Type: Lodging

6551 COLLINS AVE STE 100 , MIAMI BEACH 33141

Insp Date: 09/24/2025

Inspection Number: 1186141

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2329062

CALUSA COVE

License Type: Lodging

8000 SW 210 ST , MIAMI 33189

Insp Date: 09/19/2025

Inspection Number: 1642837

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-07-4

Observation

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. Observed fire alarm paneling showing the system trouble and system silence is triggered.

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329270

GRAND BEACH HOTEL SURFSIDE

License Type: Lodging

9449 COLLINS AVE , SURFSIDE 33154

Insp Date: 09/23/2025

Inspection Number: 1184207

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-04-4

Observation

Boiler certificate not posted in the boiler room. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2329293

6345 ACTIVATE MB LLC

License Type: Lodging

6345 COLLINS AVE , MIAMI BEACH 33141

Insp Date: 09/26/2025

Inspection Number: 1184123

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-04-4

Observation

Boiler certificate not posted in the boiler room. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310740

BISCAYNE GARDENS APTS

License Type: Lodging

15555 NW 2 AVE , MIAMI 96783

Insp Date: 09/22/2025

Inspection Number: 1592270

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

01-01-4

Observation

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By apartment 102. - From follow-up inspection 2025-09-22: Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By apartment 102. **Time Extended**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2310740

BISCAYNE GARDENS APTS

License Type: Lodging

15555 NW 2 AVE , MIAMI 96783

Insp Date: 09/22/2025

Inspection Number: 1592270

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By apartment 105.
- From follow-up inspection 2025-09-22: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By apartment 105. **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2302263

430 SW 3RD ST APARTMENTS

License Type: Lodging

430 SW 3 ST , MIAMI 33130

Insp Date: 09/25/2025

Inspection Number: 1634130

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed missing fire extinguisher on first level at building 436.
- From follow-up inspection 2025-09-25: Observed missing fire extinguisher on first level at building 436.
Time Extended

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Dade

License Number: 2304248

DECO MODE HOTEL

License Type: Lodging

411 WASHINGTON AVE , MIAMI BEACH 33139

Insp Date: 09/26/2025

Inspection Number: 1185483

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-09-26: ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608252

RED ROOF INN

License Type: Lodging

6099 YOUNGERMAN CIR , JACKSONVILLE 32244

Insp Date: 09/19/2025

Inspection Number: 1243314

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Portable fire extinguishers missing from red boxes near unit #137 and #111. ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608182

KNIGHTS INN

License Type: Lodging

8285 DIX ELLIS TRAIL , JACKSONVILLE 32256

Insp Date: 09/22/2025

Inspection Number: 1243831

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by 313 in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Duval

License Number: 2613267

EXTENDED STAY AMERICA SELECT SUITES

License Type: Lodging

10520 BALMORAL CIR W , JACKSONVILLE 32218

Insp Date: 09/22/2025

Inspection Number: 1184420

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. At front desk area, trouble light lite on fire alarm control panel, FS Trouble on screen.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613193

FAIRFIELD INN & SUITES

License Type: Lodging

1616 1 ST N , JACKSONVILLE BEACH 32250

Insp Date: 09/26/2025

Inspection Number: 1185039

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed Boiler certificate expired Jurisdiction #140596-expiration date 5-11-2025, Jurisdiction #140595-expiration date 5-11-2025

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Duval

License Number: 2607032

PEOPLES CHOICE APARTMENTS

License Type: Lodging

1661 RYAR RD , JACKSONVILLE 32216

Insp Date: 09/19/2025

Inspection Number: 1645374

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

01-02-4

Observation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by 1661 in recharge zone.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Escambia

License Number: 2705810

SOLE' INN AND SUITES

License Type: Lodging

200 N PALAFOX STREET , PENSACOLA 32502

Insp Date: 09/26/2025

Inspection Number: 1184665

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate provided was expired. Jan 2010.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2705427

RESIDENCE INN PENSACOLA DOWNTOWN

License Type: Lodging

601 E CHASE ST , PENSACOLA 32502

Insp Date: 09/26/2025

Inspection Number: 1184298

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Certificate expired 3-9 -2023.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Gilchrist

License Number: 3100004

CADILLAC MOTEL

License Type: Lodging

7490 N HWY 19 , FANNING SPRINGS 32693

Insp Date: 09/22/2025

Inspection Number: 1241907

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Smoke detector missing inside room #129.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3600462

HOLIDAY INN EXPRESS HOTEL & SUITES

License Type: Lodging

1024 W SUGARLAND HWY , CLEWISTON 33440

Insp Date: 09/19/2025

Inspection Number: 1185834

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Jurisdiction FL136106 7/12/25

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Highlands

License Number: 3800040

JACARANDA HOTEL

License Type: Lodging

19 E MAIN ST , AVON PARK 53942

Insp Date: 09/23/2025

Inspection Number: 1185770

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only in laundry room. Operator has called for repair. **Corrective Action Taken**

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800996

ROANOKE HOTEL

License Type: Lodging

211 CIR PARK DR , SEBRING 33870

Insp Date: 09/24/2025

Inspection Number: 1185147

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Highlands

License Number: 3800040

JACARANDA HOTEL

License Type: Lodging

19 E MAIN ST , AVON PARK 53942

Insp Date: 09/23/2025

Inspection Number: 1185770

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Jurisdiction 097865 3/22/25, 057118 3/22/25 Operator called State Fire and they will send the most current report. **Corrective Action Taken** **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913635

HAMPTON INN BY HILTON TAMPA FAIRGROUNDS CASINO

License Type: Lodging

4506 OAK FAIR BLVD , TAMPA 33610

Insp Date: 09/26/2025

Inspection Number: 1185954

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

06-02-4

Door marked as an exit is blocked. For reporting purposes only. Observed exit door inside of laundry room blocked by trash wheelbarrow. Employee removed. **Corrected On-Site**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Orange**

License Number: 5810160

DISNEY'S ANIMAL KINGDOM LODGE

License Type: Lodging

2901 OSCEOLA PKWY , BAY LAKE 32830

Insp Date: 09/22/2025

Inspection Number: 1187505

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificates or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2025-09-22: ****Time Extended****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811119

ARIUM CROWNTREE LAKES

License Type: Lodging

5759 CROWNTREE LN , ORLANDO 32829

Insp Date: 09/20/2025

Inspection Number: 1631592

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2025-09-20: ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Orange

License Number: 5811119

ARIUM CROWNTREE LAKES

License Type: Lodging

5759 CROWNTREE LN , ORLANDO 32829

Insp Date: 09/19/2025

Inspection Number: 1631592

Insp Type: Routine - Lodging

Disposition: Administrative complaint
recommended

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6006372

BOCA COLONY

License Type: Lodging

6061 BOCA COLONY DR , BOCA RATON 33433

Insp Date: 09/26/2025

Inspection Number: 1630646

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.Outside of unit 311Outside of unit 214	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6216043

GULL HARBOR APARTMENTS

License Type: Lodging

17105 GULF BLVD , NORTH REDINGTON BEAC 33708

Insp Date: 09/22/2025

Inspection Number: 1645362

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Active alarm observed on FACP in laundry room	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Santa Rosa

License Number: 6700064

BREEZE APARTMENTS

License Type: Lodging

75 NIGHTINGALE LN , GULF BREEZE 32561

Insp Date: 09/23/2025

Inspection Number: 1645391

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

01-02-4

Observation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Apartment 112-111Apartment 110-09

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Seminole

License Number: 6900416

GOLDELM AT CHARTER POINTE APARTMENTS

License Type: Lodging

919 BALLARD ST , ALTAMONTE SPRINGS 32701

Insp Date: 09/22/2025

Inspection Number: 1645363

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-trouble light and alarm, FACP box by 869C.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6902879

DAYS INN

License Type: Lodging

8245 S US HWY 17-92 , FERN PARK 32730

Insp Date: 09/23/2025

Inspection Number: 1244746

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Volusia

License Number: 7406503

RESIDENCE INN DAYTONA OCEANFRONT

License Type: Lodging

3209 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 09/22/2025

Inspection Number: 1186193

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-slave panel at front entrance

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406503

RESIDENCE INN DAYTONA OCEANFRONT

License Type: Lodging

3209 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 09/22/2025

Inspection Number: 1186193

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.-2 water heaters inside boiler room are 130 gallon capacity tanks. Provided boiler safety bulletin via email.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Volusia

License Number: 7401634

DAYS INN

License Type: Lodging

1608 N US HWY 1 , ORMOND BEACH 32174

Insp Date: 09/22/2025

Inspection Number: 1244721

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.-room 109.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401634

DAYS INN

License Type: Lodging

1608 N US HWY 1 , ORMOND BEACH 32174

Insp Date: 09/22/2025

Inspection Number: 1244721

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.-smoke detector covered with plastic in room 210.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Volusia

License Number: 7406676

GRANDVIEW APARTMENTS

License Type: Lodging

927 N GRAND VIEW AVE , DAYTONA BEACH 32118

Insp Date: 09/23/2025

Inspection Number: 1640838

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.-inside tenant laundry room mounted to wall in back building

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401437

SAN MARINA MOTEL

License Type: Lodging

1001 N ATLANTIC AVE , DAYTONA BCH 83626

Insp Date: 09/24/2025

Inspection Number: 1243184

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.-breaking device missing from break panel box mounted next to 113

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Volusia

License Number: 7406483

DAYTONA BEACH RESIDENCE INN

License Type: Lodging

1725 RICHARD PETTY BLVD , DAYTONA BEACH 32114

Insp Date: 09/25/2025

Inspection Number: 1185895

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-signals silenced

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406512

LOTUS INN & SUITES

License Type: Lodging

505 S ATLANTIC AVE , ORMOND BEACH 32176

Insp Date: 09/23/2025

Inspection Number: 1243784

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 09/27/2025

Volusia

License Number: 7402606

SEAGULL APTS

License Type: Lodging

401 AUBURN DR , DAYTONA BCH 83221

Insp Date: 09/19/2025

Inspection Number: 1637647

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

06-01-4

Path to fire escape exit is obstructed. For reporting purposes only.-table in front of entryway to fire escape from unit 5, location of table obstructs access

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400500

PERRY'S OCEAN EDGE RESORT

License Type: Lodging

2209 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 09/22/2025

Inspection Number: 1240188

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

07-01-4

- From initial inspection : Damaged electrical wire(s). For reporting purposes only.-wiring to electrical component attached to water heater in south meter/boiler/trash room
- From follow-up inspection 2025-07-18: Time extended Unable to access on 7/18 **Time Extended** - From follow-up inspection 2025-09-22: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.