



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Bay**

License Number: 1300392

**EL PINE MOTEL**

License Type: Lodging

8901 FRONT BEACH RD , PANAMA CITY BEACH 32407

Insp Date: 10/03/2025

Inspection Number: 1242170

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-02-4

Observation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside room 6.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618774

**STUDIO 6 CORAL SPRINGS**

License Type: Lodging

5645 N UNIVERSITY DR , CORAL SPRINGS 33067

Insp Date: 10/02/2025

Inspection Number: 1243193

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Broward**

License Number: 1618774

**STUDIO 6 CORAL SPRINGS**

License Type: Lodging

5645 N UNIVERSITY DR , CORAL SPRINGS 33067

Insp Date: 10/02/2025

Inspection Number: 1243193

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620651

**FALL AT MARINA BAY APARTMENTS**

License Type: Lodging

2600 MARINA BAY DR EAST , FORT LAUDERDALE 33312

Insp Date: 09/26/2025

Inspection Number: 1641323

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 4-103

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Broward**

License Number: 1620651

**FALL AT MARINA BAY APARTMENTS**

License Type: Lodging

2600 MARINA BAY DR EAST , FORT LAUDERDALE 33312

Insp Date: 09/26/2025

Inspection Number: 1641323

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Outside stairwell near 4-110 First floor lobby 5-107

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1603868

**FLOYD AFFORDABLE RENTALS**

License Type: Lodging

915 NW 5 ST , FORT LAUDERDALE 33311

Insp Date: 09/26/2025

Inspection Number: 1634844

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed two (2) missing, by Units# 5 & 4.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Charlotte**

License Number: 1800016

**FLAMINGO MOTEL & APTS**

License Type: Lodging

12420 TAMIAMI TRL , PUNTA GORDA 52401

Insp Date: 09/26/2025

Inspection Number: 1625094

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Observed no smoke detector at unit 8. Operator in the process of installing it.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1901156

**HAMPTON INN CRYSTAL RIVER FL**

License Type: Lodging

1103 N SUNCOAST BLVD , CRYSTAL RIVER 95483

Insp Date: 09/29/2025

Inspection Number: 1184404

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Clay**

License Number: 2000955

**INTOWN SUITES**

License Type: Lodging

442 BLANDING BLVD , ORANGE PARK 32073

Insp Date: 10/02/2025

Inspection Number: 1185879

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate expired 8/8/2025.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329470

**HOTEL INDIGO MIAMI BRICKELL / ATWELL SUITES MIAMI  
BRICKELL**

License Type: Lodging

145 SW 11 ST , MIAMI 33130

Insp Date: 09/26/2025

Inspection Number: 1185929

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Dade**

License Number: 2329408

**EVEN MIAMI AIRPORT HOTEL**

License Type: Lodging

3499 NW 25 ST , MIAMI 33142

Insp Date: 10/02/2025

Inspection Number: 1186351

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **\*\*Repeat Violation\*\***

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329418

**CORAL REEF APARTMENTS**

License Type: Lodging

303-305 GALEN DR , KEY BISCAYNE 33149

Insp Date: 09/30/2025

Inspection Number: 1184927

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Dade**

License Number: 2300246

**RALGO 3 APTS LLC**

License Type: Lodging

6437 WEST FLAGLER ST , MIAMI 33144

Insp Date: 09/26/2025

Inspection Number: 1635565

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-06-4

Observation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed on first floor across from unit #4.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310653

**DANIELLE APARTMENTS**

License Type: Lodging

115 E 9 ST , HIALEAH 33010

Insp Date: 09/29/2025

Inspection Number: 1627898

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-06-4

Observation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at first floor next to unit 17.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Dade**

License Number: 2301703

**ISLAND HOUSE**

License Type: Lodging

1428 COLLINS AVE , MIAMI BEACH 94102

Insp Date: 10/03/2025

Inspection Number: 1184087

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329332

**NOVOTEL HOTELS & RESORTS**

License Type: Lodging

1500 SW 1 AVE , MIAMI 33129

Insp Date: 10/03/2025

Inspection Number: 1185103

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Dade**

License Number: 2327515

**EXTENDED STAY AMERICA**

License Type: Lodging

6605 NW 7 ST , MIAMI 33126

Insp Date: 10/03/2025

Inspection Number: 1183917

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2319228

**PULLMAN MIAMI AIRPORT**

License Type: Lodging

5800 BLUE LAGOON DR , MIAMI 33126

Insp Date: 09/30/2025

Inspection Number: 1185973

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Dade**

License Number: 2329293

**6345 ACTIVATE MB LLC**

License Type: Lodging

6345 COLLINS AVE , MIAMI BEACH 33141

Insp Date: 09/26/2025

Inspection Number: 1184123

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329296

**ANDAZ MIAMI BEACH HOTEL**

License Type: Lodging

4041 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 09/29/2025

Inspection Number: 1183937

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed light in trouble in the main panel at the lobby.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Dade**

License Number: 2319228

**PULLMAN MIAMI AIRPORT**

License Type: Lodging

5800 BLUE LAGOON DR , MIAMI 33126

Insp Date: 09/30/2025

Inspection Number: 1185973

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed FL137725, 07/12/25; FL137726, 07/12/25; FL137727, 07/12/25; FL140401, 07/12/25, FL140402, 07/12/25.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329182

**SOLE MIAMI**

License Type: Lodging

17315 COLLINS AVE , SUNNY ISLES BEACH 33160

Insp Date: 09/29/2025

Inspection Number: 1184647

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired for 050014, 050016 & 050015 as of 8/3/25. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Dade**

License Number: 2329293

**6345 ACTIVATE MB LLC**

License Type: Lodging

6345 COLLINS AVE , MIAMI BEACH 33141

Insp Date: 09/26/2025

Inspection Number: 1184123

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329365

**WINGATE BY WYNDHAM MIAMI AIRPORT**

License Type: Lodging

3755 NW 78 AVE , DORAL 33166

Insp Date: 09/30/2025

Inspection Number: 1185397

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2025-09-30: At time of callback inspection observed Trouble/alarm light illuminated on the fire alarm control panel. \*\*Time Extended\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 10/04/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2329524

**ATRIUM HOTEL**

License Type: Lodging

656 E DR , MIAMI SPRINGS 33166

Insp Date: 09/30/2025

Inspection Number: 1185994

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\*** - From follow-up inspection 2025-09-30: At time of callback inspection observed Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Time Extended\*\***

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304248

**DECO MODE HOTEL**

License Type: Lodging

411 WASHINGTON AVE , MIAMI BEACH 33139

Insp Date: 09/26/2025

Inspection Number: 1185483

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\*** - From follow-up inspection 2025-09-26: **\*\*Time Extended\*\***

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Duval**

License Number: 2613628

**GENTLE WOODS VILLAS**

License Type: Lodging

6421 BREEZY OAKS WAY , JACKSONVILLE 32244

Insp Date: 10/02/2025

Inspection Number: 1622954

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Portable fire extinguishers in red recharge zone at 1st floor of building 6511, 1st floor of building 6481, both floors of building 6499, 1st floor of building 6493, both floors of building 6487, 1st floor of building 6475, 2nd floor of building 6457, 1st floor of building 6451, 2nd floor of building 6445, both floors of building 6434 and fire extinguisher next to ac unit left of building 6511.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613628

**GENTLE WOODS VILLAS**

License Type: Lodging

6421 BREEZY OAKS WAY , JACKSONVILLE 32244

Insp Date: 10/02/2025

Inspection Number: 1622954

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Portable fire extinguishers missing from designated area 1st floor of building 6517, 2nd floor of building 6511 and 2nd floor of building 6493.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Duval**

License Number: 2610382

**QUALITY INN JACKSONVILLE SOUTHSIDE**

License Type: Lodging

4580 COLLINS RD , JACKSONVILLE 32244

Insp Date: 10/03/2025

Inspection Number: 1241652

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Portable fire extinguisher in laundry room in red recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608853

**EMBASSY SUITES JACKSONVILLE**

License Type: Lodging

9300 BAYMEADOWS RD , JACKSONVILLE 32256

Insp Date: 10/02/2025

Inspection Number: 1185854

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble light illuminated during inspection. Person in charge states due to smoke detector in one room needs to be repaired.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Duval**

License Number: 2613193

**FAIRFIELD INN & SUITES**

License Type: Lodging

1616 1 ST N , JACKSONVILLE BEACH 32250

Insp Date: 09/26/2025

Inspection Number: 1185039

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed Boiler certificate expired Jurisdiction #140596-expiration date 5-11-2025, Jurisdiction #140595-expiration date 5-11-2025

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612170

**EXTENDED STAY AMERICA**

License Type: Lodging

10020 SKINNER LAKE DR , JACKSONVILLE 32246

Insp Date: 10/01/2025

Inspection Number: 1242504

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Operator unable to provide boiler certificates for both boilers.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Escambia**

License Number: 2705810

**SOLE' INN AND SUITES**

License Type: Lodging

200 N PALAFOX STREET , PENSACOLA 32502

Insp Date: 09/26/2025

Inspection Number: 1184665

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate provided was expired. Jan 2010.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2705427

**RESIDENCE INN PENSACOLA DOWNTOWN**

License Type: Lodging

601 E CHASE ST , PENSACOLA 32502

Insp Date: 09/26/2025

Inspection Number: 1184298

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Certificate expired 3-9 -2023.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Highlands**

License Number: 3800167

**TRAVEL INN OF SEBRING**

License Type: Lodging

5272 US HWY 27 S , SEBRING 33870

Insp Date: 10/02/2025

Inspection Number: 1243327

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Observed in room 5, no smoke detector.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913635

**HAMPTON INN BY HILTON TAMPA FAIRGROUNDS CASINO**

License Type: Lodging

4506 OAK FAIR BLVD , TAMPA 33610

Insp Date: 09/26/2025

Inspection Number: 1185954

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

06-02-4

Door marked as an exit is blocked. For reporting purposes only. Observed exit door inside of laundry room blocked by trash wheelbarrow. Employee removed. \*\*Corrected On-Site\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Indian River**

License Number: 4101329

**VERO BEACH HOTEL & SPA**

License Type: Lodging

3500 OCEAN DRIVE , VERO BEACH 32963

Insp Date: 10/01/2025

Inspection Number: 1185576

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 2nd floor fire extinguisher next to elevator

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4101329

**VERO BEACH HOTEL & SPA**

License Type: Lodging

3500 OCEAN DRIVE , VERO BEACH 32963

Insp Date: 10/01/2025

Inspection Number: 1185576

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Certificates are expired. Director has invoice of work that was completed on boilers. Boilers have been repaired and inspector is scheduled to come and reinspect

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Lee**

License Number: 4605574

**DAYS INN & SUITES**

License Type: Lodging

27991 OAKLAND DR , BONITA SPRINGS 34135

Insp Date: 10/01/2025

Inspection Number: 1184630

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel.FACP panel showing troubleFor reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605264

**HOMEWOOD SUITES BY HILTON BONITA SPRINGS**

License Type: Lodging

8901 HIGHLAND WOODS BLVD , BONITA SPRINGS 34135

Insp Date: 09/29/2025

Inspection Number: 1186652

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 090305 expired 10-23-2021 090304 expired 10-23-2021 \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Lee**

License Number: 4602772

**LA QUINTA INN AND SUITES**

License Type: Lodging

20091 SUMMERLIN RD , FORT MYERS 33908

Insp Date: 09/29/2025

Inspection Number: 1184588

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. 137013 expired 02/10/23, 137014 expired 02/10/23 Educated operator on updating boiler certifications. Establishment has work order in place and in the process of fixing. For reporting purposes only.  
\*\*Corrective Action Taken\*\* \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5200161

**PACKARD III**

License Type: Lodging

2223 NE 2ND STREET , OCALA 34470

Insp Date: 09/29/2025

Inspection Number: 1628149

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher located at the entrance of unit 2223-4.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Marion**

License Number: 5202456

**PACKARD I**

License Type: Lodging

2281 NE 2 ST , OCALA 34470

Insp Date: 09/29/2025

Inspection Number: 1626935

Insp Type: Routine - Lodging

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher located at the laundry room area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5200272

**PACKARD II**

License Type: Lodging

2311 NE 2 ST , OCALA 34470

Insp Date: 09/29/2025

Inspection Number: 1628275

Insp Type: Routine - Lodging

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Extinguisher between unit 26 and 27 missing breaking bar, also near unit 18 and unit 21

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Monroe**

License Number: 5401808

**BUD N MARY'S FISHING MARINA**

License Type: Lodging

79851 OVERSEAS HWY , ISLAMORADA 63812

Insp Date: 09/30/2025

Inspection Number: 1243801

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room1

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811173

**HOME2 SUITES BY HILTON UNIVERSAL**

License Type: Lodging

5910 AMERICAN WAY , ORLANDO 32819

Insp Date: 10/01/2025

Inspection Number: 1184619

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Room 221 , 501, 601 all three hearing smoke detectors with no audio

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Orange**

License Number: 5811173

**HOME2 SUITES BY HILTON UNIVERSAL**

License Type: Lodging

5910 AMERICAN WAY , ORLANDO 32819

Insp Date: 10/01/2025

Inspection Number: 1184619

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL136516,136517 both expired April 28 2025

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810943

**ESTATES AT PARK AVENUE**

License Type: Lodging

2801 BILTMORE PARK DR , ORLANDO 32835

Insp Date: 10/02/2025

Inspection Number: 1645468

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-system panel in main lobby \*\*Repeat Violation\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Palm Beach**

License Number: 6006372

**BOCA COLONY**

License Type: Lodging

6061 BOCA COLONY DR , BOCA RATON 33433

Insp Date: 09/26/2025

Inspection Number: 1630646

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-01-4

Observation

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Outside of unit 311 Outside of unit 214

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 10/04/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Pinellas**

License Number: 6205515

**QUALITY INN**

License Type: Lodging

2595 54 AVE N , ST. PETERSBURG 33714

Insp Date: 10/02/2025

Inspection Number: 1241997

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

02-07-4

Flammable chemicals stored near a source of ignition. For reporting purposes only. Thread sealant stored next to water heaters maintenance room on second floor, East side.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6207416

**RED ROOF INN**

License Type: Lodging

4999 34 ST N , ST. PETERSBURG 33714

Insp Date: 09/29/2025

Inspection Number: 1242200

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher located on 2nd floor, East side corridor in the overcharged zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215570

**HOLIDAY INN HOTEL & SUITES CLEARWATER BEACH**

License Type: Lodging

521 S GULFVIEW BLVD , CLEARWATER BEACH 33767

Insp Date: 09/30/2025

Inspection Number: 1185812

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 10/04/2025

**Volusia**

License Number: 7406502

**HAMPTON INN & SUITES**

License Type: Lodging

20 SUMMIT OAK PL , DELAND 32720

Insp Date: 09/30/2025

Inspection Number: 1185862

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401865

**HYATT PLACE DAYTONA BEACH - OCEANFRONT**

License Type: Lodging

3161 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 09/30/2025

Inspection Number: 1242284

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 10/04/2025

Volusia

License Number: 7406605

COCONUT PALMS APARTMENTS

License Type: Lodging

716 N HALIFAX AVE , DAYTONA BEACH 32118

Insp Date: 10/02/2025

Inspection Number: 1628187

Insp Type: Routine - Lodging

Disposition: Administrative complaint  
recommended

Violation Code

01-06-4

Observation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.-locked glass panel box, device is currently inaccessible jammed behind mounted attachment to structure, next to unit 4

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.