



Report Date: 12/13/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Brevard**

License Number: 1500349

**SURF STUDIO APTS M C**

License Type: Lodging

1801 S ATLANTIC AVE , COCOA BCH 12343

Insp Date: 12/08/2025

Inspection Number: 1243304

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between units 6 and 7

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1500461

**SOUTH BEACH INN**

License Type: Lodging

1701 S ATLANTIC AVE , COCOA BEACH 32931

Insp Date: 12/08/2025

Inspection Number: 1243366

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between units 2 and 3. No breaker bar

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621253

**4145 BY THE SEA**

License Type: Lodging

4145 BOUGAINVILLEA DRIVE , LAUDERDALE BYTHESEA 33308

Insp Date: 12/09/2025

Inspection Number: 1645886

Insp Type: Lodging-Licensing Inspection

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Broward**

License Number: 1620936

**MADISON**

License Type: Lodging

329 MADISON ST , HOLLYWOOD 33019

Insp Date: 12/12/2025

Inspection Number: 1245808

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.No fire extinguisher by 9 on level 2

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620867

**CAMBRIA SUITES FT LAUDERDALE**

License Type: Lodging

141 SW 19 CT , DANIA 33004

Insp Date: 12/08/2025

Inspection Number: 1188774

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Broward**

License Number: 1618777

**ARIUM SUNRISE**

License Type: Lodging

1501 NW 124 TER , SUNRISE 33323

Insp Date: 12/09/2025

Inspection Number: 1624535

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher needs to be recharged at 10-305.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620860

**HOLLYWOOD ALL SUITE**

License Type: Lodging

334 ARIZONA ST , HOLLYWOOD 33019

Insp Date: 12/05/2025

Inspection Number: 1242338

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. It doesn't make sound.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Broward**

License Number: 1620708

**HOLLYWOOD BEACH SUITES HOTEL AND HOTEL**

License Type: Lodging

316 ARIZONA ST , HOLLYWOOD 33019

Insp Date: 12/05/2025

Inspection Number: 1096988

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. It doesn't make sound.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329187

**HILTON GARDEN INN MIAMI AIRPORT WEST**

License Type: Lodging

3550 NW 74 AVE , MIAMI 33122

Insp Date: 12/11/2025

Inspection Number: 1186422

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329385

**SLS LUX BRICKELL**

License Type: Lodging

801 S MIAMI AVE , MIAMI 33130

Insp Date: 12/10/2025

Inspection Number: 1188792

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Dade**

License Number: 2329367

**AC HOTEL MIAMI AVENTURA**

License Type: Lodging

20805 BISCAYNE BLVD , AVENTURA 33180

Insp Date: 12/12/2025

Inspection Number: 1188839

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329385

**SLS LUX BRICKELL**

License Type: Lodging

801 S MIAMI AVE , MIAMI 33130

Insp Date: 12/10/2025

Inspection Number: 1188792

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Dade**

License Number: 2329308

**GATES HOTEL SOUTH BEACH**

License Type: Lodging

2360 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 12/05/2025

Inspection Number: 1188759

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Laundry room 138177, expired on 09-06-2024, In 501-1134 and IN 501-1145 newly installed. 499,999 BTU's water temperature 210&deg;F. Expired on 09-06-2024. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329367

**AC HOTEL MIAMI AVENTURA**

License Type: Lodging

20805 BISCAYNE BLVD , AVENTURA 33180

Insp Date: 12/12/2025

Inspection Number: 1188839

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Dade**

License Number: 2326056

**HYATT PLACE MIAMI AIRPORT-WEST/DORAL**

License Type: Lodging

3655 NW 82 AVE , DORAL 33166

Insp Date: 12/08/2025

Inspection Number: 1186393

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed by Room 301.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329126

**JUNER TRUCK INC**

License Type: Lodging

2101 W 52 ST , HIALEAH 33016

Insp Date: 12/11/2025

Inspection Number: 1639801

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Unit 107.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Dade**

License Number: 2327631

**CAMDEN DORAL**

License Type: Lodging

4790 NW 107TH AVENUE , MIAMI 33178

Insp Date: 12/11/2025

Inspection Number: 1642253

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher next unit 802 at 4762 NW 107th ave building 8 in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2314576

**COUNTRY LODGE**

License Type: Lodging

651 N KROME AVE , FLORIDA CITY 43419

Insp Date: 12/05/2025

Inspection Number: 1243709

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher missing between unit 138 and 137.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Dade**

License Number: 2311339

**ECONO LODGE INN & SUITES**

License Type: Lodging

1223 NE 1ST AVENUE , FLORIDA CITY 33034

Insp Date: 12/05/2025

Inspection Number: 1243247

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device at fire extinguisher between unit 111 and 112. Observed no breaking device at fire extinguisher between unit 105 and 106.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329358

**FOUR POINTS BY SHERATON MIAMI AIRPORT**

License Type: Lodging

3570 NW 74 AVE , MIAMI 33122

Insp Date: 12/12/2025

Inspection Number: 1186635

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Dade**

License Number: 2329183

**COURTYARD BY MARRIOTT MIAMI DOLPHIN MALL**

License Type: Lodging

11275 NW 12 ST , MIAMI 33172

Insp Date: 12/10/2025

Inspection Number: 1186450

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed Boiler certificate expire 03/01/2025, as per chief engineer documents are submitted but state hasn't issue new certificates.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329358

**FOUR POINTS BY SHERATON MIAMI AIRPORT**

License Type: Lodging

3570 NW 74 AVE , MIAMI 33122

Insp Date: 12/12/2025

Inspection Number: 1186635

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed FL 134359, FL 134358 expired 08/09/25

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 12/13/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2330668

**DOWNTOWN VILLAS I**

License Type: Lodging

439 NW 8 ST , MIAMI 33136

Insp Date: 12/09/2025

Inspection Number: 1640803

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By 203 - From follow-up inspection 2025-12-09: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. By 203 \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329470

**HOTEL INDIGO MIAMI BRICKELL / ATWELL SUITES MIAMI BRICKELL**

License Type: Lodging

145 SW 11 ST , MIAMI 33130

Insp Date: 12/08/2025

Inspection Number: 1185929

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Repeat Violation\*\* - From follow-up inspection 2025-12-08: Observed fire alarm testing being conducted at the time of inspection. \*\*Time Extended\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Dade**

License Number: 2329418

**CORAL REEF APARTMENTS**

License Type: Lodging

303-305 GALEN DR , KEY BISCAYNE 33149

Insp Date: 12/12/2025

Inspection Number: 1184927

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

08-03-4

Observation

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2025-12-12: No boiler certificate or insurance inspector's boiler report available.  
\*\*Time Extended\*\*

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Duval**

License Number: 2607905

**SOUTHBANK HOTEL AND CONFERENCE CENTER**

License Type: Lodging

1515 PRUDENTIAL DR , JACKSONVILLE 32207

Insp Date: 12/11/2025

Inspection Number: 1184756

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Expired on 10/4/25

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612691

**INTOWN SUITES**

License Type: Lodging

11451 BEACH BLVD , JACKSONVILLE 32246

Insp Date: 12/10/2025

Inspection Number: 1243897

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.Observed operator unable to provide boiler certificate. Verified jurisdiction # on boiler search website. Jurisdiction #140881 and #136542

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 12/13/2025

Hernando

License Number: 3700048

BUDGET INN

License Type: Lodging

1795 E JEFFERSON ST , BROOKSVILLE 34601

Insp Date: 12/09/2025

Inspection Number: 1241986

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-02-4

Observation

No smoke detector provided in guest room 6. For reporting purposes only.

Violation Citation

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 12/13/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Leon**

License Number: 4700572

**OAKWOOD RESERVE APARTMENTS**

License Type: Lodging

2616 MISSION RD , TALLAHASSEE 32304

Insp Date: 12/10/2025

Inspection Number: 1645948

Insp Type: Complaint Full

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 52 extinguisher in red.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4700572

**OAKWOOD RESERVE APARTMENTS**

License Type: Lodging

2616 MISSION RD , TALLAHASSEE 32304

Insp Date: 12/10/2025

Inspection Number: 1645948

Insp Type: Complaint Full

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from its designated location (sign present indicating designated location). For reporting purposes only. Extinguisher by building 52 is on the ground.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Marion**

License Number: 5202445

**MICROTEL INN & SUITES**

License Type: Lodging

1770 SW 134 ST , OCALA 34473

Insp Date: 12/05/2025

Inspection Number: 1185869

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-02-4

Observation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to exit door in back of lobby.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Monroe**

License Number: 5401577

**BAKER'S CAY RESORT KEY LARGO**

License Type: Lodging

97000 S OVERSEAS HWY , KEY LARGO 33037

Insp Date: 12/10/2025

Inspection Number: 1185771

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5403209

**BUNGALOWS KEY LARGO**

License Type: Lodging

99060 OVERSEAS HWY , KEY LARGO 33037

Insp Date: 12/11/2025

Inspection Number: 1186259

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed sound on alarm not working in room 400.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Nassau**

License Number: 5500967

**SPRINGHILL SUITES AMELIA ISLAND**

License Type: Lodging

2700 ATLANTIC AVE STE 2 , AMELIA ISLAND 32034

Insp Date: 12/10/2025

Inspection Number: 1184938

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificates expired 4/4/2025. Operator stated someone was already out to inspect them and are waiting on the certificates.  
\*\*Corrective Action Taken\*\* \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811179

**COURTYARD LAKE BUENA VISTA**

License Type: Lodging

8501 PALM PKWY , ORLANDO 32836

Insp Date: 12/10/2025

Inspection Number: 1188811

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate expired 8/4/2025 Manager Provided copy of inspection report on 5/30/2025, at time of inspection.  
\*\*Corrective Action Taken\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Orange**

License Number: 5808160

**DISNEY`S BOARDWALK INN**

License Type: Lodging

2101 N EPCOT RESORT BLVD , BAY LAKE 01000

Insp Date: 12/12/2025

Inspection Number: 1186075

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Observed trouble signal on the fire Alarm panel several area displayed on the panel.54North, 48 south 41 Cafe, 35 ESPN Engineering notify. \*\*Corrective Action Taken\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808945

**EXTENDED STAY AMERICA #9636**

License Type: Lodging

4101 EQUITY ROW , ORLANDO 32819

Insp Date: 12/12/2025

Inspection Number: 1185286

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Room 205 FL 2 3FL Elevator

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Orange**

License Number: 5806974

**DASKK HOTELS & RESORTS ORLANDO**

License Type: Lodging

7400 CANADA AVE , ORLANDO 32819

Insp Date: 12/09/2025

Inspection Number: 1184080

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Fire Pump . They are currently using temp pump. - From follow-up inspection 2025-12-09: \*\*Time Extended\*\* - From follow-up inspection 2025-12-09: \*\*Time Extended\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5806974

**DASKK HOTELS & RESORTS ORLANDO**

License Type: Lodging

7400 CANADA AVE , ORLANDO 32819

Insp Date: 12/09/2025

Inspection Number: 1184080

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Fire Pump . They are currently using temp pump. - From follow-up inspection 2025-12-09: \*\*Time Extended\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

---

**Osceola**

License Number: 5912068

**MM LAKE HOTEL LLC**

License Type: Lodging

4944 W IRLO BRONSON MEMORIAL HWY , KISSIMMEE 34746

Insp Date: 12/08/2025

Inspection Number: 1188694

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Per operator, they have an inspection pending for new boiler.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

---

License Number: 6014058

**WYNDHAM GRAND JUPITER AT HARBOURSIDE PLACE**

License Type: Lodging

122 SOUNDINGS AVE , JUPITER 33477

Insp Date: 12/10/2025

Inspection Number: 1185750

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Palm Beach**

License Number: 6004110

**88 PALMS HOTEL AND EVENT CENTER**

License Type: Lodging

1901 PALM BEACH LAKES BLVD. , WEST PALM BEACH 33409

Insp Date: 12/09/2025

Inspection Number: 1243066

Insp Type: Routine - Lodging

Disposition: Call Back - Extension given,  
pending

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.134509 06/27/2025, 111423 06/27/2025, - From follow-up inspection 2025-12-09: \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6004110

**88 PALMS HOTEL AND EVENT CENTER**

License Type: Lodging

1901 PALM BEACH LAKES BLVD. , WEST PALM BEACH 33409

Insp Date: 12/12/2025

Inspection Number: 1243066

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.134509 06/27/2025, 111423 06/27/2025, - From follow-up inspection 2025-12-09: \*\*Time Extended\*\* - From follow-up inspection 2025-12-12: \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Pasco**

License Number: 6102930

**COMFORT INN & SUITES**

License Type: Lodging

6206 US HWY 19 , NEW PORT RICHEY 34652

Insp Date: 12/05/2025

Inspection Number: 1185153

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Impaired smoke detector not working in bathroom of 410

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201176

**RODEWAY INN**

License Type: Lodging

21252 US HWY 19 N , CLEARWATER 33765

Insp Date: 12/09/2025

Inspection Number: 1245717

Insp Type: Complaint Partial

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge in main laundry room . For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Polk**

License Number: 6300029

**ECONOMY SUITES**

License Type: Lodging

1901 CYPRESS GARDENS BLVD , WINTER HAVEN 33884

Insp Date: 12/10/2025

Inspection Number: 1243445

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 23 operating replaced  
\*\*Corrected On-Site\*\*

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6300834

**PRESTLERS MOTEL**

License Type: Lodging

2435 NEW TAMPA HWY , LAKE LAND 33815

Insp Date: 12/09/2025

Inspection Number: 1242536

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 16

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Report Date: 12/13/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Volusia**

License Number: 7406505

**DELAND HOTEL**

License Type: Lodging

442 E NEW YORK AVE. , DELAND 32724

Insp Date: 12/05/2025

Inspection Number: 1185189

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only. Third level platform, . operator cleared pathway. \*\*Corrected On-Site\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400500

**PERRY'S OCEAN EDGE RESORT**

License Type: Lodging

2209 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 12/08/2025

Inspection Number: 1242487

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.- wiring at water heater near vent stack inside water heater/trash room.-engineer added caps to wiring \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406496

**COUNTRY INN AND SUITES**

License Type: Lodging

5802 JOURNEYS END WAY , PORT ORANGE 32127

Insp Date: 12/12/2025

Inspection Number: 1186295

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.-next to 427

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/13/2025

**Volusia**

License Number: 7401777

**HAMPTON INN DAYTONA SHORES - OCEANFRONT**

License Type: Lodging

3135 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 12/09/2025

Inspection Number: 1243390

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406512

**STERLING COURT**

License Type: Lodging

1001 ALABASTER WAY , DELTONA 32725

Insp Date: 12/11/2025

Inspection Number: 1639678

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-operator states alarm company stated it was a phone line issue, operator has contracted a new phone company \*\*Corrective Action Taken\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 12/13/2025

Volusia

License Number: 7401068

**SIDE O SEA MOTEL**

License Type: Lodging

1451 N ATLANTIC AVE , DAYTONA BCH 83501

Insp Date: 12/10/2025

Inspection Number: 1242965

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

07-04-4

Observation

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.-exterior outlet located near sidewalk at south east corner of property near unit 1

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.