



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Bradford**

License Number: 1400009

**MOTEL 6**

License Type: Lodging

1101 N TEMPLE AVE , STARKE 32091

Insp Date: 12/15/2025

Inspection Number: 1243546

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in front of unit 221 in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1607305

**PLAZA HOTEL FORT LAUDERDALE**

License Type: Lodging

5100 N SR 7 , FORT LAUDERDALE 33319

Insp Date: 12/17/2025

Inspection Number: 1188881

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Broward**

License Number: 1615086

**SHERATON SUITES PLANTATION**

License Type: Lodging

311 N UNIVERSITY DR , PLANTATION 33334

Insp Date: 12/17/2025

Inspection Number: 1185326

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate expired on 12/06/2024.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620936

**MADISON**

License Type: Lodging

329 MADISON ST , HOLLYWOOD 33019

Insp Date: 12/12/2025

Inspection Number: 1245808

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.No fire extinguisher by 9 on level 2

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Broward**

License Number: 1615086

**SHERATON SUITES PLANTATION**

License Type: Lodging

311 N UNIVERSITY DR , PLANTATION 33334

Insp Date: 12/18/2025

Inspection Number: 1185326

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate expired on 12/06/2024.  
- From follow-up inspection 2025-12-18: Same. \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1900058

**BELL VILLA MOTEL**

License Type: Lodging

3430 S SUNCOAST BLVD , HOMOSASSA 34448

Insp Date: 12/19/2025

Inspection Number: 1243771

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Dade**

License Number: 2329418

**CORAL REEF APARTMENTS**

License Type: Lodging

303-305 GALEN DR , KEY BISCAYNE 33149

Insp Date: 12/18/2025

Inspection Number: 1188920

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2321990

**QUALITY INN MIAMI AIRPORT**

License Type: Lodging

3959 NW 79 AVE , MIAMI 33166

Insp Date: 12/17/2025

Inspection Number: 1188865

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Dade**

License Number: 2321990

**QUALITY INN MIAMI AIRPORT**

License Type: Lodging

3959 NW 79 AVE , MIAMI 33166

Insp Date: 12/17/2025

Inspection Number: 1188865

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329367

**AC HOTEL MIAMI AVENTURA**

License Type: Lodging

20805 BISCAYNE BLVD , AVENTURA 33180

Insp Date: 12/12/2025

Inspection Number: 1188839

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Dade**

License Number: 2329367

**AC HOTEL MIAMI AVENTURA**

License Type: Lodging

20805 BISCAYNE BLVD , AVENTURA 33180

Insp Date: 12/12/2025

Inspection Number: 1188839

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. \*\*Repeat Violation\*\*

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310536

**ACEVEDO INVESTMENT**

License Type: Lodging

40 W 5 ST , HIALEAH 33010

Insp Date: 12/15/2025

Inspection Number: 1638059

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-06-4

Observation

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to unit 16.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Dade**

License Number: 2329358

**FOUR POINTS BY SHERATON MIAMI AIRPORT**

License Type: Lodging

3570 NW 74 AVE , MIAMI 33122

Insp Date: 12/12/2025

Inspection Number: 1186635

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327881

**STAYBRIDGE SUITES MIAMI/DORAL**

License Type: Lodging

3265 NW 87 AVE , MIAMI 33172

Insp Date: 12/17/2025

Inspection Number: 1186462

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at front desk area.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Dade**

License Number: 2327573

**EXTENDED STAY AMERICA #9641**

License Type: Lodging

101 FAIRWAY DR , MIAMI 33166

Insp Date: 12/15/2025

Inspection Number: 1186848

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed inside Room 104.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329358

**FOUR POINTS BY SHERATON MIAMI AIRPORT**

License Type: Lodging

3570 NW 74 AVE , MIAMI 33122

Insp Date: 12/12/2025

Inspection Number: 1186635

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed FL 134359, FL 134358 expired 08/09/25

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Dade**

License Number: 2327881

**STAYBRIDGE SUITES MIAMI/DORAL**

License Type: Lodging

3265 NW 87 AVE , MIAMI 33172

Insp Date: 12/17/2025

Inspection Number: 1186462

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired on 01/17/2025

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328948

**MOTEL 6 CUTLER BAY**

License Type: Lodging

10775 CARIBBEAN BLVD , CUTLER BAY 33189

Insp Date: 12/19/2025

Inspection Number: 1245086

Insp Type: Complaint Full

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble lights at the front desk. - From follow-up inspection 2025-12-19: Observed trouble lights at the front desk. \*\*Time Extended\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Dade**

License Number: 2328948

**MOTEL 6 CUTLER BAY**

License Type: Lodging

10775 CARIBBEAN BLVD , CUTLER BAY 33189

Insp Date: 12/19/2025

Inspection Number: 1245086

Insp Type: Complaint Full

Disposition: Call Back - Extension given,  
pending

Violation Code

Observation

Violation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed hearing impaired in room 319 no working.  
- From follow-up inspection 2025-12-19: Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed hearing impaired in room 319 no working. \*\*Time Extended\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329476

**IBEROSTAR WAVES MIAMI BEACH**

License Type: Lodging

334 20 ST , MIAMI BEACH 33139

Insp Date: 12/17/2025

Inspection Number: 1185165

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed two boilers that have a max input of 499,999 BTU's. \*\*Repeat Violation\*\* - From follow-up inspection 2025-12-17: No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed two boilers that have a max input of 499,999 BTU's. \*\*Repeat Violation \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Dade**

License Number: 2329418

**CORAL REEF APARTMENTS**

License Type: Lodging

303-305 GALEN DR , KEY BISCAYNE 33149

Insp Date: 12/12/2025

Inspection Number: 1184927

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2025-12-12: No boiler certificate or insurance inspector's boiler report available. \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612598

**EXTENDED STAY AMERICA**

License Type: Lodging

1413 PRUDENTIAL DR , JACKSONVILLE 32207

Insp Date: 12/15/2025

Inspection Number: 1185236

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In laundry room

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Duval**

License Number: 2602643

**SCOTTISH INN**

License Type: Lodging

2300 PHILLIPS HWY , JACKSONVILLE 73548

Insp Date: 12/16/2025

Inspection Number: 1242471

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. In unit 233

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613320

**CANOPY AT BELFORT PARK**

License Type: Lodging

7750 BELFORT PKWY , JACKSONVILLE 32256

Insp Date: 12/17/2025

Inspection Number: 1632334

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by unit 418 in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Duval**

License Number: 2613194

**ECONOMY INN**

License Type: Lodging

3150 PHILLIPS HWY , JACKSONVILLE 32207

Insp Date: 12/16/2025

Inspection Number: 1242803

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. In room 4, called operator to bring one \*\*Corrective Action Taken\*\*

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2700097

**DAYS INN**

License Type: Lodging

710 N PALAFOX ST , PENSACOLA 32501

Insp Date: 12/16/2025

Inspection Number: 1241932

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 133792/06/13/2025

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Marion**

License Number: 5201113

**MOTEL 728**

License Type: Lodging

5035 SE ABSHIER BLVD , BELLEVIEW 34420

Insp Date: 12/18/2025

Inspection Number: 1245878

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only. In unit #1. Unit is currently not being rented. \*\*Warning\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5201113

**MOTEL 728**

License Type: Lodging

5035 SE ABSHIER BLVD , BELLEVIEW 34420

Insp Date: 12/18/2025

Inspection Number: 1245878

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only. Wires hanging from ceiling in unit 1. Unit is not currently being rented out. \*\*Warning\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Marion**

License Number: 5201373

**COURTYARD BY MARRIOTT OCALA**

License Type: Lodging

3712 SW 38TH AVE , OCALA 34474

Insp Date: 12/16/2025

Inspection Number: 1188879

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler jurisdiction 136706 and 136707 expired on 11/09/2025

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5201757

**ROSEMERE FLATS (FKA: NORTHSIDE VILLAS II)**

License Type: Lodging

4248 NW 22ND AVE , OCALA 34475

Insp Date: 12/16/2025

Inspection Number: 1626753

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between units 4421 and 4425.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Monroe**

License Number: 5402143

**REEFHUSE RESORT & MARINA**

License Type: Lodging

103800 OVERSEAS HWY , KEY LARGO 33037

Insp Date: 12/15/2025

Inspection Number: 1184755

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603335

**FAIRFIELD INN & SUITES DESTIN**

License Type: Lodging

19001 EMERALD COAST PKWY , DESTIN 32541

Insp Date: 12/15/2025

Inspection Number: 1184129

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 139406 expired 4-12-23 **\*\*Repeat Violation\*\***

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Orange**

License Number: 5808160

**DISNEY`S BOARDWALK INN**

License Type: Lodging

2101 N EPCOT RESORT BLVD , BAY LAKE 01000

Insp Date: 12/12/2025

Inspection Number: 1186075

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Observed trouble signal on the fire Alarm panel several area displayed on the panel.54North, 48 south 41 Cafe, 35 ESPN Engineering notify. \*\*Corrective Action Taken\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811131

**DRURY INN & SUITES ORLANDO**

License Type: Lodging

7301 W SAND LAKE RD , ORLANDO 32819

Insp Date: 12/18/2025

Inspection Number: 1184541

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Circuit zone 1

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Orange**

License Number: 5808945

**EXTENDED STAY AMERICA #9636**

License Type: Lodging

4101 EQUITY ROW , ORLANDO 32819

Insp Date: 12/12/2025

Inspection Number: 1185286

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Room 205 FL 2 3FL Elevator

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811131

**DRURY INN & SUITES ORLANDO**

License Type: Lodging

7301 W SAND LAKE RD , ORLANDO 32819

Insp Date: 12/18/2025

Inspection Number: 1184541

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.FL124227 and FL 124228 expired 5/23/25 \*\*Repeat Violation\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Osceola**

License Number: 5900682

**SUPER 8 MOTEL MAINGATE**

License Type: Lodging

5875 W IRLO BRONSON HWY , KISSIMMEE 34746

Insp Date: 12/19/2025

Inspection Number: 1245777

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Expired 2023

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900204

**RAMADA PLAZA HOTEL & INN GATEWAY**

License Type: Lodging

7470 HWY 192 W , KISSIMMEE 34747

Insp Date: 12/16/2025

Inspection Number: 1243651

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2025-12-16: \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Palm Beach**

License Number: 6004110

**88 PALMS HOTEL AND EVENT CENTER**

License Type: Lodging

1901 PALM BEACH LAKES BLVD. , WEST PALM BEACH 33409

Insp Date: 12/12/2025

Inspection Number: 1243066

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.134509 06/27/2025, 111423 06/27/2025, - From follow-up inspection 2025-12-09: \*\*Time Extended\*\* - From follow-up inspection 2025-12-12: \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 12/20/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Pinellas**

License Number: 6215689

**HOLIDAY INN EXPRESS CLEARWATER**

License Type: Lodging

2580 GULF TO BAY BLVD , CLEARWATER 33765

Insp Date: 12/18/2025

Inspection Number: 1184130

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested - light not working . For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201769

**SAFETY HARBOR RESORT**

License Type: Lodging

105 N BAYSHORE DR , SAFETY HARBOR 34695

Insp Date: 12/17/2025

Inspection Number: 1188211

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Boilers were inspected by the fire marshal on 10/7/24. Establishment had attempted to get certificate from the state and are being told that they are behind in issuing certificates. - From follow-up inspection 2025-12-17: \*\*Time Extended\*\*

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Polk**

License Number: 6300029

**ECONOMY SUITES**

License Type: Lodging

1901 CYPRESS GARDENS BLVD , WINTER HAVEN 33884

Insp Date: 12/16/2025

Inspection Number: 1245852

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 33 Personal in charge has a spare smoke detector to install. \*\*Corrective Action Taken\*\*

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401547

**TRAVEL INN**

License Type: Lodging

850 S RIDGEWOOD AVE , DAYTONA BEACH 32114

Insp Date: 12/18/2025

Inspection Number: 1245856

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit 119 .For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Volusia**

License Number: 7406496

**COUNTRY INN AND SUITES**

License Type: Lodging

5802 JOURNEYS END WAY , PORT ORANGE 32127

Insp Date: 12/12/2025

Inspection Number: 1186295

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.-next to 427

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406446

**NORTHLAND GRANDEVILLE LLC**

License Type: Lodging

741 SAXON BLVD , ORANGE CITY 32763

Insp Date: 12/17/2025

Inspection Number: 1636416

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

Report Date: 12/20/2025

**Volusia**

License Number: 7406507

**SCOOT INN**

License Type: Lodging

5964 S RIDGEWOOD AVE, , PORT ORANGE 32127

Insp Date: 12/17/2025

Inspection Number: 1243866

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.-unit 10, advised to replace immediately/prior to renting unit

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406506

**ATLANTIC ECONOMY INN**

License Type: Lodging

808 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 12/19/2025

Inspection Number: 1241923

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.-non functional smoke detector inside unit 102, failed to test

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Report Date: 12/20/2025

Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Volusia**

License Number: 7406493

**LAQUINTA INN & SUITES**

License Type: Lodging

1791 DUNLAWTON AVE , PORT ORANGE 74737

Insp Date: 12/18/2025

Inspection Number: 1184235

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-04-4	Fire alarm control panel has no power. For reporting purposes only.-operator stated replacement/repairs ordered from certified fire	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 7400062

**LEGACY DAYTONA SUITES**

License Type: Lodging

209 S RIDGEWOOD AVE , DAYTONA BEACH 32114

Insp Date: 12/18/2025

Inspection Number: 1185731

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-trouble light and general alarm light on - From follow-up inspection 2025-12-18: Per manager called tech	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--