



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Bay**

License Number: 1305475

**WAFFLE HOUSE 1953**

License Type: Food

22913 PANAMA CITY BEACH PKWY , PANAMA CITY BEACH 32413

Insp Date: 12/30/2025

Inspection Number: 3652067

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class extinguisher overcharged.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329123

**RICKY AREPAS AND HOT DOGS**

License Type: Food

414 SW 22 AVE , MIAMI 33135

Insp Date: 12/29/2025

Inspection Number: 1134386

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed kitchen stove no hood attach with a 5 ibs propane tank, in food preparation area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334172

**AMBASSADOR CAFE**

License Type: Food

825 BRICKELL BAY DR , MIAMI 33131

Insp Date: 12/30/2025

Inspection Number: 3674489

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tank in kitchen area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Manatee**

License Number: 5105175

**TACO BELL**

License Type: Food

640 E 10 ST , PALMETTO 34221

Insp Date: 12/30/2025

Inspection Number: 3688175

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Gauge on the fire extinguisher stored on wall next to walk in cooler in the red. (Under changed).  
\*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5100126

**BRADENTON COUNTRY CLUB**

License Type: Food

4646 W 9 AVE , BRADENTON 93993

Insp Date: 12/30/2025

Inspection Number: 3659494

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed no current boiler certificate. \*\*Repeat Violation\*\*

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5105175

**TACO BELL**

License Type: Food

640 E 10 ST , PALMETTO 34221

Insp Date: 12/31/2025

Inspection Number: 3688175

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Gauge on the fire extinguisher stored on wall next to walk in cooler in the red. (Under changed). \*\*Repeat Violation\*\* - From follow-up inspection 2025-12-31: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Marion**

License Number: 5202972

**LAS MARGARITAS MEXICAN RESTAURANT & GALLERY**

License Type: Food

4414 SW COLLEGE RD STE 410 , OCALA 34474

Insp Date: 12/29/2025

Inspection Number: 3666147

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

49-01-4	Flammables stored/debris present in meter room. For reporting purposes only.Two containers of gasoline stored in dry goods storage area. Manager removed both tanks from building. <b>**Corrected On-Site**</b>	Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
---------	---	---

License Number: 5603961

**JIMMY BUFFETT'S MARGARITAVILLE**

License Type: Food

76 HARBOR BLVD , DESTIN 32541

Insp Date: 12/29/2025

Inspection Number: 3687968

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.130215 / 130233 ( 4/11/23 ) <b>**Repeat Violation**</b>	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	--	--

License Number: 5814808

**MR & MRS CRAB KIRKMAN INC**

License Type: Food

3875 S KIRKMAN RD , ORLANDO 32811

Insp Date: 12/29/2025

Inspection Number: 3661396

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.-exit door left side of lobby blocked by table	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Palm Beach**

License Number: 6022970

**AMRIT OCEAN - TULA / AYRE / JEEVI / LALA**

License Type: Food

3100 N OCEAN DR , RIVIERA BEACH 33404

Insp Date: 12/31/2025

Inspection Number: 3688354

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	--

License Number: 7406129

**SICILY PIZZA**

License Type: Food

20 S ATLANTIC AVE STE B , DAYTONA BEACH 32118

Insp Date: 12/29/2025

Inspection Number: 3677984

Insp Type: Routine - Food

Disposition: Emergency order recommended

Violation Code

Observation

Violation Citation

46-04-4	Exit door locked. For reporting purposes only. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--