



Division of Hotels & Restaurants

Report Date: 02/07/2026

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Bay**

License Number: 1305297

**BACK PORCH - BAY**

License Type: Food

16220 FRONT BEACH RD , PANAMA CITY BEACH 32413

Insp Date: 02/04/2026

Inspection Number: 3670343

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher at bar in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305435

**ZOLLO PIZZA**

License Type: Food

14658 FRONT BEACH RD , PANAMA CITY BEACH 32413

Insp Date: 02/04/2026

Inspection Number: 3628612

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Missing fire extinguisher near pizza oven.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 02/07/2026

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Brevard**

License Number: 1551038

**TACO VELOZ**

License Type: Food

1390 US 1 , MALABAR 32950

Insp Date: 02/03/2026

Inspection Number: 1316625

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only. Type K fire extinguisher missing, truck not in operation.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1551038

**TACO VELOZ**

License Type: Food

1390 US 1 , MALABAR 32950

Insp Date: 02/03/2026

Inspection Number: 1316625

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with unserviced hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Hood system last serviced in 2023. Truck not in operation.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Brevard**

License Number: 1506215

**LOCAL KITCHEN & TAP**

License Type: Food

4715 HELEN HAUSER BLVD , TITUSVILLE 32780

Insp Date: 02/04/2026

Inspection Number: 3657170

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.140718 and 140719 expired 11/8/2025 **Repeat Violation**	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

License Number: 1622807

**EL MARIACHI RESTAURANT**

License Type: Food

2149 N UNIVERSITY DR , CORAL SPRINGS 33071

Insp Date: 02/05/2026

Inspection Number: 3675699

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed large propane tank exceed 20 pounds stored in dry storage room.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Broward**

License Number: 1621007

**DWIKEYS SOUSE HOUSE LLC**

License Type: Food

6813 PEMBROKE RD , PEMBROKE PINES 33023

Insp Date: 02/05/2026

Inspection Number: 3650430

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 lb. Capacity propane tanks stored in kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618420

**MIYIS CUBAN CAFE INC**

License Type: Food

1380 S POWERLINE RD , DEERFIELD BEACH 33442

Insp Date: 02/04/2026

Inspection Number: 3668555

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Broward**

License Number: 1626129

**LOS VERDES HALLANDALE**

License Type: Food

144 NE 1 AVE , HALLANDALE 33009

Insp Date: 02/04/2026

Inspection Number: 3665861

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 lb. Propane tank being used in kitchen to fuel a stove.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618401

**COSTA DEL SOL REST**

License Type: Food

5611 JOHNSON ST , HOLLYWOOD 33021

Insp Date: 02/02/2026

Inspection Number: 3652008

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.Exposed capped wires at wall and light fixture in men's restroom.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Clay**

License Number: 2001439

**CHAO KING**

License Type: Food

1910 WELLS RD VC 17 , ORANGE PARK 32073

Insp Date: 02/05/2026

Inspection Number: 3653343

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by flat grill is in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001359

**TUNIS**

License Type: Food

290 BLANDING BLVD , ORANGE PARK 32073

Insp Date: 02/02/2026

Inspection Number: 3654196

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by drive thru window is in the recharge zone. **\*\*Repeat Violation\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001342

**NO-MANCHES**

License Type: Food

174 BLANDING BLVD , ORANGE PARK 32073

Insp Date: 02/02/2026

Inspection Number: 3659109

Insp Type: Routine - Food

Disposition: Emergency order recommended

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher at prep area is in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2333194

**CHABELLA MEXICAN RESTAURANT**

License Type: Food

7910 NW 25 ST STE102 , DORAL 33122

Insp Date: 02/05/2026

Inspection Number: 3691059

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only. Throughout the kitchen area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2333194

**CHABELLA MEXICAN RESTAURANT**

License Type: Food

7910 NW 25 ST STE102 , DORAL 33122

Insp Date: 02/05/2026

Inspection Number: 3691059

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Throughout the kitchen area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334739

**GATES HOTEL SOUTH BEACH**

License Type: Food

2360 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 02/06/2026

Inspection Number: 3691074

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed Laundry room 138177, expired on 09-06-2024, In 501-1134 and IN501-1145 newly installed. 499,999 BTU's water temperature 210&deg;F.Expired on 09-06-2024. **\*\*Repeat Violation\*\***

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2337754

**CREMA GOURMET ESPRESSO BAR**

License Type: Food

11515 S DIXIE HWY , MIAMI 33156

Insp Date: 02/03/2026

Inspection Number: 3658964

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

License Number: 2337171

**SNDWCH MIAMI**

License Type: Food

9420 NW 41 ST #115 , DORAL 33178

Insp Date: 02/06/2026

Inspection Number: 3650793

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed: No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. <b>**Repeat Violation**</b>	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2322952

**OLD LISBON RESTAURANT & BAR**

License Type: Food

1698 SW 22 ST , MIAMI 33145

Insp Date: 02/05/2026

Inspection Number: 3667516

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2338070

**FELICE**

License Type: Food

1450 BRICKELL AVE STE 110 , MIAMI 33131

Insp Date: 02/03/2026

Inspection Number: 3658369

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Food preparation area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615685

**SIERRA GRILLE**

License Type: Food

1021 ATLANTIC BLVD , ATLANTIC BEACH 32233

Insp Date: 02/03/2026

Inspection Number: 3656716

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed Propane tank hooked to black stone grill located in back room.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Duval**

License Number: 2616485

**HONG KONG STATION**

License Type: Food

7534 BEACH BLVD BAY 03 , JACKSONVILLE 32216

Insp Date: 02/03/2026

Inspection Number: 3675143

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Operator using table top fryer with no hood suppression system

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2616120

**CANITINA MAJANO**

License Type: Food

1352 N MAIN ST , JACKSONVILLE 32206

Insp Date: 02/03/2026

Inspection Number: 3667178

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Cooking tacos on flat op grill no hood suppression installed. **\*\*Repeat Violation\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Duval**

License Number: 2611598

**MCDONALD'S**

License Type: Food

10135 SAN JOSE BLVD , JACKSONVILLE 32257

Insp Date: 02/02/2026

Inspection Number: 3594623

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Rear side exit door blocked by equipment. Moved by manager. **\*\*Corrected On-Site\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615220

**WICKED BARLEY BREWING CO**

License Type: Food

4100 BAYMEADOWS RD , JACKSONVILLE 32217

Insp Date: 02/02/2026

Inspection Number: 3654103

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.Boile certificate not posted. ( current).

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Duval**

License Number: 2615874

**COMMUNITY LOAVES**

License Type: Food

1116 EDGEWOOD AVE S , JACKSONVILLE 32205

Insp Date: 02/06/2026

Inspection Number: 3664560

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking Fried egg on flat top no hood suppression system present.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

License Number: 2614886

**STONER'S PIZZA JOINT JACKSONVILLE SOUTHSIDE**

License Type: Food

3837 - 7 SOUTHSIDE BLVD , JACKSONVILLE 32216

Insp Date: 01/30/2026

Inspection Number: 3681015

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back kitchen door blocked with cases of flour bags	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Duval**

License Number: 2613123

**DE REAL TING CAFE**

License Type: Food

128 W ADAMS ST #1 , JACKSONVILLE 32202

Insp Date: 02/06/2026

Inspection Number: 3661707

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In back storage room downstairs, 1 lp tank

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Hillsborough**

License Number: 3917950

**TIJUANA FLATS**

License Type: Food

13009 US HWY 301 , RIVERVIEW 33578

Insp Date: 01/30/2026

Inspection Number: 3667534

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back door blocked with trash can.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

License Number: 3918258

**TRIANA CARIBBEAN SANDWISH SHOP LLC**

License Type: Food

4025 W WATERS AVE STE 115-116 , TAMPA 33614

Insp Date: 02/05/2026

Inspection Number: 3633218

Insp Type: Routine - Food

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Panini press located next to Employee handwash sink in kitchen area not placed beneath hood. - From follow-up inspection 2025-12-11: <b>**Time Extended**</b> - From follow-up inspection 2026-02-05: Panini press located next to Employee handwash sink in kitchen area not placed beneath hood. <b>**Time Extended**</b>	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Lake**

License Number: 4508836

**HUNGRY HOWIE'S #3023**

License Type: Food

1215 SUNRISE PLAZA DRIVE SUITE A, CLERMONT 34714

Insp Date: 01/30/2026

Inspection Number: 3613606

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.-Amerex extinguisher by back door  
**\*\*Repeat Violation\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4650990

**TACOS "EL TIO"**

License Type: Food

3617 PALM BEACH BLVD , FORT MYERS 33916

Insp Date: 02/04/2026

Inspection Number: 1326886

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the food truck. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Lee**

License Number: 4607523

**AROMAS ICE CREAM & BAKERY**

License Type: Food

4316 LEE BLVD UNIT 6 , LEHIGH ACRES 33971

Insp Date: 02/04/2026

Inspection Number: 3675170

Insp Type: Routine - Food

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked, right side door at front marked as exit, with rack of snacks. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4607523

**AROMAS ICE CREAM & BAKERY**

License Type: Food

4316 LEE BLVD UNIT 6 , LEHIGH ACRES 33971

Insp Date: 02/04/2026

Inspection Number: 3675170

Insp Type: Routine - Food

Disposition: Administrative  
recommended

complaint

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. By back door to right side corner.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Manatee**

License Number: 5105939

**BARNYARD**

License Type: Food

624 9 AVE W , BRADENTON 34205

Insp Date: 02/06/2026

Inspection Number: 3676717

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.Observed the back exit door locked.Operator unlocked it. **\*\*Corrected On -Site\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5203184

**2 RIVERS LOCAL BAR**

License Type: Food

20199 E PENNSYLVANIA AVE , DUNNELLON 34431

Insp Date: 02/03/2026

Inspection Number: 3690087

Insp Type: Food-Licensing Inspection

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only.Scorched electrical outlet on ceiling above cookline.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5203121

**DUNKIN DONUTS**

License Type: Food

3980 SW 26 CT SUITE 101 , OCALA 34471

Insp Date: 02/06/2026

Inspection Number: 3639246

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.Fire extinguisher in dining room.Fire extinguisher next to back door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Monroe**

License Number: 5400256

**CAFE/SALT + ASH**

License Type: Food

61 HAWKS CAY BLVD , DUCK KEY 33050

Insp Date: 02/06/2026

Inspection Number: 3663848

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5400256

**CAFE/SALT + ASH**

License Type: Food

61 HAWKS CAY BLVD , DUCK KEY 33050

Insp Date: 02/06/2026

Inspection Number: 3663848

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Monroe**

License Number: 5428290

**ANGLER AND ALE**

License Type: Food

540 DUCK KEY DRIVE , DUCK KEY 03756

Insp Date: 01/30/2026

Inspection Number: 3662773

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5428073

**PILAR BAR**

License Type: Food

61 HAWKS CAY BLVD , DUCK KEY 33050

Insp Date: 02/06/2026

Inspection Number: 3664091

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Monroe**

License Number: 5402749

**BANQUET KITCHEN**

License Type: Food

61 HAWKS CAY BLVD , DUCK KEY 33050

Insp Date: 02/06/2026

Inspection Number: 3663925

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	-----------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

License Number: 5428073

**PILAR BAR**

License Type: Food

61 HAWKS CAY BLVD , DUCK KEY 33050

Insp Date: 02/06/2026

Inspection Number: 3664091

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	-------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Nassau**

License Number: 5500812

**MINI DRUNKEN NOODLE**

License Type: Food

510 S EIGHTH ST , FERNANDINA BEACH 32034

Insp Date: 02/02/2026

Inspection Number: 3690280

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank larger than 2.7lbs located inside building.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

License Number: 5814919

**JUICY BITES**

License Type: Food

12125 APOPKA VINELAND ROAD , ORLANDO 32836

Insp Date: 02/05/2026

Inspection Number: 3654621

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two propane tanks stored inside building in the back dishmachine room.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

License Number: 5815366

**GRILLMASTER**

License Type: Food

2222 OCOEE APOPKA RD SUITE 108 , OCOEE 34761

Insp Date: 02/04/2026

Inspection Number: 3638985

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 tanks in back storage area - From follow-up inspection 2026-02-04: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------



Division of Hotels & Restaurants

Report Date: 02/07/2026

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Osceola**

License Number: 5911496

**LITTLE GREEK FRESH GRILL**

License Type: Food

3222 N JOHN YOUNG PKWY , KISSIMMEE 34741

Insp Date: 02/04/2026

Inspection Number: 3668811

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Exit door blocked by cart and bucket.  
\*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Palm Beach**

License Number: 6023020

**CARDINALS DINING BUILDING**

License Type: Food

4751 MAIN ST , JUPITER 33458

Insp Date: 02/03/2026

Inspection Number: 3674225

Insp Type: Food-Licensing Inspection

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6023020

**CARDINALS DINING BUILDING**

License Type: Food

4751 MAIN ST , JUPITER 33458

Insp Date: 02/05/2026

Inspection Number: 3674225

Insp Type: Food-Licensing Inspection

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2026-02-05: No boiler certificate.. \*\*Time Extended\*\*

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Pinellas**

License Number: 6215932

**CHIPOTLE MEXICAN GRILL #713**

License Type: Food

3700 PARK BLVD , PINELLAS PARK 33781

Insp Date: 02/06/2026

Inspection Number: 3664684

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed red near office

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211373

**CASTILLO'S RESTAURANT**

License Type: Food

1724 N FORT HARRISON AVE , CLEARWATER 33755

Insp Date: 02/05/2026

Inspection Number: 3646799

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone near restrooms . For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Pinellas**

License Number: 6214846

**DOMINOS 5022**

License Type: Food

5830 9 AVE N , ST. PETERSBURG 33710

Insp Date: 02/02/2026

Inspection Number: 3637769

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher near entrance gauge in red zone. For reporting purposes only. **\*\*Repeat Violation\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6213800

**CERTEGY CAFE**

License Type: Food

11601 ROOSEVELT BLVD , ST. PETERSBURG 33716

Insp Date: 02/02/2026

Inspection Number: 3657107

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Pinellas**

License Number: 6213800

**CERTEGY CAFE**

License Type: Food

11601 ROOSEVELT BLVD , ST. PETERSBURG 33716

Insp Date: 02/02/2026

Inspection Number: 3657107

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6308552

**CURRY MANGO**

License Type: Food

6625 SOUTH FLORIDA AVE , LAKELAND 33813

Insp Date: 02/03/2026

Inspection Number: 3680103

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 (5lbs) propane tanks in the kitchen on the floor near the electrical boxes. The tanks was removed. **\*\*Corrected On-Site\*\* \*\*Repeat Violation\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 02/07/2026

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Sarasota**

License Number: 6850665

**KEBS LLC**

License Type: Food

1705 CATTLEMEN RD UNIT 3N , SARASOTA 34232

Insp Date: 02/03/2026

Inspection Number: 1332413

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed no suppression system installed above their fryer.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405703

**NEW CHINA KING**

License Type: Food

1500 BEVILLE RD SUITE 701 , DAYTONA BEACH 32114

Insp Date: 02/05/2026

Inspection Number: 3655566

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Hood over woks making noise . Per manager needs a new belt. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 02/07/2026

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Volusia**

License Number: 7407046

**BRUNOS PIZZA**

License Type: Food

1254 OCEAN SHORE BLVD , ORMOND BEACH 32176

Insp Date: 02/02/2026

Inspection Number: 3664338

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403165

**WENDY'S 1759**

License Type: Food

335 W GRANDA BLVD , ORMOND BEACH 32174

Insp Date: 02/05/2026

Inspection Number: 3662985

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-back exit door blocked by cart. \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Volusia**

License Number: 7406067

**EL TEQUILAS AUTHENTIC MEXICAN RESTAURANT INC**

License Type: Food

1784 S RIDGEWOOD AVE. , SOUTH DAYTONA 32119

Insp Date: 01/30/2026

Inspection Number: 3644547

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Exposed wires outside at the back door, appears to be for door bell	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	-------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

License Number: 7407835

**CONCEITED MUNCHIES**

License Type: Food

556 DR MARY MCLEOD BETHUNE BLVD , DAYTONA BEACH 32114

Insp Date: 02/03/2026

Inspection Number: 3614301

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

49-01-4	Box and mop stored on electric water heater. For reporting purposes only.	Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
---------	---------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

License Number: 7602397

**SANDLOT SPORTS BAR**

License Type: Food

60 SEASCAPE DR , MIRAMAR BEACH 32550

Insp Date: 02/05/2026

Inspection Number: 3659490

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4	Portable fire extinguisher missing from its designated location and stored on floor near ice machine and ware wash area. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	-------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------