



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Brevard

License Number: 1506457

KEKE'S BREAKFAST CAFE

License Type: Food

1523 W NEW HAVEN AVE , WEST MELBOURNE 32904

Insp Date: 02/13/2026

Inspection Number: 3670614

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Type K fire extinguisher in kitchen in recharge zone. Operator has all fire extinguishers serviced in August of 2025, service company contacted will be out to replace. ****Corrective Action Taken****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506472

TINY TURTLE

License Type: Food

249 MINUTEMEN CSWY STE R , COCOA BEACH 32931

Insp Date: 02/19/2026

Inspection Number: 3652238

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to hand wash sink in kitchen

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 02/21/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1623857

BURGERFI

License Type: Food

15910 PINES BLVD , PEMBROKE PINES 33027

Insp Date: 02/18/2026

Inspection Number: 3691654

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.Observed on fire extinguisher at kitchen door entrance.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1619331

HOTOLOS HOLLYWOOD

License Type: Food

2520 STIRLING RD , HOLLYWOOD 33020

Insp Date: 02/19/2026

Inspection Number: 3626996

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Inward opening exit door in prep area blocked by trash can. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Collier

License Number: 2102413

PUB AT ARROWHEAD

License Type: Food

2205 HERITAGE GREENS DR , NAPLES 34119

Insp Date: 02/18/2026

Inspection Number: 3673125

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 45-05-4 | Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed fire extinguisher being stored on floor in kitchen | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|

License Number: 2200256

KOUNTRY KORNER RESTAURANT

License Type: Food

1084 N MARION AVE , LAKE CITY 32055

Insp Date: 02/17/2026

Inspection Number: 3666788

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 47-03-4 | Observed electrical wiring in disrepair. For reporting purposes only.Exposed wires behind the ice machine | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|

License Number: 2200256

KOUNTRY KORNER RESTAURANT

License Type: Food

1084 N MARION AVE , LAKE CITY 32055

Insp Date: 02/17/2026

Inspection Number: 3666788

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 48-04-4 | Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Near the walk in cooler | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2336823

JEALOUS FORK

License Type: Food

14417 SW 42 ST , MIAMI 33175

Insp Date: 02/20/2026

Inspection Number: 3662682

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher near exit door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322804

GOURMET KOSHER LLC

License Type: Food

330 NE 59 ST , MIAMI 33137

Insp Date: 02/20/2026

Inspection Number: 3598715

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate Expired 3-2024. **Repeat Violation**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2335152

NOVOTEL MIAMI BRICKELL

License Type: Food

1500 SW 1 AVE , MIAMI 33129

Insp Date: 02/20/2026

Inspection Number: 3606780

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 02/21/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2335079

LEMON PEPPERS

License Type: Food

2701 NW 54TH ST , MIAMI 33142

Insp Date: 02/18/2026

Inspection Number: 3691723

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher in front of 3 compartment sink in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2319251

CLUB TIPICO DOMINICANO

License Type: Food

1342 NW 36 ST , MIAMI 25556

Insp Date: 02/18/2026

Inspection Number: 3662423

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher by rear exit door in the kitchen , in recharge zone. ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2360783

LATIN FIXINS

License Type: Food

5021 NW 79 AVE , DORAL 33166

Insp Date: 02/17/2026

Inspection Number: 1330625

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed Extinguisher in recharge zone in MFDV.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330017

LOS TANITOS INC

License Type: Food

9562 - 9564 SW 137 AVE , MIAMI 33186

Insp Date: 02/18/2026

Inspection Number: 3665879

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit blocked with kitchen racks at kitchen to the right of cook line. Operator removed kitchen racks from door path. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2330017

LOS TANITOS INC

License Type: Food

9562 - 9564 SW 137 AVE , MIAMI 33186

Insp Date: 02/18/2026

Inspection Number: 3665879

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 46-04-4 | Exit door locked. For reporting purposes only. Observed exit locked at kitchen to the right of cook line. Operator unlocked door. **Corrected On-Site** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|

License Number: 2337614

SILAN

License Type: Food

5225 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 02/19/2026

Inspection Number: 3680388

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. | Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |
|---------|---|--|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2337174

CHICK N JONES

License Type: Food

9420 NW 41 ST UNIT 101 , DORAL 33178

Insp Date: 02/20/2026

Inspection Number: 3655406

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. ****Repeat Violation****

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2326832

GREATER MIAMI CATERERS

License Type: Food

4001 NW 31 AVE /2 BUILDINGS, MIAMI 33142

Insp Date: 02/13/2026

Inspection Number: 1133131

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2335871

ALTITUDE

License Type: Food

801 S MIAMI AVE , MIAMI 33130

Insp Date: 02/20/2026

Inspection Number: 3599443

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

| | | |
|---------|---|---|
| 48-01-5 | <p>- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed FL 135542 , FL 135543 both certificates expires on 09-27-24. **Repeat Violation** - From follow-up inspection 2026-02-20: Observed FL 135542 , FL 135543 both certificates expires on 09-27-24. **Time Extended**</p> | <p>Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.</p> |
|---------|---|---|

License Number: 2615753

ACOSTA

License Type: Food

6651 GATE PKWY , JACKSONVILLE 32256

Insp Date: 02/18/2026

Inspection Number: 3690921

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|---|---|
| 48-01-5 | <p>No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Establishment has two boilers at 499900 BTUs. Unable to provide boiler report. Not indicated on boiler search.</p> | <p>Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.</p> |
|---------|---|---|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lake

License Number: 4508630

PAPA JOHN'S PIZZA #923

License Type: Food

1495 E SR 50 UNIT B , CLERMONT 34711

Insp Date: 02/13/2026

Inspection Number: 3601483

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-by boxes

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4601794

ZORBA'S GREEK RESTAURANT

License Type: Food

9106 BONITA BCH RD , BONITA SPGS 34135

Insp Date: 02/17/2026

Inspection Number: 3646406

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Manatee

License Number: 5103480

PEACH'S RESTAURANT

License Type: Food

3201 MANATEE AVE W , BRADENTON 34205

Insp Date: 02/18/2026

Inspection Number: 3670199

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 45-05-4 | Portable fire extinguisher missing from its designated location. For reporting purposes only.Observed Fire Extinguisher stored on floor. | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|

License Number: 5103920

SAN REMO PIZZA & PASTA

License Type: Food

1914 14 STREET W , BRADENTON 57137

Insp Date: 02/13/2026

Inspection Number: 3659881

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 46-04-4 | - From initial inspection : Exit door locked. For reporting purposes only.Observed the kitchen fire exit door locked. - From follow-up inspection 2026-02-13: **Time Extended** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5810526

WELLBORN HOTEL

License Type: Food

211 N LUCERNE CIRCLE EAST , ORLANDO 32801

Insp Date: 02/17/2026

Inspection Number: 3594905

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

| | | |
|---------|--|---|
| 48-04-4 | <p>- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.In bakery kitchen. Operator immediately removed **Corrected On-Site**</p> <p>- From follow-up inspection 2025-10-15: **Time Extended** - From follow-up inspection 2025-12-16: **Time Extended** - From follow-up inspection 2026-02-17: **Time Extended**</p> | <p>Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p> |
|---------|--|---|

License Number: 5806700

CHENG'S CHINESE RESTAURANT

License Type: Food

4004 S SEMORAN BLVD , ORLANDO 32822

Insp Date: 02/19/2026

Inspection Number: 3669542

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

| | | |
|---------|---|---|
| 48-04-4 | <p>Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Under dish machine shelf. Has a heater attached Operator removed from inside **Corrected On-Site**</p> | <p>Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p> |
|---------|---|---|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6006959

HOUSE OF CHEUNG

License Type: Food

499 NE 20 ST , BOCA RATON 33431

Insp Date: 02/20/2026

Inspection Number: 3669277

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Sarasota

License Number: 6805328

PANERA BREAD #1600

License Type: Food

17899 TAMIAMI TRL , NORTH PORT 34287

Insp Date: 02/13/2026

Inspection Number: 3595436

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only.Observed the rear exit blocked by cardboard boxes and trash bags. | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|

License Number:

PIZZA HOUSE AND COMPANY

License Type: Food

8317 LOCKWOOD RIDGE RD , SARASOTA 34243

Insp Date: 02/18/2026

Inspection Number: 3588389

Insp Type: Food-Licensing Inspection

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 45-04-4 | - From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Observed a fully operating wood fired pizza oven without ventilation or a hood system. Manatee county fire has issued a violation and installation request from owner. Owner has stated she does not have the money to complete install. **Warning** - From follow-up inspection 2026-02-18: Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Observed a fully operating wood fired pizza oven without ventilation or a hood system. Manatee county fire has issued a violation and installation request from owner. Owner has stated she does not have the money to complete install.No change in 60 days. **Admin Complaint** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

St. Johns

License Number: 6501968

CHINA CAFE

License Type: Food

165 BLACKFORD WAY , SAINT AUGUSTINE 32086

Insp Date: 02/18/2026

Inspection Number: 3690372

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only.By boxes. Person in charge moved boxes. **Corrected On-Site** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|

License Number: 7405261

DELICIAS CENTROAMERICANAS LLC

License Type: Food

722 MASON AVE , DAYTONA BEACH 32117

Insp Date: 02/18/2026

Inspection Number: 3668800

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 45-04-4 | Use of cooking equipment producing grease laden vapors/smoke not under hood suppression system installed. Notified Fire AHJ. For reporting purposes only.- tabletop fryer not under hood suppression system. | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|

License Number: 7406588

SUPER WOK

License Type: Food

4031 S NOVA RD STE A , PORT ORANGE 32127

Insp Date: 02/19/2026

Inspection Number: 3681308

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 49-05-4 | Flammables stored near a source of ignition. For reporting purposes only.-cardboard box of packaged dry food stored on top shelf in back storage area at end of cookline immediately next to vent stack of water heater. Manager moved product away from water heater during inspection **Corrected On-Site** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|