



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Alachua**

License Number: 1102875

**GREEN TREE**

License Type: Food

14236 W NEWBERRY RD , NEW BERRY 32669

Insp Date: 02/26/2026

Inspection Number: 3660352

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher near back door of kitchen in need of recharge.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 1304404

**SUBWAY #17185**

License Type: Food

2521 THOMAS DR , PANAMA CITY BCH 86252

Insp Date: 02/26/2026

Inspection Number: 3692305

Insp Type: Complaint Partial

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone in the wall adjacent to the dry storage/ice machine room. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 1305840

**HONDURAS KITCHEN**

License Type: Food

340 PALM BEACH DR , PANAMA CITY BEACH 32413

Insp Date: 02/23/2026

Inspection Number: 3657926

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. In the kitchen, next to handwashing sink.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Brevard**

License Number: 1502902

**DOMINO'S PIZZA 4930**

License Type: Food

5360 N ATLANTIC AVE , COCOA BCH 15104

Insp Date: 02/25/2026

Inspection Number: 3639782

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to back door \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506125

**BACI**

License Type: Food

760 BARNES BLVD #108-110 , ROCKLEDGE 32955

Insp Date: 02/24/2026

Inspection Number: 3668374

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed silver chemical fire extinguisher meter is in the red \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Brevard**

License Number: 1506166

**LELLO'S RISTORANTE AND PIZZERIA**

License Type: Food

2025 MURRELL RD STE 190 , ROCKLEDGE 32955

Insp Date: 02/24/2026

Inspection Number: 3665621

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed silver chemical fire extinguisher meter extinguisher is reading in the red zone

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1502763

**KENTUCKY FRIED CHICKEN # 68**

License Type: Food

4901 BABCOCK ST NE , PALM BAY 52809

Insp Date: 02/23/2026

Inspection Number: 3673510

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Electric panel in back of restaurant missing panel door. No wiring exposed but breakers subject to dust and flour debris.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Broward**

License Number: 1623996

**DUNKIN DONUTS 337278**

License Type: Food

1450 W BROWARD BLVD , FORT LAUDERDALE 33312

Insp Date: 02/24/2026

Inspection Number: 3692262

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Empty boxes stored in front of exit door. Removed during inspection. **\*\*Corrected On-Site\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621170

**ATLANTIC HOTEL & SPA - POOL BAR**

License Type: Food

601 N FORT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 02/25/2026

Inspection Number: 3647761

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Broward**

License Number: 1621169

**ATLANTIC HOTEL & SPA - WILD THYME**

License Type: Food

601 N FORT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 02/25/2026

Inspection Number: 3679632

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	--

License Number: 1801577

**IHOP RESTAURANTS**

License Type: Food

1789 TAMIAMI TRAIL , PORT CHARLOTTE 33948

Insp Date: 02/23/2026

Inspection Number: 3692048

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.Observed a marked rear exit door blocked by cardboard boxes.The operator removed the boxes from the path of the exit. <b>**Corrected On-Site**</b>	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Charlotte

License Number: 1801912

**FIVE GUYS BURGERS AND FRIES**

License Type: Food

1900 TAMIAMI TRL STE 100 , PORT CHARLOTTE 33948

Insp Date: 02/23/2026

Inspection Number: 3632593

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Observed the rear exit blocked by cardboard boxes.The operator removed the boxes from the exit path.  
\*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1801597

**GOLDEN KRUST CARIBBEAN RESTAURANT**

License Type: Food

1825 TAMIAMI TRL STE A2 , PORT CHARLOTTE 33948

Insp Date: 02/23/2026

Inspection Number: 3652034

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Observed the rear kitchen exit blocked by empty storage buckets.The operator removed the buckets.  
\*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336823

**JEALOUS FORK**

License Type: Food

14417 SW 42 ST , MIAMI 33175

Insp Date: 02/20/2026

Inspection Number: 3662682

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher near exit door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 02/28/2026

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2322804

**GOURMET KOSHER LLC**

License Type: Food

330 NE 59 ST , MIAMI 33137

Insp Date: 02/20/2026

Inspection Number: 3598715

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate Expired 3-2024. \*\*Repeat Violation\*\*

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2335152

**NOVOTEL MIAMI BRICKELL**

License Type: Food

1500 SW 1 AVE , MIAMI 33129

Insp Date: 02/20/2026

Inspection Number: 3606780

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2334973

**DUNKIN PC#355073**

License Type: Food

19801 NW 27 AVE , MIAMI GARDENS 33056

Insp Date: 02/24/2026

Inspection Number: 3692278

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Smoke detector hanging from the ceiling.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328863

**TACOS VS BURRITO**

License Type: Food

650 NE 79 ST , MIAMI 33138

Insp Date: 02/25/2026

Inspection Number: 3647195

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed by women bathroom.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2337032

**MR PORK BELLY**

License Type: Food

9420 NW 41 ST UNIT 105 , DORAL 33178

Insp Date: 02/23/2026

Inspection Number: 3664939

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. **\*\*Repeat Violation\*\***

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337174

**CHICK N JONES**

License Type: Food

9420 NW 41 ST UNIT 101 , DORAL 33178

Insp Date: 02/20/2026

Inspection Number: 3655406

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. **\*\*Repeat Violation\*\***

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2337177

**KUFFO**

License Type: Food

9420 NW 41 ST 103-104 , DORAL 33178

Insp Date: 02/23/2026

Inspection Number: 3664287

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. **\*\*Repeat Violation\*\***

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2326487

**OH MEXICO AT MERCATO DELLA PESCHERIA**

License Type: Food

410-412 ESPANOLA WAY , MIAMI BEACH 33139

Insp Date: 02/25/2026

Inspection Number: 3668314

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2335871

**ALTITUDE**

License Type: Food

801 S MIAMI AVE , MIAMI 33130

Insp Date: 02/20/2026

Inspection Number: 3599443

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5	<p>- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed FL 135542 , FL 135543 both certificates expires on 09-27-24. <b>**Repeat Violation**</b> - From follow-up inspection 2026-02-20: Observed FL 135542 , FL 135543 both certificates expires on 09-27-24. <b>**Time Extended**</b></p>	<p>Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.</p>
---------	---	---

License Number: 2336596

**NOMA BEACH AT REDFISH**

License Type: Food

9610 OLD CUTLER RD , CORAL GABLES 33156

Insp Date: 02/27/2026

Inspection Number: 3675293

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4	<p>Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed at front prep area mini fryer; no hood. <b>**Repeat Violation**</b></p>	<p>Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
---------	---	---



Division of Hotels & Restaurants

Report Date: 02/28/2026

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**DeSoto**

License Number: 2400225

**BROKEN SPUR DINER**

License Type: Food

10 POLK AVE , ARCADIA 34266

Insp Date: 02/23/2026

Inspection Number: 3657989

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed hood system without hood filters and not operational, flat grill, burners and two counter top fryers are in use. **\*\*Repeat Violation\*\*** - From follow-up inspection 2026-02-23: **\*\*Time Extended\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 02/28/2026

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Duval**

License Number: 2607175

**CAPTAIN D'S #3371**

License Type: Food

6550 NORMANDY BLVD , JACKSONVILLE 56202

Insp Date: 02/23/2026

Inspection Number: 3646156

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.By front counter

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614981

**PANERA BREAD #1575**

License Type: Food

1440 HENDRICKS AVENUE , JACKSONVILLE 32207

Insp Date: 02/27/2026

Inspection Number: 3668136

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.By rear door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Hillsborough**

License Number: 3910572

**STRAWBERRY HUT (THE)**

License Type: Food

1505 N WHEELER ST , PLANT CITY 33563

Insp Date: 02/25/2026

Inspection Number: 3669659

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3919009

**DUNKIN DONUTS BASKIN ROBBINS**

License Type: Food

14407 S US HWY 301 , WIMAUMA 33598

Insp Date: 02/25/2026

Inspection Number: 3610093

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Trash can blocking back door. Manager removed at time of inspection. **\*\*Corrected On-Site\*\***  
**\*\*Repeat Violation\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 02/28/2026

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Lee**

License Number: 4607737

**LOS MOLCAJETES**

License Type: Food

2847 CLEVELAND AVE , FORT MYERS 33901

Insp Date: 02/23/2026

Inspection Number: 3691657

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4651585

**EASY CHEESY**

License Type: Food

4529 BAYSHORE ROAD , NORTH FORT MYERS 33903

Insp Date: 02/25/2026

Inspection Number: 1323970

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Under hot holding box.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Manatee**

License Number: 5104353

**RAGU**

License Type: Food

336 8 AVE W , PALMETTO 34221

Insp Date: 02/26/2026

Inspection Number: 3660277

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

complaint

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.Observed their right side fire exit door locked.Operator unlocked it.  
**\*\*Corrected On-Site\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Marion**

License Number: 5250617

**MCFOODLAND FOOD TRUCK DINER**

License Type: Food

310 SE 3RD ST , OCALA 34471

Insp Date: 02/23/2026

Inspection Number: 1329035

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher next to back door. **\*\*Repeat Violation\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5202466

**WOK N' STUFF II**

License Type: Food

3435 N PINE AVE #202 , OCALA 34475

Insp Date: 02/26/2026

Inspection Number: 3659578

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Barbecue grill size tank being used for two burner tabletop equipment in kitchen area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Monroe**

License Number: 5401303

**CUBAN COFFEE QUEEN DOWNTOWN**

License Type: Food

5 KEY LIME SQ , KEY WEST 33040

Insp Date: 02/24/2026

Inspection Number: 3657889

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed mini flat top grill on top of prep table next to steam table.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Osceola**

License Number: 5910840

**CRACKER BARREL #529**

License Type: Food

7878 W IRLO BRONSON MEMORIAL HWY , KISSIMMEE 34747

Insp Date: 02/26/2026

Inspection Number: 3677433

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher next to walk in cooler in red zone

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911897

**FRANCO**

License Type: Food

611 W VINE ST STE B , KISSIMMEE 34741

Insp Date: 02/26/2026

Inspection Number: 3681014

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Exit door blocked by produce and containers. **\*\*Corrected On-Site\*\* \*\*Repeat Violation\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Palm Beach**

License Number: 6006959

**HOUSE OF CHEUNG**

License Type: Food

499 NE 20 ST , BOCA RATON 33431

Insp Date: 02/20/2026

Inspection Number: 3669277

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6019350

**MACARTHUR'S**

License Type: Food

4000 RCA BLVD , PALM BEACH GARDENS 33410

Insp Date: 02/27/2026

Inspection Number: 3656250

Insp Type: Routine - Food

Disposition: Emergency order recommended

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Establishment only has expired certificates.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Pinellas**

License Number: 6218593

**HIATUS**

License Type: Food

385 S GULFVIEW BLVD , CLEARWATER 33767

Insp Date: 02/24/2026

Inspection Number: 3664466

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report. For reporting purposes only. Fl 136340, fl 136336, fl 136339, expired 4/3/2025

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6502071

**BURGER KING #19411**

License Type: Food

2455 SR 207 , SAINT AUGUSTINE 32084

Insp Date: 02/23/2026

Inspection Number: 3627132

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. By box.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407627

**CHIPOTLE #3241**

License Type: Food

1425 A CORNERSTONE BLVD , DAYTONA BEACH 32117

Insp Date: 02/24/2026

Inspection Number: 3692295

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-boxes blocked rear door \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 02/28/2026

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Volusia**

License Number: 7407600

**BRONX HOUSE PIZZA**

License Type: Food

1307 CORNERSTONE BLVD UNIT A , DAYTONA BEACH 32117

Insp Date: 02/26/2026

Inspection Number: 3690693

Insp Type: Food-Licensing Inspection

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-front exit blocked by delivery

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407336

**WILD RABBIT BISTRO**

License Type: Food

48 E GRANADA BLVD , ORMOND BEACH 32176

Insp Date: 02/24/2026

Inspection Number: 3620071

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-operator using flat grill to cook bacon.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400553

**BURGER KING**

License Type: Food

1436 W INTERNATIONAL SPEEDWAY , DAYTONA BEACH 32114

Insp Date: 02/24/2026

Inspection Number: 3610397

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/kitchen Smokey when using broiler under hood. Notified Fire AHJ. For reporting purposes only.-broiler was pushed out from wall while employee was cleaning , not completely under hood \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.