



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Alachua

License Number: 1103835

X GOLF

License Type: Food

4871 CELEBRATION POINTE AVE STE 30 , GAINESVILLE 32608

Insp Date: 03/06/2026

Inspection Number: 3691743

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed : the fire extinguisher by the far back door exit is in the red zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305920

DAT CAJUN PLACE

License Type: Food

2705 THOMAS DR , PANAMA CITY BEACH 32408

Insp Date: 03/02/2026

Inspection Number: 3692493

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. Large gas tanks in storage building at the back of the establishment. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1504228

RED GINGER

License Type: Food

6300 N WICKHAM RD STE 128 , MELBOURNE 32940

Insp Date: 03/04/2026

Inspection Number: 3692634

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver fire extinguisher was reading in the red

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1620877

SPICE RESTO LOUNGE

License Type: Food

1934 HOLLYWOOD BLVD , HOLLYWOOD 33020

Insp Date: 03/02/2026

Inspection Number: 3687245

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher at end of bar west side in undercharged zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1652657

INSPIRASIAN

License Type: Food

2608 N OCEAN BLVD , POMPANO BEACH 33062

Insp Date: 03/06/2026

Inspection Number: 1331244

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1624811

BAIRES GRILL

License Type: Food

1307 E LAS OLAS BLVD , FORT LAUDERDALE 33301

Insp Date: 03/05/2026

Inspection Number: 3680252

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two tanks at the rear door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001071

LONGHORN STEAKHOUSE OF FLEMING ISLAND

License Type: Food

1605 CR 220 , ORANGE PARK 32003

Insp Date: 03/03/2026

Inspection Number: 3663449

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Back exit blocked by bagged trash and boxes. Employee cleared exit path. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Collier

License Number: 2103867

PANADERIA Y MARISQUERIA

License Type: Food

12275 COLLIER BLVD UNIT 9 , NAPLES 34116

Insp Date: 03/06/2026

Inspection Number: 3654569

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank stored in kitchen near reach in cooler.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2328734

MIKE'S CAFE & DELI

License Type: Food

9155 S DADELAND BLVD #100 , MIAMI 33156

Insp Date: 03/02/2026

Inspection Number: 3666416

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed use of cooking equipment with no hood. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2325445

CAFETERIA DONDE VICKY

License Type: Food

4095 SW 137 AVE STE 1 , MIAMI 33175

Insp Date: 03/05/2026

Inspection Number: 3666849

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4	Exit door locked. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2337180

LA LLORONA

License Type: Food

9420 NW 41 ST UNIT 112 , DORAL 33178

Insp Date: 03/02/2026

Inspection Number: 3655448

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2336186

BACHOUR

License Type: Food

2020 SALZEDO ST, SUITE 103 , CORAL GABLES 33134

Insp Date: 03/04/2026

Inspection Number: 3672407

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only. Observed at prep station.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2336596

NOMA BEACH AT REDFISH

License Type: Food

9610 OLD CUTLER RD , CORAL GABLES 33156

Insp Date: 03/05/2026

Inspection Number: 3675293

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4	<p>- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed at front prep area mini fryer; no hood. **Repeat Violation** - From follow-up inspection 2026-03-05: Observed at front prep area mini fryer; no hood. **Time Extended**</p>	<p>Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
---------	---	---

License Number: 2335152

NOVOTEL MIAMI BRICKELL

License Type: Food

1500 SW 1 AVE , MIAMI 33129

Insp Date: 03/06/2026

Inspection Number: 3606780

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5	<p>- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2026-03-06: No current insurance inspector boiler report or boiler certificate available for boiler. **Time Extended**</p>	<p>Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.</p>
---------	--	---



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2336596

NOMA BEACH AT REDFISH

License Type: Food

9610 OLD CUTLER RD , CORAL GABLES 33156

Insp Date: 02/27/2026

Inspection Number: 3675293

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed at front prep area mini fryer; no hood. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2400050

REEF & BEEF

License Type: Food

2079 SE HWY 70 , ARCADIA 34266

Insp Date: 03/04/2026

Inspection Number: 3658702

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.Observed fire extinguisher in the red in the bar area. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2615866

CAVERN

License Type: Food

9825 SAN JOSE BLVD 18 , JACKSONVILLE 32257

Insp Date: 03/06/2026

Inspection Number: 3692166

Insp Type: Complaint Partial

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Establishment has expanded menu to include cooking of hamburgers/burgers. Also offers cooked to order.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2603878

WENDY'S OLD FASHIONED HAMBURGERS #80

License Type: Food

2006 PARK ST , JACKSONVILLE 32204

Insp Date: 03/04/2026

Inspection Number: 3675464

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher near office.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615097

CHICK-FIL-A MANDARIN

License Type: Food

3280 OAK BLUFF LN , JACKSONVILLE 32257

Insp Date: 03/02/2026

Inspection Number: 3675186

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Frontline side door exit blocked by equipment. Moved by manager. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2613004

KFC # L518068

License Type: Food

4201 OLDFIELD CROSSING DR , JACKSONVILLE 32223

Insp Date: 03/02/2026

Inspection Number: 3671030

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Loose / hanging electrical out in walk in cooler.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615312

TRIO HOOKAH LOUNGE

License Type: Food

8725 OLD KINGS RD S , JACKSONVILLE 32217

Insp Date: 03/04/2026

Inspection Number: 3672856

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 1 large LP tank in rear storage room.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2614981

PANERA BREAD #1575

License Type: Food

1440 HENDRICKS AVENUE , JACKSONVILLE 32207

Insp Date: 02/27/2026

Inspection Number: 3668136

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613040

SALUMERIA 104

License Type: Food

60 OCEAN BLVD , ATLANTIC BEACH 32233

Insp Date: 03/03/2026

Inspection Number: 3667924

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks in prep room.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hendry

License Number: 3600492

HOLIDAY INN EXPRESS HOTEL & SUITES

License Type: Food

1024 W SUGARLAND HWY , CLEWISTON 33440

Insp Date: 03/06/2026

Inspection Number: 3666968

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FL136106 7/12/23. Operator has correspondence for inspection but inspector has not been by to reinspect or recertify. ****Corrective Action Taken**** ****Repeat Violation****

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hillsborough

License Number: 3918377

HEY RAMEN & BOBA TEA

License Type: Food

2223 N WESTSHORE BLVD STE 230B , TAMPA 33607

Insp Date: 03/02/2026

Inspection Number: 3679243

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Counter top fryers and conventional stove top in kitchen.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 3906144

MARY'S CAFE II

License Type: Food

3030 ROCKY POINT DR STE 175 , TAMPA 33607

Insp Date: 03/02/2026

Inspection Number: 3654294

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Conventional stove, counter top fryer, griddle and sandwich press in kitchen with no hood ventilation and suppression system. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lake

License Number: 4508525

LITTLE CAESARS

License Type: Food

2560 E SR 50 #113 , CLERMONT 34711

Insp Date: 03/03/2026

Inspection Number: 3604569

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.-by front hand sink

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811193

TEXAS DE BRAZIL

License Type: Food

5259 INTERNATIONAL DRIVE , ORLANDO 32819

Insp Date: 03/03/2026

Inspection Number: 3674076

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. In back kitchen area above reach

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811217

AHMED INDIAN RESTAURANT OBT

License Type: Food

11301 S ORANGE BLOSSOM TRL #104 , ORLANDO 32837

Insp Date: 03/04/2026

Inspection Number: 3677755

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Exit door in hall way where bathroom are located

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5814258

HURRICANE GRILL & WINGS

License Type: Food

2209 E SEMORAN BLVD STE A , APOPKA 32703

Insp Date: 03/02/2026

Inspection Number: 3654100

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-rear door blocked by trash cans
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813065

MCDONALD'S OCOEE WEST

License Type: Food

2281 OCOEE-APOPKA RD , OCOEE 34761

Insp Date: 03/06/2026

Inspection Number: 3591386

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Employee removed bread crates from in front of exit door of kitchen. **Corrected On-Site**
Repeat Violation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811217

AHMED INDIAN RESTAURANT OBT

License Type: Food

11301 S ORANGE BLOSSOM TRL #104 , ORLANDO 32837

Insp Date: 03/05/2026

Inspection Number: 3677755

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.Exit door in hall way where bathroom are located - From follow-up inspection 2026-03-05: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6022970

AMRIT OCEAN - TULA / AYRE / JEEVI / LALA

License Type: Food

3100 N OCEAN DR , RIVIERA BEACH 33404

Insp Date: 03/02/2026

Inspection Number: 3686219

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	--

License Number: 6019350

MACARTHUR'S

License Type: Food

4000 RCA BLVD , PALM BEACH GARDENS 33410

Insp Date: 02/27/2026

Inspection Number: 3656250

Insp Type: Routine - Food

Disposition: Emergency order recommended

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Establishment only has expired certificates.	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6019350

MACARTHUR'S

License Type: Food

4000 RCA BLVD , PALM BEACH GARDENS 33410

Insp Date: 02/28/2026

Inspection Number: 3656250

Insp Type: Routine - Food

Disposition: Emergency Order Callback
Complied

Violation Code

Observation

Violation Citation

48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.Establishment only has expired certificates. - From follow-up inspection 2026-02-28:	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	--

License Number: 6022970

AMRIT OCEAN - TULA / AYRE / JEEVI / LALA

License Type: Food

3100 N OCEAN DR , RIVIERA BEACH 33404

Insp Date: 03/02/2026

Inspection Number: 3688354

Insp Type: Complaint Full

Disposition: Call Back - Admin. complaint
recommended

Violation Code

Observation

Violation Citation

48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2026-03-02: Unable to provide certificates due to deficiencies **Time Extended**	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Report Date: 03/07/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6010067

LONG ISLAND BAGEL & DELI

License Type: Food

21667 SR 7 , BOCA RATON 33428

Insp Date: 03/02/2026

Inspection Number: 3692714

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. In the kitchen	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6214350

HIBACHI BUFFET SUSHI & GRILL

License Type: Food

2456 GULF TO BAY BLVD , CLEARWATER 33765

Insp Date: 03/04/2026

Inspection Number: 3692303

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone at cook line area . For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6216515

TROPICO

License Type: Food

301 GULF VIEW BLVD , CLEARWATER 33767

Insp Date: 03/06/2026

Inspection Number: 3661702

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. F1123659, F1123660 expires 1/25/2026

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6216496

HYATT REGENCY CLEARWATER BEACH RESORT AND SPA

License Type: Food

301 GULFVIEW BLVD , CLEARWATER 33767

Insp Date: 03/06/2026

Inspection Number: 3653060

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. F1123659, F1123660 expires 1/25/2026

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6218593

HIATUS

License Type: Food

385 S GULFVIEW BLVD , CLEARWATER 33767

Insp Date: 03/04/2026

Inspection Number: 3664466

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5	- From initial inspection : No current insurance inspector boiler report. For reporting purposes only. FI 136340, fl 136336, fl 136339, expired 4/3/2025 - From follow-up inspection 2026-03-04: **Time Extended**	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	--

License Number: 6213005

TAMPA STYLE CUBAN

License Type: Food

1300 E BAY DRIVE , LARGO 33771

Insp Date: 03/04/2026

Inspection Number: 3662658

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 1 Propane tank stored next to broken ice machine across from reach in coolers near restroom. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Report Date: 03/07/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Seminole

License Number: 6902099

OMAHA STEAKHOUSE

License Type: Food

225 SHORECREST DR , ALTAMONTE SPRINGS 32701

Insp Date: 03/04/2026

Inspection Number: 3691931

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Current reports expired 2/17/26

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6904986

MEDELLIN GOURMET

License Type: Food

1349 E ALTAMONTE DR STE 1011 , ALTAMONTE SPRINGS 32701

Insp Date: 03/04/2026

Inspection Number: 3665749

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. 2 small fryers placed on prep table next to cook line.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

St. Johns

License Number: 6501938

MCDONALD'S #33505

License Type: Food

37 EPIC BLVD , SAINT AUGUSTINE 32084

Insp Date: 03/04/2026

Inspection Number: 3692389

Insp Type: Complaint Partial

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.By box. Person in charge moved box. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6501874

ST GEORGE INN

License Type: Food

4 ST GEORGE ST #101 , ST AUGUSTINE 32084

Insp Date: 03/06/2026

Inspection Number: 3675926

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

49-04-4

Flammables stored/debris present in storage room. For reporting purposes only.5 outdoor grill tanks in dry storage area. Person in charge move tanks. ****Corrected On-Site****

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7402295

HUNTERS & GATHERERS

License Type: Food

111 E RICH AVE , DELAND 32724

Insp Date: 03/03/2026

Inspection Number: 3661866

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.- small tabletop fryer in back prep area

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407168

LA CANTINA COCINA MEXICANA

License Type: Food

4085 S RIDGEWOOD AVE , PORT ORANGE 32127

Insp Date: 03/06/2026

Inspection Number: 3655071

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-front door unable to be opened at start of inspection, advised to look into problem causing malfunction. All doors marked with fire exits must remain accessible and unobstructed/unlocked when establishment is operating.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.