



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Alachua

License Number: 1102456

MCDONALDS

License Type: Food

1030 E UNIVERSITY AVE , GAINESVILLE 32601

Insp Date: 03/23/2026

Inspection Number: 3617209

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher missing from designated location near drive through window.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 1505738

MIMMOS PIZZA & RISTORANTE

License Type: Food

325 MERRITT ISLAND CAUSEWAY STE L , MERRITT ISLAND 32952

Insp Date: 03/26/2026

Inspection Number: 3683447

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. For reporting purposes only. Hood not working at all	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 1505819

VARGAS MAGICO CAFE

License Type: Food

8010 N ATLANTIC AVE #1 , CAPE CANAVERAL 32920

Insp Date: 03/24/2026

Inspection Number: 3680242

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Door through storage at rear exit is blocked	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Brevard

License Number: 1505738

MIMMOS PIZZA & RISTORANTE

License Type: Food

325 MERRITT ISLAND CAUSEWAY STE L , MERRITT ISLAND 32952

Insp Date: 03/26/2026

Inspection Number: 3683447

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. By salad cooler in wait station	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 1505738

MIMMOS PIZZA & RISTORANTE

License Type: Food

325 MERRITT ISLAND CAUSEWAY STE L , MERRITT ISLAND 32952

Insp Date: 03/27/2026

Inspection Number: 3683447

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. For reporting purposes only. Hood not working at all - From follow-up inspection 2026-03-27: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 1505738

MIMMOS PIZZA & RISTORANTE

License Type: Food

325 MERRITT ISLAND CAUSEWAY STE L , MERRITT ISLAND 32952

Insp Date: 03/27/2026

Inspection Number: 3683447

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. By salad cooler in wait station - From follow-up inspection 2026-03-27: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1626304

HOST TABLE AND TAP

License Type: Food

1522 NE 4 AVE , FORT LAUDERDALE 33304

Insp Date: 03/23/2026

Inspection Number: 3661359

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1624910

POORHOUSE

License Type: Food

110 SW 3 AVE , FORT LAUDERDALE 33312

Insp Date: 03/25/2026

Inspection Number: 3614584

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Storage room exit path blocked

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Charlotte

License Number: 1801631

SUBWAY

License Type: Food

5855 PLACIDA RD STE 404 , ENGLEWOOD 34224

Insp Date: 03/27/2026

Inspection Number: 3606553

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Observed the rear exit blocked by cardboard boxes.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1801631

SUBWAY

License Type: Food

5855 PLACIDA RD STE 404 , ENGLEWOOD 34224

Insp Date: 03/27/2026

Inspection Number: 3606553

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Rear exit door locked. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Charlotte

License Number: 1801792

SUBWAY

License Type: Food

24123 PEACHLAND BLVD C5 , PORT CHARLOTTE 33954

Insp Date: 03/24/2026

Inspection Number: 3671361

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4	Rear exit door locked. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2000765

HARDEE'S

License Type: Food

1323 N ORANGE AVE , GREEN COVE SPRINGS 32043

Insp Date: 03/24/2026

Inspection Number: 3661903

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher across from the fryers is in the recharge zone.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2338294

CREMA GOURMET ESPRESSO BAR

License Type: Food

5700 BISCAYNE BLVD #103 , MIAMI 33137

Insp Date: 03/25/2026

Inspection Number: 3679621

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed flat top griddle not under hood system.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329047

SERGIO'S PINECREST

License Type: Food

11927 S DIXIE HWY , PINECREST 33156

Insp Date: 03/23/2026

Inspection Number: 3682611

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed induction burners on top of cooler across dry storage racks used for Spanish tortilla.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2331432

TACOS LA POTRANCA & CANTINA EXPRESS

License Type: Food

2923 BISCAYNE BLVD , MIAMI 33137

Insp Date: 03/24/2026

Inspection Number: 3684115

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed fryers set up in kitchen; not under hood system.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2322040

RICKY BAKERY

License Type: Food

12761 SW 42 ST BAY 24 , MIAMI 33175

Insp Date: 03/24/2026

Inspection Number: 3648918

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed one of two back exit doors blocked.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2323502

FOGON CARIBENO RESTAURANT

License Type: Food

2114 W 68 ST , HIALEAH 33016

Insp Date: 03/24/2026

Inspection Number: 3694429

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed at kitchen food debris door to outside blocked.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335676

SEVENTEEN SUSHI AND BAR

License Type: Food

1751 ALTON RD , MIAMI BEACH 33139

Insp Date: 03/25/2026

Inspection Number: 3662031

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336565

CARNICERO STEAKHOUSE

License Type: Food

7390 SW 117 AV , MIAMI 33183

Insp Date: 03/20/2026

Inspection Number: 3632435

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

49-03-4

Flammables stored/debris present in gas water heater room. For reporting purposes only.

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2320806

MISABOR CRIOLLO

License Type: Food

5376 PALM AVE , MIAMI 33012

Insp Date: 03/26/2026

Inspection Number: 3665013

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed small fryer on top of prep table at kitchen, no under hood.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337347

MANO LIBERA MARCO GIUGLIANO

License Type: Food

7201 SW 59 AVE , SOUTH MIAMI 33143

Insp Date: 03/24/2026

Inspection Number: 3680395

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed mini fryer in use; not under hood system. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 03/28/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2325744

DEERING BAY 19TH HOLE

License Type: Food

13610 DEERING BAY DR , CORAL GABLES 33158

Insp Date: 03/26/2026

Inspection Number: 3685595

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificates expired on 02/2026.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337785

DEERING BAY YACHT & COUNTRY CLUB

License Type: Food

13610 DEERING BAY DR , CORAL GABLES 33158

Insp Date: 03/26/2026

Inspection Number: 3685808

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificates were not provided.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329047

SERGIO'S PINECREST

License Type: Food

11927 S DIXIE HWY , PINECREST 33156

Insp Date: 03/24/2026

Inspection Number: 3682611

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed induction burners on top of cooler across dry storage racks used for Spanish tortilla. - From follow-up inspection 2026-03-24: Observed induction burners on top of cooler across dry storage racks used for Spanish tortilla. ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2338294

CREMA GOURMET ESPRESSO BAR

License Type: Food

5700 BISCAYNE BLVD #103 , MIAMI 33137

Insp Date: 03/26/2026

Inspection Number: 3679621

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed flat top griddle not under hood system. - From follow-up inspection 2026-03-26: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2301749

PAULINE

License Type: Food

1801 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 03/26/2026

Inspection Number: 3665867

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

<p>48-02-5</p>	<p>- From initial inspection : Insurance inspector boiler report not posted in boiler room. For reporting purposes only. Observed jurisdiction numbers 053400 and 055333 expired on 08/18/2023 - From follow-up inspection 2026-03-26: Insurance inspector boiler report not posted in boiler room. For reporting purposes only. Observed jurisdiction numbers 053400 and 055333 expired on 08/18/2023 **Time Extended**</p>	<p>Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.</p>
----------------	---	---

License Number: 2338358

BASEMENT KITCHEN AND WARM UP KITCHEN

License Type: Food

1801 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 03/26/2026

Inspection Number: 3665973

Insp Type: Routine - Food

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

<p>48-01-5</p>	<p>- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed jurisdiction numbers 053400 and 055333 expired on 08/18/2023 - From follow-up inspection 2026-03-26: No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed jurisdiction numbers 053400 and 055333 expired on 08/18/2023 **Time Extended**</p>	<p>Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.</p>
----------------	---	---



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2332481

LAS TARASCAS RESTAURANT

License Type: Food

306 NE 8 ST , HOMESTEAD 33030

Insp Date: 03/23/2026

Inspection Number: 3675218

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed on the bottom and on the side of the exit door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2616102

FORE SCORE GOLF TAVERN

License Type: Food

1407 ATLANTIC BLVD , JACKSONVILLE 32207

Insp Date: 03/27/2026

Inspection Number: 3668002

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. One fryer in use not under hood ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2614586

HONEST RESTAURANT

License Type: Food

9865 BAYMEADOWS RD STE 8 , JACKSONVILLE 32256

Insp Date: 03/23/2026

Inspection Number: 3626558

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed small tabletop griddle stored outside of hood system in kitchen.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2612529

DAVE & BUSTERS

License Type: Food

7025 SALISBURY RD , JACKSONVILLE 32256

Insp Date: 03/26/2026

Inspection Number: 3659479

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificate for 137551, 136084 expired 8.2025. Per boiler search 137551 has been replaced with exempt unit. Invoice sent for inspection conducted 6.2025. **Repeat Violation**	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2614586

HONEST RESTAURANT

License Type: Food

9865 BAYMEADOWS RD STE 8 , JACKSONVILLE 32256

Insp Date: 03/23/2026

Inspection Number: 3626558

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Observed LP tank 20lb stored in back kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hillsborough

License Number: 3911745

GOLDEN CORRAL #842

License Type: Food

815 PROVIDENCE RD , BRANDON 33511

Insp Date: 03/25/2026

Inspection Number: 3694323

Insp Type: Complaint Partial

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 3954085

EL MARRANO EL SECRETO DEL SABOR

License Type: Food

6000 N ARMENIA AVE , TAMPA 33604

Insp Date: 03/26/2026

Inspection Number: 1322801

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-06-4

Portable fire extinguisher is inaccessible. For reporting purposes only. Refrigerator blocked the access for fire extinguishers. Operator moved refrigerator aside and able to reached fire extinguishers. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lee

License Number: 4607752

TOWN CENTER AT TIMBER CREEK

License Type: Food

11590 TIMBER CREEK DR , FORT MYERS 33913

Insp Date: 03/26/2026

Inspection Number: 3669752

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

49-03-4	Combustible materials stored/debris present in electrical/water heater room. Observed boxes of single-service items and cleaning supplies stored inside electrical/water heater room. For reporting purposes only.	Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
---------	--	---

License Number: 4651561

TAQUERIA GONZALEZ

License Type: Food

4555 PALM BEACH BLVD , FORT MYERS 33905

Insp Date: 03/26/2026

Inspection Number: 1319272

Insp Type: Routine - Food

Disposition: Emergency order recommended

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 4651561

TAQUERIA GONZALEZ

License Type: Food

4555 PALM BEACH BLVD , FORT MYERS 33905

Insp Date: 03/27/2026

Inspection Number: 1319272

Insp Type: Routine - Food

Disposition: Emergency Order Callback Complied

Violation Code

Observation

Violation Citation

45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2026-03-27: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Leon

License Number: 4703733

DAYS INN & SUITES

License Type: Food

2900 N MONROE ST , TALLAHASSEE 32303

Insp Date: 03/24/2026

Inspection Number: 3618136

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 134307- 12/18/25. 134308- 12/18/25 expired	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	--	--

License Number: 5202965

POPEYES LOUISIANA KITCHEN OPERATED BY TICE

License Type: Food

3490 W SILVER SPRING BLVD , OCALA 34475

Insp Date: 03/24/2026

Inspection Number: 3666730

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no operational hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment is full of smoke. Manager stated the fan is not working in suppressing system.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Marion

License Number: 5203093

MR. B'S

License Type: Food

18505 N US HWY 441 , REDDICK 32686

Insp Date: 03/26/2026

Inspection Number: 3681445

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.LP tank in dry storage area next to back door. Manager placed tank outside. **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 5202203

NORTHGATE DINER

License Type: Food

3541 NE JACKSONVILLE RD , OCALA 34479

Insp Date: 03/24/2026

Inspection Number: 3694331

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Propane tank stored inside exterior food storage shed. Manager removed the propane tank from the area during this inspection. **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 5815876

BAKERY 1908

License Type: Food

2021 E COLONIAL DR , ORLANDO 32803

Insp Date: 03/20/2026

Inspection Number: 3673279

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.Fire extinguisher located at exit door by the pastry display	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5814322

KEKE'S BREAKFAST CAFE

License Type: Food

9723 EAGLE CREEK CENTER BLVD , ORLANDO 32832

Insp Date: 03/25/2026

Inspection Number: 3677489

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Cart blocking exit door by mop sink. Operator moved cart ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5816017

BAMBOO WOK

License Type: Food

8675 FENTON ST #120 , ORLANDO 32836

Insp Date: 03/24/2026

Inspection Number: 3655868

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed electrical face plate missing wires exposed Near back door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5812212

PUFF N STUFF CATERING

License Type: Food

250 RIO DR , ORLANDO 32810

Insp Date: 03/23/2026

Inspection Number: 3647972

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.3 propane tanks stored in warehouse
Corrected On-Site **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805079

CHINA HOT EXPRESS LLC

License Type: Food

4700 S ORANGE BLOSSOM TRAIL , ORLANDO 32839

Insp Date: 03/24/2026

Inspection Number: 3672739

Insp Type: Routine - Food

Disposition: Emergency order recommended

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-side door in lobby bolted closed

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5811922

EL PULGARCITO GRILL AND BAR LLC

License Type: Food

4950 S ORANGE BLOSSOM TRAIL STE G , ORLANDO 32839

Insp Date: 03/24/2026

Inspection Number: 3680898

Insp Type: Routine - Food

Disposition: Emergency recommended

order

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-rear exit door in pool hall does not open

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811922

EL PULGARCITO GRILL AND BAR LLC

License Type: Food

4950 S ORANGE BLOSSOM TRAIL STE G , ORLANDO 32839

Insp Date: 03/25/2026

Inspection Number: 3680898

Insp Type: Routine - Food

Disposition: Emergency Order Callback Time Extension

Violation Code

Observation

Violation Citation

46-04-4

- From initial inspection : Exit door locked. For reporting purposes only.-rear exit door in pool hall does not open
- From follow-up inspection 2026-03-25: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5805079

CHINA HOT EXPRESS LLC

License Type: Food

4700 S ORANGE BLOSSOM TRAIL , ORLANDO 32839

Insp Date: 03/25/2026

Inspection Number: 3672739

Insp Type: Routine - Food

Disposition: Emergency Order Callback
Complied

Violation Code

Observation

Violation Citation

46-04-4	- From initial inspection : Exit door locked. For reporting purposes only.-side door in lobby bolted closed - From follow-up inspection 2026-03-25: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 5815876

BAKERY 1908

License Type: Food

2021 E COLONIAL DR , ORLANDO 32803

Insp Date: 03/23/2026

Inspection Number: 3673279

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.Fire extinguisher located at exit door by the pastry display - From follow-up inspection 2026-03-23: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 6021077

IL MULINO NEW YORK

License Type: Food

451 E PALMETTO PARK RD , BOCA RATON 33432

Insp Date: 03/23/2026

Inspection Number: 3656252

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed table top fryers on cook line. Fryers not located under hood system	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pasco

License Number: 6113667

EL PAISA SPORTS BAR & RESTAURANT

License Type: Food

9814,16,18 US HWY 19 N , NEW PORT RICHEY 34668

Insp Date: 03/20/2026

Inspection Number: 3693806

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. The fire extinguisher near the exit door. ****Repeat Violation**** - From follow-up inspection 2026-03-20: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6212649

READY, SET, YO!

License Type: Food

409 GULF BLVD , INDIAN ROCKS BEACH 52539

Insp Date: 03/23/2026

Inspection Number: 3649910

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

49-01-4	Flammables stored/debris present in prep room. For reporting purposes only. 2-20 gallon propane tanks in prep storage area. Items removed. **Corrected On-Site**	Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
---------	---	---

License Number: 6215969

SAVOR THE MOMENT

License Type: Food

409 GULF BLVD , INDIAN ROCKS BEACH 33785

Insp Date: 03/23/2026

Inspection Number: 1133655

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

49-01-4	Flammables stored/debris present in prep room. For reporting purposes only. 2-20 gallon propane tanks in prep storage area. Items removed. **Corrected On-Site**	Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
---------	---	---

License Number: 6217242

CEDARS GRILL

License Type: Food

6549 54 AVE N , ST.PETERSBURG 33709

Insp Date: 03/20/2026

Inspection Number: 3677499

Insp Type: Routine - Food

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-gyro cooker not installed under hood ventilation system **Repeat Violation** - From follow-up inspection 2026-03-20: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Sarasota

License Number: 6804129

NONNO UMBERTO ITALIAN SEAFOOD AND STEAKHOUSE

License Type: Food

22 S BLVD OF THE PRESIDENTS , SARASOTA 34236

Insp Date: 03/20/2026

Inspection Number: 3687223

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Exit in the back of the dining room blocked with chairs and a small table.Owner removed the items. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905315

CHAYHANA

License Type: Food

851 W STATE RD 436 STE 1037 , ALTAMONTE SPRINGS 32714

Insp Date: 03/25/2026

Inspection Number: 3651720

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.-15 lb propane tank used in kitchen. - From follow-up inspection 2026-03-25: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6502141

KOOKABURRA

License Type: Food

1835 US HWY 1 S STE 133-135 , SAINT AUGUSTINE 32084

Insp Date: 03/24/2026

Inspection Number: 3660972

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.By coolers. Person in charge removed coolers. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

St. Lucie

License Number: 6603193

DELICIAS DE LA ABUELA INC

License Type: Food

1180-1184 SE PORT ST LUCIE BLVD , PORT ST LUCIE 34952

Insp Date: 03/27/2026

Inspection Number: 3664563

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 propane tanks in kitchen, employee removed and placed out side	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 7407865

UN GIRO ITALIAN PIZZA &GRILL

License Type: Food

515 NORTH ATLANTIC AVENUE , DAYTONA BEACH 32118

Insp Date: 03/24/2026

Inspection Number: 3664131

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-04-4	Exit door locked. For reporting purposes only.-back door **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 7406811

AB PHO AND DELI

License Type: Food

312 S PENINSULA DR , DAYTONA BEACH 32118

Insp Date: 03/26/2026

Inspection Number: 3692662

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.-unit on wall near entryway to kitchen	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7408081

SOUL FOODS

License Type: Food

948 ORANGE AVE , DAYTONA BEACH 32114

Insp Date: 03/20/2026

Inspection Number: 3693898

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.- 2 small table fryers

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7408081

SOUL FOODS

License Type: Food

948 ORANGE AVE , DAYTONA BEACH 32114

Insp Date: 03/20/2026

Inspection Number: 3693898

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-Front door with security door locked ,currently not operating.-slide lock on rear marked exit door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7407756

SAUTE' KINGZ BY CHEF COUNT

License Type: Food

200 S MARTIN LUTHER KING BLVD , DAYTONA BEACH 32114

Insp Date: 03/20/2026

Inspection Number: 3676285

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-kitchen Smokey , per manager do to filters not being in hood and using smoking pellets

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406796

COCKY ROOSTER CAFE

License Type: Food

1382 HOWLAND BLVD STE 110-112 , DELTONA 32738

Insp Date: 03/26/2026

Inspection Number: 3670580

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-rear hallway door blocked by wood, operator removed **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7407477

DUNKIN DONUTS

License Type: Food

2450 S RIDGEWOOD AVE , SOUTH DAYTONA 32119

Insp Date: 03/20/2026

Inspection Number: 3623149

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by speed rack ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407378

DUNKIN DONUTS

License Type: Food

3665 CLYDE MORRIS BLVD UNIT 101 , PORT ORANGE 32129

Insp Date: 03/23/2026

Inspection Number: 3609810

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-one of the two doors marked as a fire exit is currently not operational. Located at front of establishment.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7405531

CARRABBA'S ITALIAN GRILL

License Type: Food

2200 W INTERNATIONAL SPEEDWAY BLVD , DAYTONA BEACH 32114

Insp Date: 03/20/2026

Inspection Number: 3665063

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.-emergency light hanging by wires in exit hallway by bathrooms

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407497

JACKIES JAMAICA POT

License Type: Food

996 DERBYSHIRE RD , DAYTONA BEACH 32117

Insp Date: 03/25/2026

Inspection Number: 3653747

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2026-03-25:

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.