



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Bay

License Number: 1300134

ANGELOS STEAK PIT

License Type: Food

9527 W HWY 98 , PANAMA CITY BCH 74149

Insp Date: 04/06/2026

Inspection Number: 3668073

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class in seafood room in recharge zone. ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1304603

BOON DOCKS RESTAURANT

License Type: Food

14854 BAY VIEW CIR , PANAMA CITY BCH 32413

Insp Date: 04/02/2026

Inspection Number: 3683034

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher in prep room in recharge zone. Fire protection service switched out extinguisher during inspection. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Bay

License Number: 1305344 **BIG EASY**
License Type: Food 8744 THOMAS DR , PANAMA CITY BEACH 32408

Insp Date: 04/07/2026 Inspection Number: 3689592 Insp Type: Routine - Food Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone, next to back door area. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505941 **FIRE UP A COAL OVEN PIZZARIA**
License Type: Food 195 MALABAR ROAD N.W. STE 101 , PALM BAY 32907

Insp Date: 04/07/2026 Inspection Number: 3683728 Insp Type: Routine - Food Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Outlet near pizza oven missing plastic cover plate.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1551002 **DELTA PRIME**
License Type: Food 3085 JUPITER BLVD SE , PALM BAY 32909

Insp Date: 04/03/2026 Inspection Number: 1332904 Insp Type: Food-Licensing Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only. Requires a type K fire extinguisher and a portable 2A:10B:C. Prior to operation.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Brevard

License Number: 1551002

DELTA PRIME

License Type: Food

3085 JUPITER BLVD SE , PALM BAY 32909

Insp Date: 04/03/2026

Inspection Number: 1332904

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with hood suppression system installed but requires service, last service completed in 2024. Hood working cylinder gauge in green. Notified Fire AHJ. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1507350

CAFE MARINA WINE AND DELI

License Type: Food

2137 N COURTENAY PKWY, UNIT 31 , MERRITT ISLAND 32953

Insp Date: 04/07/2026

Inspection Number: 3681794

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer unit **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Charlotte

License Number: 1801695

QDOBA MEXICAN EATS

License Type: Food

1804 TAMIAMI TRL UNIT E1 , PORT CHARLOTTE 33948

Insp Date: 04/06/2026

Inspection Number: 3655767

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Observed the rear exit blocked by a rolling wire cart.The cart was removed from the exit path.
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1801157

CHECKERS DRIVE IN REST # 179

License Type: Food

1793 TAMIAMI TRL 179-C , MURDOCK 33948

Insp Date: 04/02/2026

Inspection Number: 3662104

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.Observed the rear exit door locked.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Columbia

License Number: 2200725

JAFHEW CAFE AT RUM 138

License Type: Food

2070 SW COUNTY RD 138 , FORT WHITE 32038

Insp Date: 04/09/2026

Inspection Number: 3641496

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher to door leading to outside.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337172

SHISHKABOB MEDITERRANEAN CUISINE

License Type: Food

9420 NW 41 ST UNIT 113 , DORAL 33178

Insp Date: 04/06/2026

Inspection Number: 3661971

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. **Repeat Violation**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2338723

DELANO - 4TH FLOOR

License Type: Food

1685 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 04/09/2026

Inspection Number: 3583516

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed the hotel has 4 boilers with 475,000 BTUs.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2338724

DELANO GIGI BASEMENT KITCHEN

License Type: Food

1685 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 04/09/2026

Inspection Number: 3590028

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. The hotel has 4 boilers with 745,000 BTUs.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2338725

DELANO GIGI LEVEL 1 AND MEZZ

License Type: Food

1685 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 04/09/2026

Inspection Number: 3589908

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed the hotel has 4 boilers with 745,000 BTUs.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2338701

CHURROMANIA/DALE DOG/LA FAMILIA BAR

License Type: Food

1900 NW 37 AVE MC 116 & 121 , MIAMI 33125

Insp Date: 04/02/2026

Inspection Number: 3691429

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2338703

LA BIRRA BAR

License Type: Food

1900 NW 37 AVE MC116 & 121 ZONE 2, MIAMI 33125

Insp Date: 04/02/2026

Inspection Number: 3691431

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2338709

WEST CLUB NORTH LOUNGE

License Type: Food

1900 NW 37 AVE AREA 32 LVL 150 , MIAMI 33125

Insp Date: 04/02/2026

Inspection Number: 3691558

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2338711

WEST CLUB LOUNGE

License Type: Food

1900 NW 37 AVE AREA 34 LVL 150 , MIAMI 33125

Insp Date: 04/03/2026

Inspection Number: 3691559

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2338712

WEST CLUB NW LOUNGE

License Type: Food

1900 NW 37 AVE AREA 33, 35 LVL 150 , MIAMI 33125

Insp Date: 04/03/2026

Inspection Number: 3691560

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 04/11/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2338718

HOME CLUBHOUSE KITCHEN

License Type: Food

501 MARLINS WAY , MIAMI 33125

Insp Date: 04/06/2026

Inspection Number: 3693579

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337234

CASA TULIA

License Type: Food

334 20 STREET , MIAMI BEACH 33139

Insp Date: 04/03/2026

Inspection Number: 3678613

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boilers with an input of

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2330048

VALE FOOD CO

License Type: Food

9537 S DIXIE HWY , MIAMI 33156

Insp Date: 04/09/2026

Inspection Number: 3645307

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed convection burners used for cooking in establishment not under hood. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2652622

EL RINCONCITO DE LIMA PERUVIAN CUISINE 2

License Type: Food

7300 BEACH BLVD UNIT 4 , JACKSONVILLE 32216

Insp Date: 04/03/2026

Inspection Number: 1330135

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane stored inside food trailer larger than 2.7 lb. Manager removed **Corrected On-Site** **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Highlands

License Number: 3801116

CANG TONG

License Type: Food

110 SEBRING SQUARE , SEBRING 33870

Insp Date: 04/06/2026

Inspection Number: 3695081

Insp Type: Complaint Full

Disposition: Emergency order recommended

Violation Code

Observation

Violation Citation

47-02-4	Observed: Observed scorch marks around electrical outlet. For reporting purposes only.Observed scorch marks around electrical outlet in the dish room. Priority: Reporting	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 3801116

CANG TONG

License Type: Food

110 SEBRING SQUARE , SEBRING 33870

Insp Date: 04/07/2026

Inspection Number: 3695081

Insp Type: Complaint Full

Disposition: Emergency Order Callback Not Complied

Violation Code

Observation

Violation Citation

47-02-4	- From initial inspection : Observed: Observed scorch marks around electrical outlet. For reporting purposes only.Observed scorch marks around electrical outlet in the dish room. Priority: Reporting - From follow-up inspection 2026-04-07: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Highlands

License Number: 3801116

CANG TONG

License Type: Food

110 SEBRING SQUARE , SEBRING 33870

Insp Date: 04/08/2026

Inspection Number: 3695081

Insp Type: Complaint Full

Disposition: Emergency Order Callback
Not Complied

Violation Code

Observation

Violation Citation

47-02-4	- From initial inspection : Observed: Observed scorch marks around electrical outlet. For reporting purposes only.Observed scorch marks around electrical outlet in the dish room. Priority: Reporting - From follow-up inspection 2026-04-07: **Time Extended** - From follow-up inspection 2026-04-08: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 3801116

CANG TONG

License Type: Food

110 SEBRING SQUARE , SEBRING 33870

Insp Date: 04/09/2026

Inspection Number: 3695081

Insp Type: Complaint Full

Disposition: Emergency Order Callback
Not Complied

Violation Code

Observation

Violation Citation

47-02-4	- From initial inspection : Observed: Observed scorch marks around electrical outlet. For reporting purposes only.Observed scorch marks around electrical outlet in the dish room. Priority: Reporting - From follow-up inspection 2026-04-07: **Time Extended** - From follow-up inspection 2026-04-08: **Time Extended** - From follow-up inspection 2026-04-09: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hillsborough

License Number: 3912829

METRO DELI

License Type: Food

11225 RACE TRACK RD , TAMPA 33626

Insp Date: 04/08/2026

Inspection Number: 3634055

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.2 sandwich press stored on behind front service counter. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 4508439

ROBATA JAPANESE STEAKHOUSE

License Type: Food

1500 OAKLEY SEAVER DR #5 , CLERMONT 34711

Insp Date: 04/08/2026

Inspection Number: 3673504

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.-back door, operator cleared path **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 4608018

CHUCK LAGER LEGENDARY KITCHEN FORT MYERS

License Type: Food

9980 UNIVERSITY PLAZA DR , FORT MYERS 33913

Insp Date: 04/06/2026

Inspection Number: 3695139

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Near ice machine, right side entrance to kitchen.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lee

License Number: 4604100

FORTUNE COOKIE

License Type: Food

4017 PALM BEACH BLVD , FORT MYERS 33916

Insp Date: 04/09/2026

Inspection Number: 3690493

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone near kitchen exit door. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4606886

HABANEROS MEXICAN GRILL

License Type: Food

547 PINE ISLAND RD , NORTH FORT MYERS 33903

Insp Date: 04/08/2026

Inspection Number: 3675725

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed LP gas tank larger than 2.7 lbs connected and being used for cooking equipment inside kitchen area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lee

License Number: 4607657

EL TIKAL INC

License Type: Food

475 MARSH AVE , FORT MYERS 33905

Insp Date: 04/09/2026

Inspection Number: 3684193

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed LP tank larger than 2.7 lb inside in use for steam table at front counter.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 4605759

BEACHES BOARDWALK CAFE

License Type: Food

11000 TERMINAL ACCESS RD SWFIA , FORT MYERS 33913

Insp Date: 04/09/2026

Inspection Number: 3647737

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. At entrance to kitchen. - From follow-up inspection 2026-04-09: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 4605759

BEACHES BOARDWALK CAFE

License Type: Food

11000 TERMINAL ACCESS RD SWFIA , FORT MYERS 33913

Insp Date: 04/08/2026

Inspection Number: 3647737

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At entrance to kitchen.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Monroe

License Number: 5428100

PARTY CAKE BAKERY

License Type: Food

103200 OVERSEAS HWY UNITS 13-14 , KEY LARGO 33037

Insp Date: 04/08/2026

Inspection Number: 3674466

Insp Type: Routine - Food

Disposition: Emergency recommended

order

Violation Code

Observation

Violation Citation

46-04-4	Exit door locked. For reporting purposes only. Observed ladder and cleaning supplies blocking back door next to oven.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 5501118

CINNAMON BEAR COUNTRY STORE

License Type: Food

107 CENTRE ST , FERNANDINA BEACH 32034

Insp Date: 04/07/2026

Inspection Number: 3593227

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.Back exit door blocked by bins and miscellaneous items.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 5811597

MING'S BISTRO

License Type: Food

1212 WOODWARD ST #6 , ORLANDO 32803

Insp Date: 04/08/2026

Inspection Number: 3677737

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.Exit door by server front counter area blocked by chairs and card board	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Osceola

License Number: 5911696

DUNKIN DONUTS

License Type: Food

2435 OLD CANOE CREEK RD , SAINT CLOUD 34772

Insp Date: 04/03/2026

Inspection Number: 3600283

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back door blocked by garbage can Operator removed **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 6021370

AL REEF HOOKAH & GRILL

License Type: Food

99 SE MIZNER BLVD STE 116 , BOCA RATON 33432

Insp Date: 04/07/2026

Inspection Number: 3614104

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at kitchen fire extinguisher	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 6150636

OLD BAY CAFE LLC

License Type: Food

9533 LITTLE RD , NEW PORT RICHEY 34655

Insp Date: 04/03/2026

Inspection Number: 1329777

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator deep frying fish.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6218551

PIN ON GRAND

License Type: Food

2458-2462 CENTRAL AVE , ST. PETERSBURG 33712

Insp Date: 04/07/2026

Inspection Number: 3673190

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher at back door next to cook line in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6214974

NOVU AT PONCE

License Type: Food

95 CENTRAL AVE , ST. PETERSBURG 33701

Insp Date: 04/07/2026

Inspection Number: 3670640

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher next to bar outside patio. Gauge in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 04/11/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6214974

NOVU AT PONCE

License Type: Food

95 CENTRAL AVE , ST. PETERSBURG 33701

Insp Date: 04/07/2026

Inspection Number: 3670640

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Grease build up on walls. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6217885

NITALLY'S THAIMEX CUISINE

License Type: Food

1163 DR MLK JR STREET , ST. PETERSBURG 33701

Insp Date: 04/03/2026

Inspection Number: 3680083

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 propane tanks larger than 2.7 lbs observed across from bar. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Polk

License Number: 6303865

SUBWAY #7066

License Type: Food

1509 HWY 98 S #8 , LAKELAND 16551

Insp Date: 04/02/2026

Inspection Number: 3628377

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Walk-in freezer light hanging by wires. Manager has contacted DM for repair. ****Corrective Action Taken****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6701636

COLD BREEZE

License Type: Food

3026 GULF BREEZE PKWY , GULF BREEZE 32563

Insp Date: 04/07/2026

Inspection Number: 3610848

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed small fryer in back kitchen in use. Educated operator to reach out to AHJ fire marshal for further guidance.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Sarasota

License Number: 6806149

MERCI CAFE

License Type: Food

6112 S TAMIAMI TRL , SARASOTA 34231

Insp Date: 04/06/2026

Inspection Number: 3655668

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.Observed exit door locked with chain on side dining room exit. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6803876

SONNYS BBQ 109

License Type: Food

3926 S TAMIAMI TRL , SARASOTA 34231

Insp Date: 04/02/2026

Inspection Number: 3668960

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed extinguisher on floor near office.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903982

MEXICAN RESTAURANT LOS MONDRAGON

License Type: Food

2960 W SR.426 # 1000 , OVIEDO 32765

Insp Date: 04/02/2026

Inspection Number: 3670639

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.By front door - From follow-up inspection 2026-04-02: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Taylor

License Number: 7200350

3 NELSONS BURGERS & WRAPS LLC

License Type: Food

102 E ASH ST , PERRY 32347

Insp Date: 04/02/2026

Inspection Number: 3695013

Insp Type: Complaint Full

Disposition: Emergency recommended

order

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Chew marks on extension cord near water heater closet.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407232

PO REDBOWL LLC

License Type: Food

1820 DUNLAWTON AVE #105 , PORT ORANGE 32127

Insp Date: 04/09/2026

Inspection Number: 3668734

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-side fire exit door near restrooms

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407942

5TH ELEMENT INDIAN CATERING

License Type: Food

1484 W INTERNATIONAL SPEEDWAY BLVD , DAYTONA BEACH 32114

Insp Date: 04/08/2026

Inspection Number: 3670118

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-04-4

Hasp on front door and bolt type lock on rear door. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7406995

PEPPERS MEXICAN GRILL AND CANTINA

License Type: Food

794 S ATLANTIC AVE , ORMOND BEACH 32176

Insp Date: 04/06/2026

Inspection Number: 3633510

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-02-4	Observed scorch marks around electrical outlet. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 7407799

JET'S PIZZA - PORT ORANGE

License Type: Food

3813 CLYDE MORRIS BLVD #103 , PORT ORANGE 32129

Insp Date: 04/07/2026

Inspection Number: 3624175

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4	Gasoline tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.-large gas powered generator inside the building, located inside restroom.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 7406364

OMG BISTRO

License Type: Food

2032 S RIDGEWOOD AVE STE 1 & 2 , SOUTH DAYTONA 32119

Insp Date: 04/06/2026

Inspection Number: 3692979

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4	Exit door locked. For reporting purposes only. labeled exit between restrooms and storage room locked, no key on site.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7407933

THAI MANGO

License Type: Food

1714 SR 44 , NEW SMYRNA BEACH 32168

Insp Date: 04/02/2026

Inspection Number: 3694790

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to back door
- From follow-up inspection 2026-04-02: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.