



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Alachua

License Number: 1103628

SENSEI ASIAN BISTRO

License Type: Food

4860 SW 31 PL #10 , GAINESVILLE 32608

Insp Date: 04/17/2026

Inspection Number: 3665907

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-06-4

Portable fire extinguisher is inaccessible. For reporting purposes only. Observed : the K Class Fire extinguisher by the back door was inaccessible by being covered with jackets and hats. These items were adjusted to give visibility. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1150395

R U HUNGRY WORKING KICHEN COMMISSARY

License Type: Food

219 NW 10 AVE , GAINESVILLE 32601

Insp Date: 04/13/2026

Inspection Number: 1328436

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.15-20lb propane tank inside back area of truck.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Bay

License Number: 1304520

BAMBOO GRILL/OASIS BAR

License Type: Food

11127 FRONT BEACH RD , PANAMA CITY BEACH 32407

Insp Date: 04/10/2026

Inspection Number: 3668390

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. No extinguisher in kitchen area. Observed fire extinguisher sign by fryers.
****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305821

SPRINGHILL SUITES PANAMA CITY BEACH BEACHFRONT

License Type: Food

12513 FRONT BEACH RD , PANAMA CITY BEACH 32407

Insp Date: 04/14/2026

Inspection Number: 3652478

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Bay

License Number: 1302920

MIKE'S CAFE AND OYSTER BAR

License Type: Food

17554 FRONT BEACH RD , PANAMA CITY BCH 32050

Insp Date: 04/14/2026

Inspection Number: 3677691

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Inside storage room under office. Moved outside during inspection. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305468

JIN JIN SUPER KING BUFFET

License Type: Food

9802 FRONT BEACH RD , PANAMA CITY BEACH 32407

Insp Date: 04/14/2026

Inspection Number: 3695700

Insp Type: Complaint Partial

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

49-02-4

Flammables stored/debris present in attic/basement. For reporting purposes only. Can of gasoline in attic storage area.

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 1505941

FIRE UP A COAL OVEN PIZZARIA

License Type: Food

195 MALABAR ROAD N.W. STE 101 , PALM BAY 32907

Insp Date: 04/15/2026

Inspection Number: 3683728

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Outlet near pizza oven missing plastic cover plate. - From follow-up inspection 2026-04-15: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Charlotte

License Number: 1801867

FIREHOUSE SUBS HERITAGE PLAZA

License Type: Food

18500 VETERANS BLVD , PORT CHARLOTTE 33954

Insp Date: 04/10/2026

Inspection Number: 3665424

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.Observed the rear exit pathway blocked by discarded cardboard boxes.The operator removed the boxes from the doorway. **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 1901381

SALTY HOOK SANDWICH SHOP

License Type: Food

9691 WEST FT ISLAND TRAIL , CRYSTAL RIVER 34429

Insp Date: 04/16/2026

Inspection Number: 3692105

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment (multiple fryers) producing grease laden vapors/smoke with no hood suppression system installed in kitchen/prep area. Notified Fire AHJ. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Clay

License Number: 2001277

STONE'S IRISH PUB

License Type: Food

323 NE COMMERCIAL CIR , KEYSTONE HEIGHTS 32656

Insp Date: 04/16/2026

Inspection Number: 3655803

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher on wall of kitchen area in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2050180

PILON AUTHENTIC CUBAN

License Type: Food

280 BLANDING BLVD STE 103 , ORANGE PARK 32073

Insp Date: 04/13/2026

Inspection Number: 1327101

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher is in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Collier

License Number: 2103530

ZACATECAS RESTAURANT TAQUERIA

License Type: Food

105 S 1 ST UNIT 6 , IMMOKALEE 34142

Insp Date: 04/14/2026

Inspection Number: 3676247

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

49-05-4	Flammables stored near a source of ignition. For reporting purposes only. Observed lighter fluid store on dry goods shelf.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2338539

MAE'S ROOM /DRINKING PIG/CHUGGIES

License Type: Food

3444 MAIN HWY STE 16 , MIAMI 33133

Insp Date: 04/16/2026

Inspection Number: 3695827

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Observed 4 propane tanks stored in parking garage storage area of establishment.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2330341

LUCKY 9 BARTENDING & CONSULTING INC

License Type: Food

528 SW 9 AVE , MIAMI 33130

Insp Date: 04/17/2026

Inspection Number: 1134703

Insp Type: Food-Licensing Inspection

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed Portable fire extinguisher gauge in red zone.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2338728

SW PANTRY 2

License Type: Food

1900 NW 37 AVE EVENT LEVEL 000 AREA 3, MIAMI 33125

Insp Date: 04/10/2026

Inspection Number: 3691685

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2338729

NW PANTRY

License Type: Food

1900 NW 37 AVE EVENT LEVEL 000 AREA 4 (PANTRY 1), MIAMI 33125

Insp Date: 04/10/2026

Inspection Number: 3691686

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2337151

CITY FOOD HALL

License Type: Food

9420 NW 41 STREET , DORAL 33178

Insp Date: 04/13/2026

Inspection Number: 3692975

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible.	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	--	--

License Number: 2329788

BEFIT NUTRITION

License Type: Food

12320 SW 132 CT , MIAMI 33186

Insp Date: 04/16/2026

Inspection Number: 1133913

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed back exit door blocked by dish rack.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2334383

PITZZA AT IRONSIDE

License Type: Food

7580 NE 4 CT 118 , MIAMI 33138

Insp Date: 04/15/2026

Inspection Number: 3674524

Insp Type: Routine - Food

Disposition: Emergency recommended

order

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed use of burner to cook salmon and chicken, no hood system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334383

PITZZA AT IRONSIDE

License Type: Food

7580 NE 4 CT 118 , MIAMI 33138

Insp Date: 04/16/2026

Inspection Number: 3674524

Insp Type: Routine - Food

Disposition: Emergency Order Callback Time Extension

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed use of burner to cook salmon and chicken, no hood system. - From follow-up inspection 2026-04-16: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2330048

VALE FOOD CO

License Type: Food

9537 S DIXIE HWY , MIAMI 33156

Insp Date: 04/10/2026

Inspection Number: 3645307

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

45-04-4	<p>- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed convection burners used for cooking in establishment not under hood. **Repeat Violation** - From follow-up inspection 2026-04-10: **Time Extended**</p>	<p>Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
---------	---	---

License Number: 2615282

CATULLO'S ITALIAN

License Type: Food

1650 SAN PABLO RD S #2, JACKSONVILLE 32224

Insp Date: 04/17/2026

Inspection Number: 3679277

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4	<p>Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two LP tanks near men's restroom. **Repeat Violation**</p>	<p>Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
---------	---	---



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2612624

HURRICANE GRILL AND WINGS

License Type: Food

1615 HENDRICKS AVE STE 2 , JACKSONVILLE 32207

Insp Date: 04/13/2026

Inspection Number: 3670933

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.By office	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2607904

PIER 1515

License Type: Food

1515 PRUDENTIAL DR , JACKSONVILLE 32207

Insp Date: 04/16/2026

Inspection Number: 3672415

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Temporary cook line at dining area across bar, cooking eggs, employe removed everything by the time I washed my hands **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2613836

MAA KITCHEN

License Type: Food

8206 PHILLIPS HWY ST 25 , JACKSONVILLE 32256

Insp Date: 04/15/2026

Inspection Number: 3660844

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Observed two LP tanks 20lb in bar area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3600469

CULVER'S RESTAURANT

License Type: Food

1030 W SUGARLAND HWY , CLEWISTON 33440

Insp Date: 04/16/2026

Inspection Number: 3695924

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only: at entry.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hernando

License Number: 3750495

WEENIES ON THE WATER

License Type: Food

410 BROAD STREET , BROOKSVILLE 34604

Insp Date: 04/15/2026

Inspection Number: 1333405

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3801116

CANG TONG

License Type: Food

110 SEBRING SQUARE , SEBRING 33870

Insp Date: 04/10/2026

Inspection Number: 3695081

Insp Type: Complaint Full

Disposition: Emergency Order Callback Not Complied

Violation Code

Observation

Violation Citation

47-02-4

- From initial inspection : Observed: Observed scorch marks around electrical outlet. For reporting purposes only.Observed scorch marks around electrical outlet in the dish room. Priority: Reporting - From follow-up inspection 2026-04-07: ****Time Extended**** - From follow-up inspection 2026-04-08: ****Time Extended**** - From follow-up inspection 2026-04-09: ****Time Extended**** - From follow-up inspection 2026-04-10: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Highlands

License Number: 3801116

CANG TONG

License Type: Food

110 SEBRING SQUARE , SEBRING 33870

Insp Date: 04/13/2026

Inspection Number: 3695081

Insp Type: Complaint Full

Disposition: Emergency Order Callback
Not Complied

Violation Code

Observation

Violation Citation

47-02-4

- From initial inspection : Observed: Observed scorch marks around electrical outlet. For reporting purposes only.Observed scorch marks around electrical outlet in the dish room. Priority: Reporting - From follow-up inspection 2026-04-07: ****Time Extended**** - From follow-up inspection 2026-04-08: ****Time Extended**** - From follow-up inspection 2026-04-09: ****Time Extended**** - From follow-up inspection 2026-04-10: ****Time Extended**** - From follow-up inspection 2026-04-13: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3801116

CANG TONG

License Type: Food

110 SEBRING SQUARE , SEBRING 33870

Insp Date: 04/14/2026

Inspection Number: 3695081

Insp Type: Complaint Full

Disposition: Emergency Order Callback
Not Complied

Violation Code

Observation

Violation Citation

47-02-4

- From initial inspection : Observed: Observed scorch marks around electrical outlet. For reporting purposes only.Observed scorch marks around electrical outlet in the dish room. Priority: Reporting - From follow-up inspection 2026-04-07: ****Time Extended**** - From follow-up inspection 2026-04-08: ****Time Extended**** - From follow-up inspection 2026-04-09: ****Time Extended**** - From follow-up inspection 2026-04-10: ****Time Extended**** - From follow-up inspection 2026-04-13: ****Time Extended**** - From follow-up inspection 2026-04-14: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Highlands

License Number: 3801116

CANG TONG

License Type: Food

110 SEBRING SQUARE , SEBRING 33870

Insp Date: 04/15/2026

Inspection Number: 3695081

Insp Type: Complaint Full

Disposition: Emergency Order Callback
Complied

Violation Code

Observation

Violation Citation

47-02-4	- From initial inspection : Observed: Observed scorch marks around electrical outlet. For reporting purposes only.Observed scorch marks around electrical outlet in the dish room. Priority: Reporting - From follow-up inspection 2026-04-07: **Time Extended** - From follow-up inspection 2026-04-08: **Time Extended** - From follow-up inspection 2026-04-09: **Time Extended** - From follow-up inspection 2026-04-10: **Time Extended** - From follow-up inspection 2026-04-13: **Time Extended** - From follow-up inspection 2026-04-14: **Time Extended** - From follow-up inspection 2026-04-15: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 4101322

(THE) SOURCE

License Type: Food

1015 COMMERCE AVE , VERO BEACH 32960

Insp Date: 04/15/2026

Inspection Number: 1133928

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.Under 3 bay sink	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Leon

License Number: 4703660

MOE'S SOUTHWEST GRILL #100683

License Type: Food

3437 BANNERMAN RD UNIT 101 , TALLAHASSEE 32312

Insp Date: 04/16/2026

Inspection Number: 3679528

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. On floor.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5150455

TAQUERIA MI REINA

License Type: Food

1880 63RD AVE E , BRADENTON 34203

Insp Date: 04/17/2026

Inspection Number: 1331706

Insp Type: Routine - Food

Disposition: Emergency order recommended

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. BasicObserved: Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ.For reporting purposes only.As a repeat violation, the importance of following proper protocol with this violation was reinforced with the operator.employe ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Marion

License Number: **GRAB N GO**
 License Type: Food 6157 SE BASELINE RD , BELLEVIEW 34420

Insp Date: 04/16/2026 Inspection Number: 3695509 Insp Type: Food-Licensing Inspection Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. In kitchen area.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5815077 **MAGURO**
 License Type: Food 1311 FLORIDA MALL AVE , ORLANDO 32809

Insp Date: 04/16/2026 Inspection Number: 3686585 Insp Type: Routine - Food Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Located in the kitchen.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5812347 **BONEFISH GRILL**
 License Type: Food 5463 ORLANDO GATEWAY CIR #101 , ORLANDO 32812

Insp Date: 04/10/2026 Inspection Number: 3674470 Insp Type: Routine - Food Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Boxes and cart blocked the exit door . **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5809199

CHARLEYS PHILLY STEAKS

License Type: Food

2567 S KIRKMAN RD , ORLANDO 32811

Insp Date: 04/13/2026

Inspection Number: 3691409

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4	Exit door locked. For reporting purposes only.-rear door	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 5811597

MING'S BISTRO

License Type: Food

1212 WOODWARD ST #6 , ORLANDO 32803

Insp Date: 04/10/2026

Inspection Number: 3677737

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.Exit door by server front counter area blocked by chairs and card board - From follow-up inspection 2026-04-10: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 5812447

FIVE GUYS BURGERS & FRIES

License Type: Food

6125 S SEMORAN BLVD STE 108 , ORLANDO 32822

Insp Date: 04/13/2026

Inspection Number: 3675892

Insp Type: Routine - Food

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.By back doorWork order in **Corrective Action Taken** - From follow-up inspection 2026-03-11: **Time Extended** - From follow-up inspection 2026-04-13: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6022029

DINA'S VEGAN DELI & DESSERTS

License Type: Food

1880 W 10 ST BLDG 106 , RIVIERA BEACH 33404

Insp Date: 04/17/2026

Inspection Number: 3593674

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Flat top - as per operator grape seed oil used ;

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6215987

PIEROGI GRILL & STEAKHOUSE

License Type: Food

1535 GULF TO BAY BLVD , CLEARWATER 33755

Insp Date: 04/16/2026

Inspection Number: 3691598

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked.in deli area For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6209478

SALTY'S BEACH BAR

License Type: Food

5700 GULF BLVD , ST. PETE BEACH 33706

Insp Date: 04/14/2026

Inspection Number: 3669631

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

49-01-4	Flammables stored/debris present in bar room. For reporting purposes only. Propane tanks store in bar area.	Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
---------	---	---

License Number: 6205716

PAJANO'S PIZZA AND SUBS

License Type: Food

1305 GULF BLVD , INDIAN ROCKS BEACH 33785

Insp Date: 04/17/2026

Inspection Number: 3646336

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door by bathroom is blocked by pizza boxes.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Putnam

License Number: 6400910

STEAMBOAT WILLIES

License Type: Food

309 SAINT JOHNS AVE , PALATKA 32177

Insp Date: 04/17/2026

Inspection Number: 3656755

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Flat top counter grill used to cook burgers not under hood system.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6903953

REY'S CUBAN CAFE

License Type: Food

7800 US 17-92 S #194 , FERN PARK 32730

Insp Date: 04/13/2026

Inspection Number: 3674042

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.In mop sink. Operator removed to outside **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 7406465

LITTLE CAESARS

License Type: Food

328 E NEW YORK AVE , DELAND 32724

Insp Date: 04/16/2026

Inspection Number: 3686625

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-04-4	Exit door locked. For reporting purposes only. Operator opened lock. . **Corrected On-Site** ***Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Report Date: 04/18/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7406654

SONIC DRIVE IN 5404

License Type: Food

2020 S RIDGEWOOD AVE , SOUTH DAYTONA 32119

Insp Date: 04/15/2026

Inspection Number: 3695678

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.Next to back door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406442

STEWIE'S PIZZA

License Type: Food

2120 SAXON BLVD SUITE 206A , DELTONA 32725

Insp Date: 04/10/2026

Inspection Number: 3667368

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-rear kitchen door blocked by wood, operator removed **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7407666

4RIVERS SMOKEHOUSE

License Type: Food

1866 VICTORY CIR , DAYTONA BEACH 32114

Insp Date: 04/10/2026

Inspection Number: 3670737

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-partial blocked by chairs in dining
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406995

PEPPERS MEXICAN GRILL AND CANTINA

License Type: Food

794 S ATLANTIC AVE , ORMOND BEACH 32176

Insp Date: 04/15/2026

Inspection Number: 3633510

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

47-02-4

- From initial inspection : Observed scorch marks around electrical outlet. For reporting purposes only. - From follow-up inspection 2026-04-15:

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.