



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Bay

License Number: 1304822

BEACH PIZZA

License Type: Food

8815 THOMAS DR STE B , PANAMA CITY BEACH 32408

Insp Date: 04/30/2026

Inspection Number: 3601080

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by mixer in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2101883

ROMA IN LIMA PIZZA & CUISINE LLC

License Type: Food

1025 W MAIN ST , IMMOKALEE 34142

Insp Date: 05/01/2026

Inspection Number: 3673357

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed chairs stored in fire exit hallway. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Collier

License Number: 2103146

LA PESCHERIA

License Type: Food

474-476 5 AVE SOUTH , NAPLES 34102

Insp Date: 05/01/2026

Inspection Number: 3657500

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed their marked exit door in the front locked.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2101883

ROMA IN LIMA PIZZA & CUISINE LLC

License Type: Food

1025 W MAIN ST , IMMOKALEE 34142

Insp Date: 05/01/2026

Inspection Number: 3673357

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed fire door locked. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 05/02/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2330890

ONYX LUXURY PRODUCTION

License Type: Food

2717 SW 142 AVE , MIAMI 33175

Insp Date: 04/28/2026

Inspection Number: 3677139

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed for exit door near reach in coolers and freezers blocked by boxes of alcohol products.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324810

LOS VERDES

License Type: Food

2426 SW 137 AVE , MIAMI 33175

Insp Date: 04/30/2026

Inspection Number: 3657800

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed the exit door in the dry store area blocked by boxes of bottled beer and cases of soda.
Repeat Violation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2324810

LOS VERDES

License Type: Food

2426 SW 137 AVE , MIAMI 33175

Insp Date: 04/30/2026

Inspection Number: 3657800

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed exit door near walk in cooler latch locked.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335806

MIA MARKET

License Type: Food

140 NE 39 ST #241 , MIAMI 33137

Insp Date: 04/24/2026

Inspection Number: 3674993

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed counter top fryers with no hood system at MIAMI NICE. - From follow-up inspection 2026-04-24: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2335805

MIA MARKET

License Type: Food

140 NE 39 ST #241 , MIAMI 33137

Insp Date: 04/24/2026

Inspection Number: 3674788

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed at Jaffa, mini fryer in use; no hood system. - From follow-up inspection 2026-04-24: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612833

HYATT REGENCY JACKSONVILLE RIVERFRONT -DANIEL BUILDING ANNEX

License Type: Food

225 E COASTLINE DR , JACKSONVILLE 32202

Insp Date: 04/28/2026

Inspection Number: 3683347

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. One by hand sink next to cook line

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hillsborough

License Number: 3952618

LOS SUAREZ

License Type: Food

6601 HANLEY RD , TAMPA 33634

Insp Date: 04/24/2026

Inspection Number: 1324331

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Operator added a table top fryer with two baskets at the back of the food truck. Fryer not placed under hood suppression system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5103322

SUBWAY 986

License Type: Food

737 8TH AVE. WEST UNIT 130, PALMETTO 34221

Insp Date: 04/27/2026

Inspection Number: 3696435

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.Observed two fire extinguishers stored on floor of kitchen and not mounted on wall.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Monroe

License Number: 5401533

WENDY'S #203

License Type: Food

5150 OVERSEAS HWY , MARATHON 02624

Insp Date: 05/01/2026

Inspection Number: 3681427

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Located under handwashing sink in kitchen

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500878

NEW CHINA

License Type: Food

1013 AMELIA PLAZA , FERNANDINA BEACH 32034

Insp Date: 04/24/2026

Inspection Number: 3689488

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Emergency exit door in dry storage room blocked by cases/bags of food products.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Okaloosa

License Number: 5603962

JIMMY BUFFETT'S MARGARITAVILLE CAFE 2ND FLOOR

License Type: Food

76 HARBOR BLVD , DESTIN 32541

Insp Date: 04/30/2026

Inspection Number: 3687666

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5816590

ZESTY SIPS & BITES

License Type: Food

1020 W MICHIGAN ST , ORLANDO 32805

Insp Date: 04/29/2026

Inspection Number: 3696332

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5813555

ZEN DUMPLING

License Type: Food

423 N ALAFAYA TRL , ORLANDO 32828

Insp Date: 04/24/2026

Inspection Number: 3657480

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Blocked with 2 big trash can . **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811354

CATERING BY MOTTI

License Type: Food

6807 VISITORS CIR UNIT I , ORLANDO 32819

Insp Date: 04/29/2026

Inspection Number: 1133905

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Gas powered pressure washer stored in building **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 05/02/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5807590

BAMBU MEXICAN RESTAURANT INC

License Type: Food

5731 S ORANGE BLOSSOM TRL , ORLANDO 32839

Insp Date: 04/24/2026

Inspection Number: 3672978

Insp Type: Routine - Food

Disposition: Emergency Order Callback
Complied

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. - From follow-up inspection 2026-04-24: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6019343

OAKS AT BOCA RATON POA INC

License Type: Food

9950 BRIGDEBROOK DR , BOCA RATON 33496

Insp Date: 05/01/2026

Inspection Number: 3684569

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Ansul fire extinguisher sitting on the floor by the front bar

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pasco

License Number: 6113880

JUST SMASH

License Type: Food

9754 LITTLE RD , NEW PORT RICHEY 34654

Insp Date: 05/01/2026

Inspection Number: 3695354

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 47-03-4 | Observed electrical wiring in disrepair. For reporting purposes only. In the women's bathroom the light switch is hanging down on the wall. | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|

License Number: 6212995

WINGHOUSE BAR AND GRILL

License Type: Food

7369 ULMERTON RD , LARGO 33771

Insp Date: 04/29/2026

Inspection Number: 3688134

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 45-02-4 | Portable fire extinguisher gauge on left side of cooler door in red zone. For reporting purposes only. | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|

License Number: 6212995

WINGHOUSE BAR AND GRILL

License Type: Food

7369 ULMERTON RD , LARGO 33771

Insp Date: 05/01/2026

Inspection Number: 3688134

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 45-02-4 | - From initial inspection : Portable fire extinguisher gauge on left side of cooler door in red zone. For reporting purposes only. - From follow-up inspection 2026-05-01: **Time Extended** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Putnam

License Number: 6400879

THIS & THAT CAFE

License Type: Food

700 ST JOHNS AVE , PALATKA 32177

Insp Date: 05/01/2026

Inspection Number: 3689152

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 45-04-4 | Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Flat top griddle next to oven used for cooking egg and sausages not under hood system. **Repeat Violation** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|

License Number: 6805893

SARA'S ITALIAN KITCHEN

License Type: Food

6538 GATEWAY AVE , SARASOTA 34231

Insp Date: 04/28/2026

Inspection Number: 3675268

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 46-04-4 | Exit door locked. For reporting purposes only.Observed their back exit door locked.Operator locked it. **Corrected On-Site** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|

License Number: 7000414

TEQUILA CANTINA MEXICAN KITCHEN

License Type: Food

3551 WEDGEWOOD LN , THE VILLAGES 32162

Insp Date: 05/01/2026

Inspection Number: 3634051

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only.Extinguisher on cookline in red zone. | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7405091

CRACKER BARREL #158

License Type: Food

2325 W INTERNATIONAL SPEEDWAY BLVD , DAYTONA BEACH 32114

Insp Date: 04/28/2026

Inspection Number: 3667679

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-exit partial block by cart containers

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407373

HARD DECK TIKI BAR

License Type: Food

2900 BELLEVUE AVE , DAYTONA BEACH 32124

Insp Date: 04/29/2026

Inspection Number: 3668953

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.-2 lp tanks by rear door near water heater

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407134

MCDONALD'S #36016

License Type: Food

131 HOWLAND BLVD , DELTONA 32738

Insp Date: 05/01/2026

Inspection Number: 3696741

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.-rear exit door blocked by large waste cart, operator relocated ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7407497

JACKIES JAMAICA POT

License Type: Food

996 DERBYSHIRE RD , DAYTONA BEACH 32117

Insp Date: 04/30/2026

Inspection Number: 3653747

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2026-03-25: - From follow-up inspection 2026-04-30:

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.