



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Bradford

License Number: 1400225

BLUELINE Q

License Type: Food

15070 US HWY 301 , STARKE 32091

Insp Date: 05/13/2026

Inspection Number: 3684196

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Flat top grill used to cook raw beef on cook line with no hood system. ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506162

CHAMBERLAIN'S GOOD THYMES FAMILY RESTAURANT

License Type: Food

1413 GARDEN ST , TITUSVILLE 32796

Insp Date: 05/12/2026

Inspection Number: 3697258

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.Silver chemical fire extinguisher

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 05/16/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Brevard

License Number: 1507099

SWEET DELIGHT JAMAICAN CUISINE

License Type: Food

4500 DIXIE HWY NE STE 4 AND 5 , PALM BAY 32905

Insp Date: 05/13/2026

Inspection Number: 3697514

Insp Type: Complaint Full

Disposition: Emergency recommended

order

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. 80 B: C extinguisher in recharge status.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1507099

SWEET DELIGHT JAMAICAN CUISINE

License Type: Food

4500 DIXIE HWY NE STE 4 AND 5 , PALM BAY 32905

Insp Date: 05/14/2026

Inspection Number: 3697514

Insp Type: Complaint Full

Disposition: Emergency Order Callback Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. 80 B: C extinguisher in recharge status. - From follow-up inspection 2026-05-14: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1600225

LAS OLAS CO - RIVERSIDE HOTEL

License Type: Food

620 E LAS OLAS BLVD , FORT LAUDERDALE 33301

Insp Date: 05/11/2026

Inspection Number: 3697255

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. At the salad station

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1801999

FUSION CANTINA

License Type: Food

24123 PEACHLAND BLVD UNIT A16-A17 , PORT CHARLOTTE 33954

Insp Date: 05/12/2026

Inspection Number: 3678164

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Observed the rear exit door near the office blocked by furniture.The operator cleared the exit pathway. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1801997

CHEFS

License Type: Food

2150 TAMIAMI TRL #22-24 , PORT CHARLOTTE 33948

Insp Date: 05/11/2026

Inspection Number: 3664671

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Observed the rear exit of the dining room blocked by cardboard boxes.The operator removed all items from the exit path. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2321975

HAVANA BEACH

License Type: Food

740 OCEAN DRIVE , MIAMI BEACH 33139

Insp Date: 05/12/2026

Inspection Number: 3677392

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher located at staircase to kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322028

NEWS CAFE AT OH MEXICO TACO SHOP

License Type: Food

804 OCEAN DR , MIAMI BEACH 33139

Insp Date: 05/14/2026

Inspection Number: 3664252

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher gauge in red zone at kitchen area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326443

SUMAK

License Type: Food

908 71 ST , MIAMI BEACH 33141

Insp Date: 05/13/2026

Inspection Number: 3673646

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed glass door reach in cooler blocking exit path in kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2337173

MARIDILIA RAW BAR

License Type: Food

9420 NW 41 ST UNIT 114 , DORAL 33178

Insp Date: 05/08/2026

Inspection Number: 3685880

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. **Repeat Violation** | Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |
|---------|--|--|

License Number: 2300147

JOES STONE CRABS RESTAURANT

License Type: Food

11 WASHINGTON AVE , MIAMI BEACH 33139

Insp Date: 05/08/2026

Inspection Number: 3683669

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. | Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |
|---------|---|--|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2331522

KNIFE STEAK HOUSE

License Type: Food

1455 1455 NW 107 AVE , DORAL 33172

Insp Date: 05/11/2026

Inspection Number: 3675516

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. | Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |
|---------|---|--|

License Number: 2322028

NEWS CAFE AT OH MEXICO TACO SHOP

License Type: Food

804 OCEAN DR , MIAMI BEACH 33139

Insp Date: 05/15/2026

Inspection Number: 3664252

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 45-02-4 | - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher gauge in red zone at kitchen area. - From follow-up inspection 2026-05-15: Observed fire extinguisher gauge in red zone at kitchen area. **Time Extended** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|



Division of Hotels & Restaurants

Report Date: 05/16/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

DeSoto

License Number: 2400268

KING BUFFET

License Type: Food

1319 E OAK ST , ARCADIA 34266

Insp Date: 05/12/2026

Inspection Number: 3676680

Insp Type: Routine - Food

Disposition: Emergency order recommended

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. By the back door. | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|

License Number: 2400268

KING BUFFET

License Type: Food

1319 E OAK ST , ARCADIA 34266

Insp Date: 05/13/2026

Inspection Number: 3676680

Insp Type: Routine - Food

Disposition: Emergency Order Callback Complied

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 45-02-4 | - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By the back door. - From follow-up inspection 2026-05-13: **Time Extended** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lee

License Number: 4607046

SUJI JAPANESE STEAKHOUSE & SUSHI LOUNGE

License Type: Food

10801 CORKSCREW RD STE 51 , ESTERO 33928

Insp Date: 05/12/2026

Inspection Number: 3689160

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed garbage can in front of fire escape in the hallway next to the restrooms, operator moved can. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605425

WENDY'S

License Type: Food

2501 LEE BLVD , LEHIGH ACRES 33971

Insp Date: 05/13/2026

Inspection Number: 3697606

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Under left side triple sink in back kitchen, large electrical attachment pulled out of wall. By drive thru window, ice cream machine cord at wall hookup to left damaged.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4702467

FUJI HIBACHI EXPRESS

License Type: Food

2329 N MONROE ST , TALLAHASSEE 32303

Insp Date: 05/11/2026

Inspection Number: 3676798

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank in dry storage area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Manatee

License Number: 5105319

ED'S TAVERN

License Type: Food

10719 RODEO DR , BRADENTON 34202

Insp Date: 05/11/2026

Inspection Number: 3687377

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 45-05-4 | Portable fire extinguisher missing from its designated location. For reporting purposes only. | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|

License Number: 5604195

RESIDENCE INN BY MARRIOTT AT FORT WALTON BEACH

License Type: Food

2 MIRACLE STRIP PKWY SE , FORT WALTON BEACH 32548

Insp Date: 05/15/2026

Inspection Number: 3691190

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. | Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |
|---------|--|--|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5812944

DUNKIN DONUTS

License Type: Food

4115 E COLONIAL DR , ORLANDO 32803

Insp Date: 05/12/2026

Inspection Number: 3624168

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Back exit by officer blocked with carts

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5815075

WALLYS BAR AND LIQUOR

License Type: Food

1001 N MILLS AVE , ORLANDO 32803

Insp Date: 05/14/2026

Inspection Number: 3603148

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Exit blocked facing mills

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5815693

PORTILLO'S

License Type: Food

8041 W IRLO BRONSON MEMORIAL HWY , KISSIMMEE 34747

Insp Date: 05/08/2026

Inspection Number: 3683236

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Exit door blocked by cart. Operator relocated ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813383

SUSHI LOLAS

License Type: Food

2902 CORRINE DR , ORLANDO 32803

Insp Date: 05/15/2026

Inspection Number: 3678270

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Gas can on stairway inside building - From follow-up inspection 2026-05-15: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Osceola

License Number: 5910185

SUBWAY SANDWICHES&SALADS#24007

License Type: Food

829 CYPRESS PKWY , KISSIMMEE 34758

Insp Date: 05/12/2026

Inspection Number: 3614731

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Exit door blocked by cardboard boxes.
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6218730

RUDYS FOOD AND MARKET

License Type: Food

1698 CLEARWATER LARGO RD , CLEARWATER 33756

Insp Date: 05/11/2026

Inspection Number: 3606586

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Deep fryer used in back kitchen area not under a hood system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6251896

STREET HEAT LLC

License Type: Food

2619 23RD N , ST. PETERSBURG 33713

Insp Date: 05/08/2026

Inspection Number: 1325743

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6217242

CEDARS GRILL

License Type: Food

6549 54 AVE N , ST.PETERSBURG 33709

Insp Date: 05/13/2026

Inspection Number: 3677499

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 45-04-4 | - From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-gyro cooker not installed under hood ventilation system **Repeat Violation** - From follow-up inspection 2026-03-20: **Time Extended** - From follow-up inspection 2026-05-13: **Time Extended** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|

License Number: 6216198

EL TORO NEGRO MEXICAN GRILL CANTINA CORP

License Type: Food

5780 54 AVE N , KENNETH CITY 33709

Insp Date: 05/11/2026

Inspection Number: 3684887

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 46-01-4 | - From initial inspection : Back near restrooms Marked exit to marked exit blocked with religious statues. For reporting purposes only. - From follow-up inspection 2026-05-11: Back near restrooms Marked exit to marked exit blocked with religious statues. For reporting purposes only. **Time Extended** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

St. Johns

License Number: 6502250

JERSEY MIKE'S

License Type: Food

833 S PONCE DE LEON BLVD UNIT 2 , SAINT AUGUSTINE 32084

Insp Date: 05/12/2026

Inspection Number: 3678784

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only.By boxes. Person in charge removed boxes. **Corrected On-Site** | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|

License Number: 7407529

ASIAN HOUSE

License Type: Food

3813 CLYDE MORRIS BLVD STE 107 , PORT ORANGE 32129

Insp Date: 05/14/2026

Inspection Number: 3684868

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

| | | |
|---------|---|--|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only.Red fired extinguisher by back door is in the red | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|---|--|

License Number: 7405344

BOONDOCKS PORT ORANGE

License Type: Food

3948 S PENINSULA DR , PORT ORANGE 32127

Insp Date: 05/11/2026

Inspection Number: 3683266

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

| | | |
|---------|--|--|
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only.-partially blocked/obstructed fire exit at cookline | Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
|---------|--|--|



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7407194

MCDONALD'S #36779

License Type: Food

1376 W INTERNATIONAL SPEEDWAY BLVD , DAYTONA BEACH 32114

Insp Date: 05/08/2026

Inspection Number: 3623830

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Rear exit partial blocked by bun rack
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405344

BOONDOCKS PORT ORANGE

License Type: Food

3948 S PENINSULA DR , PORT ORANGE 32127

Insp Date: 05/12/2026

Inspection Number: 3683266

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.-partially blocked/obstructed fire exit at cookline - From follow-up inspection 2026-05-12: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.