



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Brevard**

License Number: 1505613

**LILI'S BEACHSIDE RESTAURANT**

License Type: Food

240 HWY A1A , SATELLITE BEACH 32937

Insp Date: 06/05/2026

Inspection Number: 3671831

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. One by back door next to 3 compartment sinkOne in dishwashing area.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2150552

**CJ'S PASTELILLOS FOOD TRUCK**

License Type: Food

13510 TAMIAMI TRAIL N STE 7 , NAPLES 34110

Insp Date: 06/02/2026

Inspection Number: 1326425

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed two fire extinguishers not mounted.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2337223

**NOVEL CAFE SOCIAL**

License Type: Food

2323 N MIAMI AVE , MIAMI 33137

Insp Date: 06/01/2026

Inspection Number: 3676461

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed induction burner on prep table next to walk in. Observed sandwich press on table across hand sink. - From follow-up inspection 2026-06-01: <b>**Time Extended**</b>	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 4508333

**AKINA**

License Type: Food

4300 S HIGHWAY 27 , CLERMONT 34711

Insp Date: 06/02/2026

Inspection Number: 3686574

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 4508333

**AKINA**

License Type: Food

4300 S HIGHWAY 27 , CLERMONT 34711

Insp Date: 06/03/2026

Inspection Number: 3686574

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors. For reporting purposes only. - From follow-up inspection 2026-06-03: <b>**Time Extended**</b>	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Lee**

License Number: 4651844

**TACO WORX**

License Type: Food

1017 CAPE CORAL PKWY EAST STE B , CAPE CORAL 33904

Insp Date: 05/29/2026

Inspection Number: 1334256

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. Observed electrical outlet cover missing and observed wires hanging from ceiling. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Orange**

License Number: 5812689

**ALEX GYRO AND CHEESESTEAKS**

License Type: Food

7310 E COLONIAL DR , ORLANDO 32807

Insp Date: 06/03/2026

Inspection Number: 3698825

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tanks stored inside back area by chest freezers Operator moved tanks outside \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807952

**WENDY'S #5479**

License Type: Food

5503 MAJOR BLVD , ORLANDO 32819

Insp Date: 06/03/2026

Inspection Number: 3623450

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by boxes , operator moved \*\*Corrected On-Site\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Palm Beach**

License Number: 6013589

**POLO CLUB - BISTRO KITCHEN**

License Type: Food

5400 CHAMPION BLVD , BOCA RATON 33496

Insp Date: 06/04/2026

Inspection Number: 3697281

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  
**\*\*Repeat Violation\*\***

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6113960

**RHONDA'S RIDGE ROAD TAVERN**

License Type: Food

6205 RIDGE RD , PORT RICHEY 34668

Insp Date: 06/01/2026

Inspection Number: 3690776

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top electric fryers and griddle in kitchen with no hood system

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Polk**

License Number: 6308869

**KULTURE ON 1ST**

License Type: Food

1780 1 ST N , WINTER HAVEN 33881

Insp Date: 06/01/2026

Inspection Number: 3642099

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed 2 small fryers on counter across from cook line, recommended to operator to move to table under hood system.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6804725

**SUBWAY 28358**

License Type: Food

1433 S SUMTER BLVD , NORTH PORT 34287

Insp Date: 06/02/2026

Inspection Number: 3598240

Insp Type: Routine - Food

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

46-04-4	- From initial inspection : Rear exit door locked. For reporting purposes only. <b>**Repeat Violation**</b> - From follow-up inspection 2026-06-02: Observed rear exit door locked at the establishment. <b>**Time Extended**</b>	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Seminole**

License Number: 6904993

**LITTLE GREEK FRESH GRILL**

License Type: Food

155 CRANES ROOST BLVD SUITE #1110 , ALTAMONTE SPRINGS 32701

Insp Date: 06/02/2026

Inspection Number: 3698929

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.K class extinguisher On cook line

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Sumter**

License Number: 7000649

**FIRST WATCH RESTAURANT #302**

License Type: Food

5833 SEVEN MILE DRIVE STE 101 , WILDWOOD 34785

Insp Date: 06/01/2026

Inspection Number: 3612254

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed : the silver K-class was not at the sign designated location. The Fire extinguisher was returned the the wall hook under the sign. **\*\*Corrected On-Site\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7000649

**FIRST WATCH RESTAURANT #302**

License Type: Food

5833 SEVEN MILE DRIVE STE 101 , WILDWOOD 34785

Insp Date: 06/01/2026

Inspection Number: 3612254

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed : the back door was blocked by a rolling cart ready for a trash run. The cart was there over 19 minutes. The cart was moved to the side to give free axes to the exit. **\*\*Corrected On-Site\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Volusia**

License Number: 7402525

**POPEYES LOUISIANA KITCHEN #125**

License Type: Food

101 N RIDGEWOOD AVE , DAYTONA BCH 43241

Insp Date: 06/01/2026

Inspection Number: 3698756

Insp Type: Complaint Partial

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-03-4	Observed electrical wiring in disrepair. For reporting purposes only.-rear door exit sign hanging by wire	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 7407936

**EUPHORIA**

License Type: Food

1130 S RIDGEWOOD AVE , DAYTONA BEACH 32114

Insp Date: 05/29/2026

Inspection Number: 3681177

Insp Type: Routine - Food

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.-rear exit in dining room partial blocked by boxes - From follow-up inspection 2026-05-29:	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 7407936

**EUPHORIA**

License Type: Food

1130 S RIDGEWOOD AVE , DAYTONA BEACH 32114

Insp Date: 06/05/2026

Inspection Number: 3681177

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.-rear exit in dining room partial blocked by boxes - From follow-up inspection 2026-05-29: - From follow-up inspection 2026-06-05:	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--