



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Brevard

License Number: 1507059

POPEYES 13660

License Type: Food

3675 CHENEY HWY , TITUSVILLE 32780

Insp Date: 06/19/2026

Inspection Number: 3700376

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. In kitchen by walk in cooler

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001387

MINDY'S CUBAN KITCHEN

License Type: Food

1810 TOWN CENTER BLVD STE 13 , FLEMING ISLAND 32003

Insp Date: 06/18/2026

Inspection Number: 3699559

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small counter top fryer in use cooking croquettes and fries located to the left of hood system. Operator states plans are in place to extend the hood system. **Corrective Action Taken**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Collier

License Number: 2102261

AQUA SEAFOOD & STEAKS

License Type: Food

862 5 AVE S , NAPLES 34102

Insp Date: 06/12/2026

Inspection Number: 3670958

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone near cook line. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2103269

MAIN KITCHEN (FISH RISTORANTE)

License Type: Food

4360 GULF SHORE BLVD N UNIT 600 , NAPLES 34103

Insp Date: 06/18/2026

Inspection Number: 3700284

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. There is an unprotected electrical bod in dry storage.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334383

PITZZA AT IRONSIDE

License Type: Food

7580 NE 4 CT 118 , MIAMI 33138

Insp Date: 06/16/2026

Inspection Number: 3700179

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observe use of cooking with no hood.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2338539

MAE'S ROOM /DRINKING PIG/CHUGGIES

License Type: Food

3444 MAIN HWY STE 16 , MIAMI 33133

Insp Date: 06/16/2026

Inspection Number: 3695827

Insp Type: Complaint Full

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Observed 4 propane tanks stored in parking garage storage area of establishment. - From follow-up inspection 2026-06-16: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2334383

PITZZA AT IRONSIDE

License Type: Food

7580 NE 4 CT 118 , MIAMI 33138

Insp Date: 06/16/2026

Inspection Number: 3674524

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed use of burner to cook salmon and chicken, no hood system. - From follow-up inspection 2026-04-16: **Time Extended** - From follow-up inspection 2026-06-16: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2614505

SWEET SOUTHERN SKILLET

License Type: Food

6661 BOWDEN RD , JACKSONVILLE 32216

Insp Date: 06/19/2026

Inspection Number: 3681659

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator using double portable fryer in kitchen area & no hood suppression system installed over area being used.
Repeat Violation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613603

PANERA BREAD #943

License Type: Food

4720 TOWN CROSSING DR #G01 , JACKSONVILLE 32246

Insp Date: 06/12/2026

Inspection Number: 3647520

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed kitchen exit door blocked with boxes.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2615220

WICKED BARLEY BREWING CO

License Type: Food

4100 BAYMEADOWS RD , JACKSONVILLE 32217

Insp Date: 06/19/2026

Inspection Number: 3698371

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.Side kitchen exit door blocked by garbage can. Moved by manager.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 4605831

GOLDEN CORRAL BUFFET & GRILL

License Type: Food

4690 COLONIAL BLVD. , FORT MYERS 33966

Insp Date: 06/19/2026

Inspection Number: 3693554

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.Observed electric scooter and hamper blocking the exit door near ice machine.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 5319145

CHIPOTLE MEXICAN GRILL STORE 4149

License Type: Food

3150 MARTIN DOWNS BLVD , PALM CITY 34990

Insp Date: 06/19/2026

Inspection Number: 3700508

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.Back door blocked by cardboard boxes-operator removed. **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5811225

CRABBERS

License Type: Food

2258 S KIRKMAN RD , ORLANDO 32811

Insp Date: 06/15/2026

Inspection Number: 3699213

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.-rear door exit path blocked	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 5812209

KNIGHTS CURRY EXPRESS

License Type: Food

11565 UNIVERSITY BLVD STE #4 , ORLANDO 32817

Insp Date: 06/16/2026

Inspection Number: 3699858

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.Back exit door blocks with multiple bags of rice, removed **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 5812241

Q KARAOKE

License Type: Food

4519 S ORANGE BLOSSOM TR , ORLANDO 32839

Insp Date: 06/19/2026

Inspection Number: 3634108

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5816575

DYA ICE FOOD SERVICE

License Type: Food

4880 DISTRIBUTION CT UNIT 1-3 , ORLANDO 32822

Insp Date: 06/15/2026

Inspection Number: 3699835

Insp Type: Routine - Food

Disposition: Emergency recommended

order

Violation Code

Observation

Violation Citation

46-04-4	Exit door locked. For reporting purposes only.Operator unlocked **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 5811225

CRABBERS

License Type: Food

2258 S KIRKMAN RD , ORLANDO 32811

Insp Date: 06/16/2026

Inspection Number: 3699213

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.-rear door exit path blocked - From follow-up inspection 2026-06-16: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 5815077

MAGURO

License Type: Food

1311 FLORIDA MALL AVE , ORLANDO 32809

Insp Date: 06/16/2026

Inspection Number: 3686585

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Located in the kitchen. - From follow-up inspection 2026-06-16: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Report Date: 06/20/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5814560

BLESSED KITCHEN LLC

License Type: Food

810 W COLONIAL DR , ORLANDO 32804

Insp Date: 06/18/2026

Inspection Number: 3671602

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Speed rack blocking back exit door. **Corrected On-Site** - From follow-up inspection 2026-03-18: **Time Extended** - From follow-up inspection 2026-06-18: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 5804348

UNDERGROUND PUBLIC HOUSE

License Type: Food

19 SOUTH ORANGE AVE , ORLANDO 32801

Insp Date: 06/12/2026

Inspection Number: 3631882

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.-Hallway between kitchen leading to kitchen blocked by equipment and bulk items.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6013640

POLLO TROPICAL #58

License Type: Food

950 LINTON BLVD , DELRAY BEACH 33444

Insp Date: 06/18/2026

Inspection Number: 3700245

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only...blocked by discarded boxes . Manager removed paper. **Corrected On-Site**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6010841

ANOTHER BROKEN EGG CAFE

License Type: Food

508 VIA DE PALMAS ROYAL PALM PLACE 76, BOCA RATON 33432

Insp Date: 06/12/2026

Inspection Number: 3699640

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit door blocked with empty boxes

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6006186

BURGER KING #3697

License Type: Food

8175 GLADES RD , BOCA RATON 33434

Insp Date: 06/17/2026

Inspection Number: 3678145

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on the floor in cook line area. Maintenance person picked up and placed in designated area. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6218765

PHO 97 - CLEARWATER

License Type: Food

30113 US HWY 19 N , CLEARWATER 33761

Insp Date: 06/17/2026

Inspection Number: 3699713

Insp Type: Food-Licensing Inspection

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Hood system removed from over 4 burner range, 6 burner range and fryers added without hood system. Operator has spring rolls and egg rolls on her menu that she does plan to fry.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6214974

NOVU AT PONCE

License Type: Food

95 CENTRAL AVE , ST. PETERSBURG 33701

Insp Date: 06/16/2026

Inspection Number: 3670640

Insp Type: Routine - Food

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Grease build up on walls. **Repeat Violation** - From follow-up inspection 2026-06-16: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Putnam

License Number: 2050197

GRILL NEXT DOOR

License Type: Food

167 US 17 , EAST PALATKA 32131

Insp Date: 06/19/2026

Inspection Number: 1316876

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Two table top fryers used for cooking fries and cheese sticks not stored under hood system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7406726

FILO GREEK

License Type: Food

1665 DUNLAWTON AVE UNIT 104 , PORT ORANGE 32127

Insp Date: 06/18/2026

Inspection Number: 3679624

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.-back wall near back door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407352

DOMINOS PIZZA

License Type: Food

1820 DUNLAWTON AVE UNIT 101 , PORT ORANGE 32127

Insp Date: 06/18/2026

Inspection Number: 3699645

Insp Type: Complaint Full

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

46-04-4

- From initial inspection : Exit door locked. For reporting purposes only.-manager unlocked back door ****Corrected On-Site**** - From follow-up inspection 2026-06-18: Person in charge during prior inspection stated corporate policy to keep fire exit locked. Advised to discuss with local fire authorities having jurisdiction for concerns regarding the violation ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.