



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Alachua

License Number: 1101276

KENTUCKY FRIED CHICKEN

License Type: Food

1231 E UNIVERSITY AVE , GAINESVILLE 32641

Insp Date: 07/24/2026

Inspection Number: 3711138

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

49-01-4

Flammables stored/debris present in meter room. For reporting purposes only. Observed : cardboard boxes touching circuit breaker boxes.

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 1103580

GYRO PLUS

License Type: Food

2409 SW 13 ST , GAINESVILLE 32608

Insp Date: 07/31/2026

Inspection Number: 3735936

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Needle in red zone of extinguisher at front kitchen entrance.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103524

CARIBBEAN SPICE

License Type: Food

1310 NW 23 AVE UNIT C , GAINESVILLE 32605

Insp Date: 07/27/2026

Inspection Number: 3738733

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed : the back door by the restrooms is blocked by a garbage can and locked. The trash can was moved and the door unlocked. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Bay

License Number: 1305740

DIEGO'S BURRITO FACTORY

License Type: Food

6209 SUNSET DRIVE , PANAMA CITY BEACH 32408

Insp Date: 07/30/2026

Inspection Number: 3762983

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only. Outlet in prep area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1500199

BURGER KING

License Type: Food

380 E. MERRITT ISLAND CAUSEWAY , MERRITT ISLAND 32952

Insp Date: 07/27/2026

Inspection Number: 3704581

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver extinguisher in kitchen by office in recharge

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1801385

FINNEGAN'S GRILLE AND PUB

License Type: Food

1825 TAMIAMI TRL UNIT F2 , PORT CHARLOTTE 33948

Insp Date: 07/24/2026

Inspection Number: 3723560

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located behind the keg cooler. For reporting purposes only. The operator removed the propane tank. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Charlotte

License Number: 1802060

CHICKEN SALAD CHICK

License Type: Food

1799 TAMIAMI TRL #103-104 , PORT CHARLOTTE 33948

Insp Date: 07/30/2026

Inspection Number: 3731451

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only.Observed the fire extinguisher near the office in the red zone for recharging.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1801597

GOLDEN KRUST CARIBBEAN RESTAURANT

License Type: Food

1825 TAMIAMI TRL STE A2 , PORT CHARLOTTE 33948

Insp Date: 07/27/2026

Inspection Number: 3716781

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Rear kitchen exit/path to marked exit blocked. For reporting purposes only.The operator cleared a pathway for the exit. **Corrected On-Site** **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Charlotte

License Number: 1802060

CHICKEN SALAD CHICK

License Type: Food

1799 TAMIAMI TRL #103-104 , PORT CHARLOTTE 33948

Insp Date: 07/30/2026

Inspection Number: 3731451

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed front entrance and front exit double doors locked on one side for each door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1801656

HAMPTON INN

License Type: Food

24480 SANDHILL BLVD , PORT CHARLOTTE 33983

Insp Date: 07/30/2026

Inspection Number: 3702884

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Jurisdiction No. 093953, Expiration: 06/14/2026.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Dade**

License Number: 2334231

PLAZA MARKET

License Type: Food

913 BRICKELL AVE , MIAMI 33131

Insp Date: 07/28/2026

Inspection Number: 3761449

Insp Type: Complaint Full

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed chicken being cooked with no fire suppression system observed vapor and smoke in the kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2338381

SOBOL

License Type: Food

7094 SW 117 AVE , MIAMI 33183

Insp Date: 07/31/2026

Inspection Number: 3726201

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed for extinguisher in front area near hws.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334894

PRETTY HEALTHY

License Type: Food

17560 NW 27 AVE STE 123 , MIAMI 33056

Insp Date: 07/27/2026

Inspection Number: 3742142

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed 2 electrical cookers that use grease on the prep table in the back kitchen area with no hood system. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2336616

CUBAOHCO

License Type: Food

1465 SW 8 ST STE 106 , MIAMI 33135

Insp Date: 07/24/2026

Inspection Number: 3747832

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed the establishment have two portable grease fryers on a table in the new kitchen area, no hood system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337873

BROTHERHOOD JW RESTURANT

License Type: Food

16610 NE 4 AVE , MIAMI 33162

Insp Date: 07/27/2026

Inspection Number: 3713400

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed 2 gas stoves in the kitchen on the opposite side of the hood system not under it.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337873

BROTHERHOOD JW RESTURANT

License Type: Food

16610 NE 4 AVE , MIAMI 33162

Insp Date: 07/27/2026

Inspection Number: 3713400

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 4 propane tanks of 40 lbs in the kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2334487

SUBWAY 58064

License Type: Food

847 WASHINGTON AVE , MIAMI BEACH 33139

Insp Date: 07/31/2026

Inspection Number: 3702766

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher at prep area in the recharge zone.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328909

MANOLO'S COIN LAUNDRY & COFFE SHOP

License Type: Food

11480 SW QUAIL ROOST DRIVE , MIAMI 33157

Insp Date: 07/29/2026

Inspection Number: 3721212

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed operator using oil fryer and also a portable stove with no hood suppression system installed. **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2336796

CUBATA

License Type: Food

1605 SW 8 ST , MIAMI 33135

Insp Date: 07/24/2026

Inspection Number: 3717194

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a double sided portable grease fryer in use without a hood.
Repeat Violation

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337694

ROZU

License Type: Food

200 E FLAGLER ST UNIT 207 , MIAMI 33131

Insp Date: 07/29/2026

Inspection Number: 3705675

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed deep fryer with no hood attached, observed no cooking that produces lead grease and vapors at time of inspection.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2335884

MORELIA WYNWOOD

License Type: Food

185 NW 25 ST , MIAMI 33127

Insp Date: 07/28/2026

Inspection Number: 3703398

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-05-4

Observation

Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed fire extinguisher stored on the floor.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331727

DOMINO'S PIZZA #3196

License Type: Food

1485 NE 1 AVE UNIT 102 , FLORIDA CITY 33034

Insp Date: 07/30/2026

Inspection Number: 3739515

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked with boxes and blue trays and rolling racks. Operator removed boxes and blue containers. **Corrected On-Site** **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2334007

LITTLE CAESARS PIZZA

License Type: Food

15457 SW 137 AVE , MIAMI 33177

Insp Date: 07/28/2026

Inspection Number: 3721623

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked with trash can. **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328544

DICED

License Type: Food

15467 SW 137 AVE , MIAMI 33177

Insp Date: 07/28/2026

Inspection Number: 3711263

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

46-01-4

Observation

Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked with trash can and boxes. Manager clear path to exit door. **Corrected On-Site**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2333138

HOLIDAY INN HOTEL 4TH FLOOR

License Type: Food

4333 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 07/29/2026

Inspection Number: 3702180

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2338123

CITIZENM HOTELS

License Type: Food

1200 LINCOLN RD , MIAMI BEACH 33139

Insp Date: 07/30/2026

Inspection Number: 3725891

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 1 Serial 2318133877469 and #2 Serial 23181338774 operate on 800,000 BTUs.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Dade**

License Number: 2334894

PRETTY HEALTHY

License Type: Food

17560 NW 27 AVE STE 123 , MIAMI 33056

Insp Date: 07/27/2026

Inspection Number: 3686778

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed 2 electrical cookers that use grease on the prep table in the back kitchen area with no hood system. ****Repeat Violation**** - From follow-up inspection 2026-07-27: Observed 2 electrical cookers that use grease on the prep table in the back kitchen area with no hood system. ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2400316

BROTHER'S FISH HOUSE RESTAURANT II

License Type: Food

5 & 7 N LUTHER AVE , ARCADIA 34266

Insp Date: 07/24/2026

Inspection Number: 3745938

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed back exit door with two cases of lids on the floor blocking the door, owner moved. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2614304

GARAGE

License Type: Food

2692 POST ST , JACKSONVILLE 32204

Insp Date: 07/29/2026

Inspection Number: 3761443

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in kitchen area in red recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615140

SUBWAY #35836

License Type: Food

7908 BLANDING BLVD # 2 , JACKSONVILLE 32244

Insp Date: 07/28/2026

Inspection Number: 3741504

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by restrooms is in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2616097

WHATABURGER

License Type: Food

8239 OLD MIDDLEBURG ROAD S , JACKSONVILLE 32222

Insp Date: 07/30/2026

Inspection Number: 3743739

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Back exit door blocked by large cart.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2612529

DAVE & BUSTERS

License Type: Food

7025 SALISBURY RD , JACKSONVILLE 32256

Insp Date: 07/31/2026

Inspection Number: 3705507

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
Repeat Violation

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2616458

WAAH INDIAN BISTRO AND KWALITY ICE CREAMS

License Type: Food

9551 BAYMEADOWS RD #20 , JACKSONVILLE 32256

Insp Date: 07/29/2026

Inspection Number: 3754956

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 LP tanks in rear kitchen area. **Repeat Violation**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hernando

License Number: 3701311

CHARLEYS CHEESESTEAKS & WINGS

License Type: Food

1147 S BROAD ST , BROOKSVILLE 34601

Insp Date: 07/29/2026

Inspection Number: 3724711

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.Extinguisher by back door of kitchen - From follow-up inspection 2026-07-29: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3801211

MERLOS FRUTERIA

License Type: Food

211 US HWY 27 S , SEBRING 33870

Insp Date: 07/30/2026

Inspection Number: 3719896

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Observed two small fryers on the counter top without a hood suppression, owner stated on phone that recently had fire inspection sent copy by email, operator removed fryer. **Corrected On-Site** **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Hillsborough

License Number: 3917706

WINGSTOP 1047

License Type: Food

2115 E HILLSBOROUGH AVE STE 2115-1A , TAMPA 33610

Insp Date: 07/30/2026

Inspection Number: 3731331

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Back door has boxes stacked in front of it.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4100626

CAPTAIN HIRAM'S

License Type: Food

1606 INDIAN RIVER DR , SEBASTIAN 81610

Insp Date: 07/30/2026

Inspection Number: 3717806

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Tiffany room kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4606131

PANDA EXPRESS #1656

License Type: Food

9330-1 BEN C PRATT 6 MI CYPRESS PKWY , FORT MYERS 66505

Insp Date: 07/24/2026

Inspection Number: 3734257

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked rear exit blocked by garbage cans. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Lee

License Number: 4605779

APPLEBEE'S NEIGHBORHOOD GRILL AND BAR

License Type: Food

8243 DANI DR , FORT MYERS 33966

Insp Date: 07/28/2026

Inspection Number: 3761956

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed rear exit blocked by cardboard boxes, the manager removed the items. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4651350

TAQUERIA Y ANTOJITOS MEXICANOS

License Type: Food

4529 BAYSHORE RD , N FT MYERS 33917

Insp Date: 07/24/2026

Inspection Number: 1335847

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher not charged.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lee

License Number: 4606756

DOMINO'S 5045

License Type: Food

3112 CLEVELAND AVE , FORT MYERS 33901

Insp Date: 07/27/2026

Inspection Number: 3736882

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed rear exit blocked by garbage can and dough trays.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4606546

MCDONALDS # 35747

License Type: Food

2925 SW PINE ISLAND RD , CAPE CORAL 33991

Insp Date: 07/30/2026

Inspection Number: 3732342

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. The manager removed tech gear supplies from blocking emergency door. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5105840

MI HAVANA LATIN CAFE AND CATERING INC

License Type: Food

1144 WHITFIELD AVE , SARASOTA 34243

Insp Date: 07/28/2026

Inspection Number: 3717547

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks stored inside kitchen. Operator removed them.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Manatee

License Number: 5105593

NONNA'S PIZZA AND RESTAURANT LLC

License Type: Food

7604 CORTEZ RD W STE 10 , BRADENTON 34210

Insp Date: 07/29/2026

Inspection Number: 3742435

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed their kitchen fire extinguisher in the red.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5102656

BASIL'S FLAME BROILED CHICKEN & RIBS

License Type: Food

5917 MANATEE AVE N , BRADENTON 34209

Insp Date: 07/24/2026

Inspection Number: 3741242

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed the back exit door locked. Operator unlocked it. **Corrected On Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Manatee

License Number: 5100092

WOODY'S RIVER ROO PUB & GRILL

License Type: Food

5717 E 18TH ST , ELLENTON 34222

Insp Date: 07/27/2026

Inspection Number: 3737127

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tank larger than 2.7 lb stored under building structure.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5428507

MAESTRO DELLA PIZZA/STARBUCKS

License Type: Food

3495 S ROOSEVELT BLVD , KEY WEST 33040

Insp Date: 07/28/2026

Inspection Number: 3732559

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed at exit next to dry storage. Operator cleared path. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5604187

FATBOYS

License Type: Food

104 HARBOR BLVD , DESTIN 32541

Insp Date: 07/27/2026

Inspection Number: 3701441

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-02-4

Observed active water leak and pooled water around electrical outlet and main electrical feed / breaker box . For reporting purposes only. M. Taylor Destin Fire Control AHJ notified

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Okeechobee**

License Number: 5700742

SAN DIEGO MEXICAN RESTAURANT Y TAQUERIA INC

License Type: Food

219 SW PARK ST , OKEECHOBEE 34972

Insp Date: 07/29/2026

Inspection Number: 3740130

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only at exit in kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5700742

SAN DIEGO MEXICAN RESTAURANT Y TAQUERIA INC

License Type: Food

219 SW PARK ST , OKEECHOBEE 34972

Insp Date: 07/30/2026

Inspection Number: 3740130

Insp Type: Routine - Food

Disposition: Call Back - Admin. complaint recommended

Violation CodeObservationViolation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only at exit in kitchen.
- From follow-up inspection 2026-07-30: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813725

LITTLE GREEK RESTAURANT

License Type: Food

855 N ALAFAYA TRAIL , ORLANDO 32828

Insp Date: 07/24/2026

Inspection Number: 3728568

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Exit door blocked with trash boxes and buckets.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Orange

License Number: 5814961

LA' DIFFERENCE BAKERY & TAKEOUT RESTAURANT, LLC

License Type: Food

737 NORTH APOPKA VINELAND RD #200 , ORLANDO 32818

Insp Date: 07/28/2026

Inspection Number: 3742481

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Exit blocked by cases of product in hallway to back exit.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813255

TROPICAL SMOOTHIE CAFE

License Type: Food

3120 S KIRKMAN RD STE E , ORLANDO 32811

Insp Date: 07/31/2026

Inspection Number: 3702418

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-rear door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Palm Beach

License Number: 6013329

ANGELA'S PIZZA KITCHEN

License Type: Food

22191 POWERLINE RD #28-C , BOCA RATON 33433

Insp Date: 07/27/2026

Inspection Number: 3747202

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Ansul fire extinguisher in kitchen in red

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6007910

CARVEL STORE #1225

License Type: Food

5901 S DIXIE HWY , WEST PALM BEACH 33405

Insp Date: 07/29/2026

Inspection Number: 3753255

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in back prep area in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Palm Beach

License Number: 6009923

KFC

License Type: Food

360 N CONGRESS AVE , BOYNTON BEACH 63414

Insp Date: 07/29/2026

Inspection Number: 3757658

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only....blocked garbage bags

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6021782

DUNKIN PC#301559

License Type: Food

3501 S DIXIE HWY , WEST PALM BEACH 33405

Insp Date: 07/27/2026

Inspection Number: 3716717

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. Back exit door blocked by multiple boxes. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Pinellas**

License Number: 6218730

RUDYS FOOD AND MARKET

License Type: Food

1698 CLEARWATER LARGO RD , CLEARWATER 33756

Insp Date: 07/29/2026

Inspection Number: 3606586

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation CodeObservationViolation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Deep fryer used in back kitchen area not under a hood system. - From follow-up inspection 2026-07-29: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6309094

CULVER'S

License Type: Food

1395 N HOLLAND PKWY , BARTOW 33830

Insp Date: 07/29/2026

Inspection Number: 3584630

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation CodeObservationViolation Citation

51-04-4

No child labor law poster. For reporting purposes only. The manager printed a copy. **Corrected On-Site**

Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Sarasota

License Number: 6805375

HOTEL VENEZIA A RAMADA HOTEL

License Type: Food

425 US 41 BYPASS N , VENICE 34285

Insp Date: 07/31/2026

Inspection Number: 3717505

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Observed fire exit at back of kitchen blocked by garbage bin and excess cardboard boxes.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6806072

IL PANIFICIO

License Type: Food

1703 MAIN ST , SARASOTA 34236

Insp Date: 07/27/2026

Inspection Number: 3711882

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.Exposed wires on the light fixture in the walk in cooler..

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Sarasota

License Number: 6806063

BESO

License Type: Food

30 S LEMON AVE , SARASOTA 34236

Insp Date: 07/27/2026

Inspection Number: 3731457

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. One propane tank stored inside next to the back exit. Manager placed the tank outside. **Corrected On Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6904952

BEIRUT GRILL AND DELI

License Type: Food

3100 ALAFAYA TRL STE 1006 , OVIEDO 32765

Insp Date: 07/28/2026

Inspection Number: 3755724

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.- flat grill not under hood system.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

St. Johns

License Number: 6502086

FLAGLER INN

License Type: Food

2700 N PONCE DE LEON BLVD , SAINT AUGUSTINE 32084

Insp Date: 07/27/2026

Inspection Number: 3746189

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

45-05-4

Observation

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher is on floor in kitchen.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6605310

LA ROMA CAFE

License Type: Food

1409 ORANGE AVE , FORT PIERCE 34950

Insp Date: 07/27/2026

Inspection Number: 3759600

Insp Type: Complaint Partial

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Suwannee

License Number: 7100137

PIZZA HUT #2986

License Type: Food

625 S OHIO AVE , LIVE OAK 32060

Insp Date: 07/27/2026

Inspection Number: 3761498

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher on wall across from walk-in freezer.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7100374

TOADAL CONTROL PLAY CAFE - HOPPIN' EATS AND SWAMP TREATS

License Type: Food

1102 OHIO AVE S , LIVE OAK 32064

Insp Date: 07/27/2026

Inspection Number: 3713617

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

47-03-4

Observation

Observed electrical outlet in disrepair. For reporting purposes only. Floor outlet in kitchen.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7407772

FARM TO FIT

License Type: Food

168 N BEACH ST , DAYTONA BEACH 32114

Insp Date: 07/30/2026

Inspection Number: 3731289

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-per operator working on getting a hood with suppression

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405406

ICHI NI SAN

License Type: Food

246 S BEACH ST #100 , DAYTONA BEACH 32114

Insp Date: 07/29/2026

Inspection Number: 3755727

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-small fryer not under hood

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407565

VENEMEX

License Type: Food

201 SEABREEZE BLVD , DAYTONA BEACH 32118

Insp Date: 07/28/2026

Inspection Number: 3727118

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.-wiring around/hanging below light at entrance to back of house

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Volusia

License Number: 7407391

LUCKY JOVY'S ASIAN MARKET & EATERY

License Type: Food

577 DELTONA BLVD STE 5-6 , DELTONA 32725

Insp Date: 07/24/2026

Inspection Number: 3726034

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-rear exit door from storage room, unlocked **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407772

FARM TO FIT

License Type: Food

168 N BEACH ST , DAYTONA BEACH 32114

Insp Date: 07/31/2026

Inspection Number: 3731289

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-per operator working on getting a hood with suppression - From follow-up inspection 2026 -07-31:

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Volusia

License Number: 7405406

ICHI NI SAN

License Type: Food

246 S BEACH ST #100 , DAYTONA BEACH 32114

Insp Date: 07/30/2026

Inspection Number: 3755727

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-small fryer not under hood - From follow-up inspection 2026-07-30: Moved to under hood

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407824

FUSION HUT BISTRO

License Type: Food

933 BEVILLE RD UNIT 102- C , SOUTH DAYTONA 32119

Insp Date: 07/24/2026

Inspection Number: 3719083

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Next to the oven
Repeat Violation - From follow-up inspection 2026-07-24: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.