



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Alachua

License Number: 1102112

AMELIAS ITALIAN CUISINE

License Type: Food

235 S MAIN ST STE107 , GAINESVILLE 32601

Insp Date: 08/14/2026

Inspection Number: 3753500

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed : the back door hallway is lined with boxes, impeding egress.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103172

CHINA BOWL

License Type: Food

5200 NW 43 ST STE 506 , GAINESVILLE 32606

Insp Date: 08/18/2026

Inspection Number: 3705505

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 20lb propane tank on shelf in back storage area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Alachua**

License Number: 1101508

BURRITO FAMOUS

License Type: Food

3412 W UNIVERSITY AVE , GAINESVILLE 32607

Insp Date: 08/17/2026

Inspection Number: 3755395

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Wires hanging down from the ceiling above dish machine.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1304052

VIEW

License Type: Food

11127 W FRONT BEACH RD , PANAMA CITY BEACH 32407

Insp Date: 08/21/2026

Inspection Number: 3742552

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher in prep area, gauge in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1304520

BAMBOO GRILL/OASIS BAR

License Type: Food

11127 FRONT BEACH RD , PANAMA CITY BEACH 32407

Insp Date: 08/21/2026

Inspection Number: 3714335

Insp Type: Routine - Food

Disposition: Warning Issued

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Bamboo grill K class extinguisher gauge in recharge zone. Portable fire extinguisher is inaccessible. For reporting purposes only. K class extinguisher in oasis kitchen blocked by fryers and table.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Brevard

License Number: 1506455

PERSIS INDIAN GRILL

License Type: Food

2447 N WICKHAM RD #148 & 149 , MELBOURNE 32935

Insp Date: 08/18/2026

Inspection Number: 3706922

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tanks in dry storage room
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506587

PIZZAVOLA CB

License Type: Food

5240 N ATLANTIC AVE #150 , COCOA BEACH 32931

Insp Date: 08/20/2026

Inspection Number: 3735830

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Red fire extinguisher next to ice machine in recharge

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/22/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Brevard

License Number: 1507030

DEL TACO RESTAURANT

License Type: Food

2936 SARNO ROAD , MELBOURNE 32935

Insp Date: 08/19/2026

Inspection Number: 3754245

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Hood systems not functioning. Smoke billowing into building. Operator propping open rear door to ventilate during working hours

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1507030

DEL TACO RESTAURANT

License Type: Food

2936 SARNO ROAD , MELBOURNE 32935

Insp Date: 08/19/2026

Inspection Number: 3754245

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Exposed wire above walk-in cooler door on interior

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/22/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1607304

TOWER CLUB (THE)

License Type: Food

1 FINANCIAL PLAZA , FORT LAUDERDALE 33301

Insp Date: 08/14/2026

Inspection Number: 3720558

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. On the unit for the hood suppression system, over charged

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1622202

WOK"N"LIME

License Type: Food

2979 W COMMERCIAL BLVD , FORT LAUDERDALE 33309

Insp Date: 08/19/2026

Inspection Number: 3732940

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryers in use not under hood system

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1625265

WORLD FAMOUS GHOST KITCHEN

License Type: Food

1002 E NEWPORT CENTER DR , DEERFIELD BEACH 33442

Insp Date: 08/14/2026

Inspection Number: 3720227

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/22/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1624111

BEEHIVE KITCHEN

License Type: Food

6312 N ANDREWS AVENUE , FORT LAUDERDALE 33309

Insp Date: 08/18/2026

Inspection Number: 3703097

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2026-08-18: Operator states new fire extinguisher ordered **Corrective Action Taken**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1624111

BEEHIVE KITCHEN

License Type: Food

6312 N ANDREWS AVENUE , FORT LAUDERDALE 33309

Insp Date: 08/17/2026

Inspection Number: 3703097

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623236

EL TAQUITO IV

License Type: Food

917 N FORT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 08/17/2026

Inspection Number: 3711922

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Across from the pot and pan storage rack.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Broward

License Number: 1618058

KASE CUISINE

License Type: Food

1519 NE 4 AVE , FORT LAUDERDALE 33304

Insp Date: 08/18/2026

Inspection Number: 3719498

Insp Type: Routine - Food

Disposition: Administrative complaint
recommended

Violation Code

45-02-4

Observation

Portable fire extinguisher gauge in red zone. For reporting purposes only. The silver canister in the kitchen

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2200598

WENDYS 376

License Type: Food

180 SW MAIN BLVD , LAKE CITY 32025

Insp Date: 08/14/2026

Inspection Number: 3706973

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

47-02-4

Observation

Observed scorch marks around electrical outlet. For reporting purposes only. Electrical outlet with black scorch marks hanging from ceiling behind grill.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337976

EMPANADAS

License Type: Food

5645 NW 87 AVE STE 111 , DORAL 33178

Insp Date: 08/14/2026

Inspection Number: 3725264

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

45-04-4

Observation

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed smoke produced by conveyor oven throughout establishment.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/22/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2336329

NOVA GOURMET

License Type: Food

7520 NW 104 AVE STE A-106 , DORAL 33178

Insp Date: 08/19/2026

Inspection Number: 3720505

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Observed flat electrical grill at preparation area being used to fry eggs.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322684

SERGIO'S CAFETERIA

License Type: Food

3252 CORAL WAY , MIAMI 33145

Insp Date: 08/18/2026

Inspection Number: 3705627

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.Back prep area: two carts blocking the back door. **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337334

JASS KITCHEN

License Type: Food

190 NE 46 ST , MIAMI 33137

Insp Date: 08/14/2026

Inspection Number: 3711555

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Observed two small fryers by RIF BY cook line. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Dade

License Number: 2332126

COURTYARD BY MARRIOTT MIAMI DOLPHIN MALL

License Type: Food

11275 NW 12TH STREET , MIAMI 33172

Insp Date: 08/18/2026

Inspection Number: 3721213

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337171

ADRIANO'S ITALIAN SANDWICHES

License Type: Food

9420 NW 41 ST #115 , DORAL 33178

Insp Date: 08/19/2026

Inspection Number: 3731391

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible
Repeat Violation

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Dade

License Number: 2331579

HAMPTON INN MIAMI - AIRPORT WEST

License Type: Food

3620 NW 79 AVE , DORAL 33166

Insp Date: 08/19/2026

Inspection Number: 3731616

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-01-5

Observation

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Violation Citation

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2320521

PISCO HABANERO

License Type: Food

2238 NW 82 AVE , DORAL 33122

Insp Date: 08/18/2026

Inspection Number: 3733144

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

48-04-4

Observation

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. On the back kitchen area.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Dade

License Number: 2337178

BFF BURGERS

License Type: Food

9420 NW 41 ST #110 , DORAL 33178

Insp Date: 08/19/2026

Inspection Number: 3665087

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. ****Repeat Violation**** - From follow-up inspection 2026-08-19: Observed 2 gas boilers with 650,000 BTUs next to ice machines / SN #1 2145126818071 and SN #2 Not visible. ****Time Extended****

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337491

CREMA GOURMET ESPRESSO BAR

License Type: Food

8915 SW 72 PL , MIAMI 33156

Insp Date: 08/18/2026

Inspection Number: 3711549

Insp Type: Routine - Food

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed flat top grill and 2 induction burners, no hood system. Observed in kitchen. ****Repeat Violation**** - From follow-up inspection 2026-08-18: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Dade

License Number: 2326613

LITTLE CAESARS #2218

License Type: Food

29625 S DIXIE HWY , HOMESTEAD 33030

Insp Date: 08/21/2026

Inspection Number: 3769240

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked with trash cans.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337491

CREMA GOURMET ESPRESSO BAR

License Type: Food

8915 SW 72 PL , MIAMI 33156

Insp Date: 08/17/2026

Inspection Number: 3711549

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed flat top grill and 2 induction burners, no hood system. Observed in kitchen. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614730

MAGNUSON HOTEL

License Type: Food

2228 PHILLIPS HWY , JACKSONVILLE 32207

Insp Date: 08/19/2026

Inspection Number: 3721491

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

49-01-4

Flammables stored/debris present in meter room. For reporting purposes only. Observed red gas container filled with gas stored in back storage room of kitchen area.

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.



Report Date: 08/22/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2614869

PASSIONS

License Type: Food

9801 BEACH BLVD , JACKSONVILLE 32246

Insp Date: 08/19/2026

Inspection Number: 3734679

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Flat top grill in kitchen not completely under hood suppression system

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2616478

KAIROS

License Type: Food

4815 SWEETGRASS PL UNIT 105 & 107 , JACKSONVILLE 32224

Insp Date: 08/21/2026

Inspection Number: 3769167

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Single table top fryer in kitchen on cook line not under hood suppression system

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Duval

License Number: 2614442

BUDDHAS BELLY ROYAL THAI CUISINE

License Type: Food

301 10 AVE N , JACKSONVILLE BEACH 32250

Insp Date: 08/18/2026

Inspection Number: 3754765

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Observed in dining area near entrance of kitchen 2 -LP Propane tanks.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615932

PALETERIA MAGIA FRESCA

License Type: Food

5810 ST AUGUSTINE RD , JACKSONVILLE 32207

Insp Date: 08/19/2026

Inspection Number: 3754875

Insp Type: Routine - Food

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Observed propane tank in back kitchen area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3600469

CULVER'S RESTAURANT

License Type: Food

1030 W SUGARLAND HWY , CLEWISTON 33440

Insp Date: 08/17/2026

Inspection Number: 3752224

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only at entry. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Hillsborough

License Number: 3906962

CAFE BREEZE

License Type: Food

2225 LOIS AVE. , TAMPA 33607

Insp Date: 08/20/2026

Inspection Number: 3701715

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. All 3 boiler certificates are expired on 03/2026.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 3916425

QDOBA MEXICAN GRILL #557

License Type: Food

13155 S US HWY 301 , RIVERVIEW 33569

Insp Date: 08/17/2026

Inspection Number: 3730633

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Back door blocked with mop bucket and trash can.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4100091

NINOS CORNER

License Type: Food

4236 20TH ST , VERO BEACH 32960

Insp Date: 08/20/2026

Inspection Number: 3740686

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. On cook line

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/22/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lake

License Number: 4501509

CHECKERS 6324

License Type: Food

480 E BURLEIGH BLVD , TAVARES 32778

Insp Date: 08/17/2026

Inspection Number: 3767478

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Front door swing arm is broken and operator is keeping exit door locked. **Warning**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/22/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lee

License Number: 4602454

POPEYES LOUISIANA KITCHEN OPERATED BY TICE

License Type: Food

3238 FOWLER ST , FORT MYERS 33901

Insp Date: 08/14/2026

Inspection Number: 3744989

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed rear exit blocked by cardboard boxes and mop bucket. The operator removed the items.
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605809

TRATTORIA MIA

License Type: Food

6631 ORION DR #107 , FORT MYERS 33912

Insp Date: 08/17/2026

Inspection Number: 3709150

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-02-4

Damage around electrical outlet in middle of bar top wall.
For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4608065

SWEET TOMATOES

License Type: Food

14080 S TAMIAMI TRL , FORT MYERS 33912

Insp Date: 08/17/2026

Inspection Number: 3746671

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Front marked door one side locked, back hallway of kitchen blocked with cart, operator removed.
Corrective Action Taken

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Manatee

License Number: 5106183

AU P'TIT BONHEUR

License Type: Food

310-312 12 ST WEST , BRADENTON 34205

Insp Date: 08/19/2026

Inspection Number: 3746372

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed exit door in kitchen locked during operation.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5428290

ANGLER AND ALE

License Type: Food

540 DUCK KEY DRIVE , DUCK KEY 03756

Insp Date: 08/14/2026

Inspection Number: 3722001

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Orange

License Number: 5807537

SABAI THAI STREET FOOD

License Type: Food

3333 S ORANGE AVE STE 105 , ORLANDO 32806

Insp Date: 08/18/2026

Inspection Number: 3746015

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Kitchen exit door at cook line is. Locked by push cart with spices

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807781

AYITI BREEZE BAR & GRILL

License Type: Food

701 W LANCASTER RD , ORLANDO 32809

Insp Date: 08/17/2026

Inspection Number: 3755758

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 20lb gas tank used to cook on a portable gas stove. Establishment has no gas for use of stove and fryers at time of inspection. Gas turned off by municipality.
Warning

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Orange

License Number: 5804439

**DOUBLETREE SUITES ORLANDO DISNEY SPRINGS AREA
EVERGREEN CAFE**

License Type: Food

2305 HOTEL PLAZA BLVD , ORLANDO 32830

Insp Date: 08/21/2026

Inspection Number: 3744626

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed both boiler certificates expired 135234 135233 3/7/2026

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5855927

QUICK BITE

License Type: Food

977 N GOLDENROD RD , ORLANDO 32807

Insp Date: 08/19/2026

Inspection Number: 1338288

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank inside unit set up to a 2 burner portable stove

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Orange

License Number: 5807781

AYITI BREEZE BAR & GRILL

License Type: Food

701 W LANCASTER RD , ORLANDO 32809

Insp Date: 08/18/2026

Inspection Number: 3755758

Insp Type: Routine - Food

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 20lb gas tank used to cook on a portable gas stove. Establishment has no gas for use of stove and fryers at time of inspection. Gas turned off by municipality. ****Warning**** - From follow-up inspection 2026-08-18: Visited the facility on a second day and they were still utilizing the 20lb tank in the kitchen. ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6205716

PAJANO'S PIZZA AND SUBS

License Type: Food

1305 GULF BLVD , INDIAN ROCKS BEACH 33785

Insp Date: 08/19/2026

Inspection Number: 3711576

Insp Type: Routine - Food

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Partially blocked exit path next to bathroom. ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Pinellas

License Number: 6211849

MARRIOTT KOKOMOS GRILL

License Type: Food

1201 GULF BLVD , CLEARWATER BEACH 33767

Insp Date: 08/14/2026

Inspection Number: 3703150

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. FI137614 expired 9/21/2025. **Repeat Violation**

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6200468

SAFETY HARBOR RESORT& KITCHEN

License Type: Food

105 N BAYSHORE DR , SAFETY HARBOR 34695

Insp Date: 08/18/2026

Inspection Number: 3701766

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.Expired.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Report Date: 08/22/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6211628

SLOPPY JOE'S

License Type: Food

10650 GULF BLVD , TREASURE ISLAND 33706

Insp Date: 08/14/2026

Inspection Number: 3764175

Insp Type: Complaint Full

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

47-02-4

- From initial inspection : Observed scorch marks around electrical outlet. For reporting purposes only.Observed on outline near kitchen entrance. - From follow-up inspection 2026-08-12: **Time Extended** - From follow-up inspection 2026-08-14: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6218765

PHO 97 - CLEARWATER

License Type: Food

30113 US HWY 19 N , CLEARWATER 33761

Insp Date: 08/18/2026

Inspection Number: 3699713

Insp Type: Food-Licensing Inspection

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.Hood system removed from over 4 burner range, 6 burner range and fryers added without hood system. Operator has spring rolls and egg rolls on her menu that she does plan to fry. - From follow-up inspection 2026-08-18: Hood system replaced. 4 burner range is setting partially under the hood system. Small table top fryer remains on counter top. Fire Marshall to be notified. **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Sarasota

License Number: 6805296

BOMBON MEXICAN RESTAURANT

License Type: Food

1118 N WASHINGTON BLVD , SARASOTA 34236

Insp Date: 08/14/2026

Inspection Number: 3751064

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. One propane tank stored in the kitchen next to the expo area. Owner placed the tank outside.
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/22/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Seminole

License Number: 6905472

ALEBRIJES

License Type: Food

1566 S FRENCH AVE , SANFORD 32771

Insp Date: 08/17/2026

Inspection Number: 3752540

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-rear exit door near bathrooms, operator unlocked **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905038

BACK PORCH

License Type: Food

145 WEKIVA SPRINGS RD STE B161 , LONGWOOD 32779

Insp Date: 08/21/2026

Inspection Number: 3735972

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2026-08-21: **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6905038

BACK PORCH

License Type: Food

145 WEKIVA SPRINGS RD STE B161 , LONGWOOD 32779

Insp Date: 08/20/2026

Inspection Number: 3735972

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Volusia

License Number: 7403206

JON HALL SNACK BAR

License Type: Food

551 N NOVA RD , DAYTONA BCH 41701

Insp Date: 08/17/2026

Inspection Number: 3729953

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.-small fryer on counter

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403206

JON HALL SNACK BAR

License Type: Food

551 N NOVA RD , DAYTONA BCH 41701

Insp Date: 08/17/2026

Inspection Number: 3729953

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

49-01-4

Flammables stored/debris present in water heater room . For reporting purposes only.-boxes stored around water heater

Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 7407486

BEACH HUT CANTINA

License Type: Food

250 N ATLANTIC AVE STE 206 , DAYTONA BEACH 32118

Insp Date: 08/18/2026

Inspection Number: 3767804

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.-unit on wall at entrance in refill red zone

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Volusia

License Number: 7407486

BEACH HUT CANTINA

License Type: Food

250 N ATLANTIC AVE STE 206 , DAYTONA BEACH 32118

Insp Date: 08/18/2026

Inspection Number: 3767804

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.-full size propane tank on floor in dining area **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7451179

ZNZ SWEET TREATS LLC

License Type: Food

2220 HIBISCUS DR STE 7 , EDGEWATER 32141

Insp Date: 08/20/2026

Inspection Number: 1347597

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Volusia

License Number: 7407562

KING'S GRANDMAS SUPREME CUISINE

License Type: Food

560 DR MARY MCLOUD BETHUNE BLVD UNIT A & B, DAYTONA BEACH 32114

Insp Date: 08/20/2026

Inspection Number: 3756181

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit doorsFront door has a hasp on the exterior.Rear door at sliding lock. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407660

KULTCHA SHACK LLC

License Type: Food

322 SEABREEZE BLVD , DAYTONA BEACH 32118

Insp Date: 08/19/2026

Inspection Number: 3733020

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.-back door, operator stated closed/locked due to security concerns. Operator unlocked during inspection **Corrected On-Site**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Volusia

License Number: 7402587

PATS RIVERFRONT CAFE

License Type: Food

3300 PENINSULA DR , PORT ORANGE 32127

Insp Date: 08/18/2026

Inspection Number: 3713922

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

47-02-4

Observation

Observed scorch marks around electrical outlet. For reporting purposes only.-outlet on ceiling at cookline

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.