

**Alachua County**

License Number: 1102633 MOM'S OG  
 License Type: Permanent Food Service 1017 W UNIVERSITY AVE, GAINESVILLE 32601

Inspection Date: 01/04/2024 Inspection Number: 3414195 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended  
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Under towel dispenser outside of beer walk in cooler. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1102495 NOPAL BY CINTRON  
 License Type: Permanent Food Service 5112 NW 34 BLVD, GAINESVILLE 32605

Inspection Date: 01/03/2024 Inspection Number: 3384986 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In dry storage hall.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103453 WORLD OF BEER TIOGA  
 License Type: Permanent Food Service 140 SW 128 ST STE A & B, NEWBERRY 32669

Inspection Date: 01/04/2024 Inspection Number: 3377706 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BERRY, JOHNNY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank stored beside ice machine in storage area of kitchen. Manager stated the tank was expanded placed it behind the restaurant during this inspection. <b>**Corrected On-Site**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1304997

THAI BASIL RESTAURANT

License Type: Permanent Food Service

1001 BECK AVE, PANAMA CITY 32401

Inspection Date: 01/04/2024

Inspection Number: 3414171

Inspection Type: Complaint Partial

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class by dish washer in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1506733

PHO THIEN VIETNAMESE KITCHEN

License Type: Permanent Food Service

2447 N WICKHAM RD STE 106, MELBOURNE 32935

Inspection Date: 01/03/2024

Inspection Number: 3377872

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRAYBOY, LYNN

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher in recharge by rice cooker in kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Broward County**

License Number: 1618721

STAND #115

License Type: Permanent Food Service

1 PANTHER PARKWAY, SUNRISE 33323

Inspection Date: 01/05/2024

Inspection Number: 3322522

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MIGHTY, NICOLA

Violation Code    ObservationViolation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.  
Observed boiler certificate expired 4/21/23.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1618722

BUD TERRACE

License Type: Permanent Food Service

1 PANTHER PKWY, SUNRISE 33323

Inspection Date: 01/05/2024

Inspection Number: 3346411

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MIGHTY, NICOLA

Violation Code    ObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  
Observed boiler certificate expired 4/21/23.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1618723

STAND #108

License Type: Permanent Food Service

1 PANTHER PKWY, SUNRISE 33323

Inspection Date: 01/05/2024

Inspection Number: 3328532

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MIGHTY, NICOLA

Violation Code    ObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  
Observed boiler certificate expired 4/21/23.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1618736

STAND #105

License Type: Permanent Food Service

1 PANTHER PKWY, SUNRISE 33323

Inspection Date: 01/05/2024

Inspection Number: 3340294

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MIGHTY, NICOLA

Violation Code    ObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate expired 4/21/23.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



**Broward County**

License Number: 1618741

STAND #430

License Type: Permanent Food Service

1 PANTHER PKWY, SUNRISE 33323

Inspection Date: 01/05/2024

Inspection Number: 3340421

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MIGHTY, NICOLA

Violation Code    ObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  
Observed boiler certificate expired 4/21/23.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1618742

STAND #405

License Type: Permanent Food Service

1 PANTHER PKWY, SUNRISE 33323

Inspection Date: 01/05/2024

Inspection Number: 3358550

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MIGHTY, NICOLA

Violation Code    ObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  
Observed boiler certificate expired 4/21/23.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1623365

SKY LEVEL CLUB

License Type: Permanent Food Service

1 PANTHER PKWY, SUNRISE 33323

Inspection Date: 01/05/2024

Inspection Number: 3334439

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MIGHTY, NICOLA

Violation Code    ObservationViolation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.  
Observed boiler certificate expired 4/21/23.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Charlotte County**

License Number: 1801069

THE OLIVE GARDEN ITALIAN RESTAURANT 1197

License Type: Permanent Food Service

1341 TAMIAMI TRL, PORT CHARLOTTE 33948

Inspection Date: 01/04/2024

Inspection Number: 3385832

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TARTAGLIONE, EVA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed backdoor exit blocked with 4 slim Jim trash cans and a crate with a mini refrigerator on it.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Clay County**

License Number: 2001108

SUBWAY #33908

License Type: Permanent Food Service

2851 HENLEY RD #100, GREEN COVE SPRINGS 32043

Inspection Date: 01/05/2024

Inspection Number: 3414325

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BUCKLER, MANDY

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Back door exit blocked by empty cardboard boxes and mop bucket.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





**Duval County**

License Number: 2652131 CHUBBY BURRITO 2  
 License Type: Mobile Food Dispensing Vehicle 4333 ST AUGUSTINE RD, JACKSONVILLE 32207

Inspection Date: 01/03/2024 Inspection Number: 1280376 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank larger than 2.7 pounds stored near back door of truck next to cooking equipments	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2609811 THE MITT TEX-MEX CAFE  
 License Type: Permanent Food Service 4130 SALISBURY RD STE 1000, JACKSONVILLE 32216

Inspection Date: 01/03/2024 Inspection Number: 3403297 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator uses stove and flat top plug in electrical grill in kitchen area with no hood system **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612011 MCDONALD'S #18040  
 License Type: Permanent Food Service 8570 ARGYLE FOREST BLVD, JACKSONVILLE 32244

Inspection Date: 01/04/2024 Inspection Number: 3321573 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Side exit door in dry storage area blocked by multiple boxes and trash container. Manager asked employee to remove boxes/container. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Flagler County**

License Number: 2800837

MARCO'S PIZZA

License Type: Permanent Food Service

782 BELLE TERRE PKWY, PALM COST 32164

Inspection Date: 01/04/2024

Inspection Number: 3361586

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HARTMANN, MICHELLE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. By boxes. Person in charge removed boxes. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hernando County**

License Number: 3701133

FUJIYAMA JAPANESE STEAKHOUSE

License Type: Permanent Food Service

12070 CORTEZ BLVD, BROOKSVILLE 34613

Inspection Date: 01/05/2024

Inspection Number: 3366840

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: SEXTON, CODY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. In server area near hand sink between hibachi tables

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Highlands County**

License Number: 3800292

SCHOONI'S ITALIAN AMERICAN RESTAURANT

License Type: Permanent Food Service

209 N MAIN AVE, LAKE PLACID 33852

Inspection Date: 01/03/2024

Inspection Number: 3375653

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: JACKS, ALBERT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only at line.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4607350 TIKI SUBS & MEXICAN PLACE  
 License Type: Permanent Food Service 16203 SAN CARLOS BLVD, FORT MYERS 33908

Inspection Date: 01/03/2024 Inspection Number: 3391224 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SOMMERS, KARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building/enclosure. For reporting purposes only. Educated operator on not storing lp gas tanks inside. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4602416 CANTINA CAPTIVA LLC  
 License Type: Permanent Food Service 14970 CAPTIVA DR, CAPITIVA 33924

Inspection Date: 01/04/2024 Inspection Number: 3365389 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: YURDAKUL, AYKAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Exposed wires throughout kitchen and dining room. Breaker panels no covers, main electrical feed's exposed when employees working in the area and guests entering to use restrooms.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Leon County**

License Number: 4703661

CANOPY ROAD CAFÉ

License Type: Permanent Food Service

1779 APALACHEE PARKWAY UNIT 107, TALLAHASSEE 32301

Inspection Date: 01/05/2024

Inspection Number: 3372292

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K class on cook line in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5402727

SLICE OF PARADISE OF THE FLORIDA KEYS

License Type: Permanent Food Service

24458 OVERSEAS HWY, SUMMERLAND KEY 33042

Inspection Date: 01/04/2024

Inspection Number: 3412967

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603961 JIMMY BUFFETT'S MARGARITAVILLE  
 License Type: Permanent Food Service 76 HARBOR BLVD, DESTIN 32541

Inspection Date: 01/04/2024 Inspection Number: 3414209 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: STEINMAN, MARC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
49-02-4	Flammables stored in bottom kitchen next to ice machine. Gas powered pressure washer . . . For reporting purposes only.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 5603962 JIMMY BUFFETT'S MARGARITAVILLE CAFE 2ND FLOOR  
 License Type: Permanent Food Service 76 HARBOR BLVD, DESTIN 32541

Inspection Date: 01/04/2024 Inspection Number: 3414210 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: STEINMAN, MARC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



**Pasco County**

License Number: 6100318

SUNNYSIDE UP

License Type: Permanent Food Service

14148 US 19 N, HUDSON 34667

Inspection Date: 01/03/2024

Inspection Number: 3361531

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: EASLER, VERONICA

Violation Code

Observation

Violation Citation

47-02-4

- From initial inspection : Observed scorch marks and fire damage on outer shed ceiling and walls directly outside of rear kitchen door containing the mop sink and water heater. For reporting purposes only. - From follow-up inspection 2024-01-03: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Putnam County**

License Number: 6400914

GOLDEN GLORY CAFE

License Type: Permanent Food Service

816 ST JOHNS AVE, PALATKA 32177

Inspection Date: 01/04/2024

Inspection Number: 3385531

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERKINS, MARC

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
Propane gas tank stored inside kitchen by the three compartment sink.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6806049

BELLA VINO ITALIAN PASTARIA &amp; TACOS &amp; TEQUILA LLC

License Type: Permanent Food Service

3983 DESTINATION DR, OSPREY 34229

Inspection Date: 01/04/2024

Inspection Number: 3389608

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: RODARTE, ERIC

Violation Code   ObservationViolation Citation48-04-4   Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside  
of the kitchen. For reporting purposes only.509.032(2)(d) FS Reporting: (d) The division, or its  
agent, shall notify the local firesafety authority or the  
State Fire Marshal of any readily observable violation of  
a rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.

License Number: 6804763

ICHIBAN RESTAURANT

License Type: Permanent Food Service

2724 STICKNEY POINTE RD, SARASOTA 34231

Inspection Date: 01/03/2024

Inspection Number: 3413809

Inspection Type: Complaint Full

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: RODARTE, ERIC

Violation Code   ObservationViolation Citation46-04-4   Rear exit door locked at the back of he dining area. For reporting purposes only.  
\*\*Repeat Violation\*\*509.032(2)(d) FS Reporting: (d) The division, or its  
agent, shall notify the local firesafety authority or the  
State Fire Marshal of any readily observable violation of  
a rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.

License Number: 6803649

THE ITALIAN GRILL

License Type: Permanent Food Service

8620 S TAMIAMI TR, SARASOTA 34238

Inspection Date: 01/04/2024

Inspection Number: 3389234

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: CATTLEY, RAYMOND

Violation Code   ObservationViolation Citation45-05-4   Portable fire extinguisher missing from its designated location. For reporting  
purposes only. Observed by dry storage.509.032(2)(d) FS Reporting: (d) The division, or its  
agent, shall notify the local firesafety authority or the  
State Fire Marshal of any readily observable violation of  
a rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.



