

**Alachua County**

License Number: 1102860 PINK FLAMINGO  
 License Type: Permanent Food Service 19726 NW US HWY 441, HIGH SPRINGS 32643

Inspection Date: 01/16/2024 Inspection Number: 3379076 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 behind outside bar area and 1 in screened porch area. Manager moved items to outside storage next to dumpster. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103140 GREAT OUTDOORS RESTAURANT  
 License Type: Permanent Food Service 18587 HIGH SPRINGS MAIN ST, HIGH SPRINGS 32643

Inspection Date: 01/16/2024 Inspection Number: 3381338 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BAILEY, KIMBERLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By the back door in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Bradford County**

License Number: 1400176

ORANGE BLOSSOMS

License Type: Permanent Food Service

7154 SE COUNTY RD 21 B, KEYSTONE HEIGHTS 32656

Inspection Date: 01/16/2024

Inspection Number: 3377982

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: PERKINS, MARC

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
In the back dry storage room, propane gas tank stored on the floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





**Collier County**

License Number: 2103397

ROSATI'S OF NAPLES

License Type: Permanent Food Service

818 NEOPOLITAN WAY, NAPLES 34103

Inspection Date: 01/18/2024

Inspection Number: 3381874

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MEADE, ARTHUR

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Back exit door locked, and very difficult to be unlocked and opened. Door is in disrepair.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2335073 TOWN PLACE SUITES BY MARRIOT MIAMI LAKES  
 License Type: Permanent Food Service 8079 NW 154 ST, MIAMI LAKES 33016

Inspection Date: 01/16/2024 Inspection Number: 3345630 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate expired for boiler. For reporting purposes only. Observed boiler jurisdiction number's FL124043 and FL124050 both expired on 10/14/2022.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2323910 PIZZA HUT #710710  
 License Type: Permanent Food Service 2750 W 68 ST SUITE 104, HIALEAH 330165446

Inspection Date: 01/17/2024 Inspection Number: 3338309 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MIRABAL, MAYRELIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334828 EL TUCAN / MARION  
 License Type: Permanent Food Service 1111 SW 1 AVE CU #1-2, MIAMI 33130

Inspection Date: 01/19/2024 Inspection Number: 3327878 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329978 RITMOS PRODUCTION INC  
 License Type: Catering 7165 SW 47 ST STE 312, MIAMI 33155

Inspection Date: 01/17/2024 Inspection Number: 1124874 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Observed storage racks stored in front of side exit door. - From follow-up inspection 2024-01-17: Marked exit/path to marked exit blocked. For reporting purposes only. Observed storage racks stored in front of side exit door. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-04-4	- From initial inspection : Exit door locked. For reporting purposes only. - From follow-up inspection 2024-01-17: Exit door locked. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331868 IN & OUT BAGELS AND MORE  
 License Type: Permanent Food Service 18800 NE 29 AVE STE 9, AVENTURA 33180

Inspection Date: 01/16/2024 Inspection Number: 3394150 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: TAYLOR, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a flat grill added in kitchen area with no hood suppression system installed. **Repeat Violation** **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a flat grill added in kitchen area with no hood suppression system installed. **Warning** - From follow-up inspection 2024-01-16: Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a flat grill added in kitchen area with no hood suppression system installed. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330303 STEVE'S PIZZA WEST  
 License Type: Permanent Food Service 16285 SW 88 ST, MIAMI 33196

Inspection Date: 01/16/2024 Inspection Number: 3329957 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: ASTROQUIZA, MIGUEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	- From initial inspection : Exit door locked. For reporting purposes only. Observed back exit door near bathrooms locked. Operator unlocked door. **Corrected On-Site** **Repeat Violation** - From follow-up inspection 2024-01-16: Observed back exit door near bathrooms locked. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2615505

THE LOOP PIZZA GRILL

License Type: Permanent Food Service

14035 BEACH BLVD SUITE 101, JACKSONVILLE 32250

Inspection Date: 01/18/2024

Inspection Number: 3373094

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: CENTENO, ANGEL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Observed fire extinguisher on cook line in red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3912268

THINH AN KITCHEN & TOFU

License Type: Permanent Food Service

8104 W WATERS AVE, TAMPA 33615

Inspection Date: 01/17/2024

Inspection Number: 3342596

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ZHANG, JACKY

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



**Leon County**

License Number: 4703415

KOREAN BBQ & MORE

License Type: Permanent Food Service

1490 APALACHEE PKWY, TALLAHASSEE 32301

Inspection Date: 01/16/2024

Inspection Number: 3414633

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HAND, NATASHA

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 25 lbs. propane tank in cooking area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5400243

7 MILE GRILL

License Type: Permanent Food Service

1240 OVERSEAS HWY, MARATHON 33050

Inspection Date: 01/18/2024

Inspection Number: 3386345

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Extinguisher Outside Near back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5801751

RTK INDIAN CUISINE

License Type: Permanent Food Service

401 N SEMRON BLVD, WINTERPARK 32792

Inspection Date: 01/16/2024

Inspection Number: 3375341

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Door at the buffet is blocked at lunch by the buffet . Door is lighted as a EXIT

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pasco County**

License Number: 6113867

RHYTHM PON DE GRILLE

License Type: Permanent Food Service

5822 GRAND ORO LANE STE 106, WESLEY CHAPEL 33544

Inspection Date: 01/18/2024

Inspection Number: 3398440

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MOULDER, BRITTANY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
Observed mini fryer stored on prep table adjacent to hand sink

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Sarasota County**

License Number: 6803469

WOK INN

License Type: Permanent Food Service

1287 S BENEVA RD, SARASOTA 34232

Inspection Date: 01/16/2024

Inspection Number: 3396723

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YOTHERS, DANIEL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed a fire extinguisher in the back of the kitchen under pressure in the red. As a repeat violation the importance of following proper protocol with this violation was reinforced with the employee. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6904717

RIVERWALK PIZZERIA

License Type: Permanent Food Service

5040 W STATE ROAD 46 STE 1102, SANFORD 32771

Inspection Date: 01/16/2024

Inspection Number: 3383110

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JENKINS, ELAINE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
-oil boxes and supplies are partially blocking rear exit door area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7404930		CHECKERS #6261	
License Type: Permanent Food Service		898 N NOVA RD, DAYTONA BEACH 32117	
Inspection Date: 01/18/2024	Inspection Number: 3373945	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: RUTLEDGE, REBECCA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. - path to back exit door blocked by chair, trash can, large box, two flat grills, and K class fire extinguisher	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7404501		BOOTHILL SALOON	
License Type: Permanent Food Service		310 MAIN ST, DAYTONA BEACH 32118	
Inspection Date: 01/19/2024	Inspection Number: 3378334	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WOOD, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. -on wall near back door adjacent to retail side of establishment	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7407318		C S WAFFLES	
License Type: Permanent Food Service		1700 STATE RD 44, NEW SMYRNA BEACH 32168	
Inspection Date: 01/16/2024	Inspection Number: 3374171	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PICHARDO, RENEE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Emergency exit marked back door blocked by trifold room divider and storage rack	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7407540		TIPSY TACO CANTINA	
License Type: Permanent Food Service		746 S ATLANTIC AVE, ORMOND BEACH 32176	
Inspection Date: 01/16/2024	Inspection Number: 3379952	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: RUTLEDGE, REBECCA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	2 unit tabletop fryer not under fire suppression system.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	