

**Alachua County**

License Number: 1103654

WAFFLE HOUSE #2387

License Type: Permanent Food Service

915 E UNIVERSITY AVE, GAINESVILLE 32601

Inspection Date: 01/23/2024

Inspection Number: 3391574

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
In the recharge zone by the back door. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1506695 TEQUILA VEINTIUNO CAFE AND PALETERIA  
 License Type: Permanent Food Service 2311 FL-524, STE 106, COCOA 32926

Inspection Date: 01/26/2024 Inspection Number: 3417010 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended  
 Inspector Name: FRANZ, LINDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-04-4	Flammables stored/debris present in indoors back hallway to back exit, plastic gas can with gas stored on chemical shelf.. For reporting purposes only.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 1506264 NOLAN'S IRISH PUB  
 License Type: Permanent Food Service 204 W COCOA BEACH CSWY, COCOA BEACH 32931

Inspection Date: 01/22/2024 Inspection Number: 3372055 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: FICHTER, GARRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. In kitchen and dry storage room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Citrus County**

License Number: 1901242

CHINA GOURMET

License Type: Permanent Food Service

9435 S SUNCOAST BLVD, HOMOSASSA 34446

Inspection Date: 01/23/2024

Inspection Number: 3417042

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SEXTON, CODY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
-fire extinguisher near hot water heater gauge in red

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Clay County**

License Number: 2001271

TIJUANA FLATS BURRITO CO

License Type: Permanent Food Service

1647 CR 220 #103, FLEMING ISLAND 32003

Inspection Date: 01/26/2024

Inspection Number: 3388143

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BUCKLER, MANDY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Fire extinguisher at front register area showing in need of recharging.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2102451

JUANITAS

License Type: Permanent Food Service

204 BOSTON AVE, IMMOKALEE 34142

Inspection Date: 01/22/2024

Inspection Number: 3388495

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: METCALF, VIRGIL

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed fire exit obstructed with child seats. operator moved kids chairs. \*\*Corrected On-Site\*\* \*\*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2332499		RESIDENCE INN BY MARRIOTT	
License Type: Permanent Food Service		1201 NW 42 AVE, MIAMI 33126	
Inspection Date: 01/24/2024	Inspection Number: 3337572	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  FI 059124 11/02/2023, FI 059125 11/02/2023, FI 059256 11/2/2023, FI095982 11/2/2023, FI 59260 11/2/2023 **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2325908		TIPICO HONDURENO	
License Type: Permanent Food Service		3002 NW 7 AVE, MIAMI 33127	
Inspection Date: 01/24/2024	Inspection Number: 3332324	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SAENZ, HILDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed at the storage room by the preparation area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2335807		MIA MARKET	
License Type: Permanent Food Service		140 NE 39 ST #241, MIAMI 33137	
Inspection Date: 01/24/2024	Inspection Number: 3328329	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CRUZ, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed Pasta Bar Station.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2336230		CHEF YANK CORPORATION	
License Type: Permanent Food Service		7900 NW 27TH AVE F06, MIAMI 33147	
Inspection Date: 01/25/2024	Inspection Number: 3346234	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LODENQUAI, BARRINGTON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed in the kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2336497 AL FORNO NEAPOLITAN WOOD FIRED PIZZA  
 License Type: Permanent Food Service 10674 SW 24 ST, MIAMI 33165

Inspection Date: 01/26/2024 Inspection Number: 3365323 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed back exit door blocked with trash can and boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336806 THE KETO KITCHEN MIAMI  
 License Type: Permanent Food Service 9640 CORAL WAY, MIAMI 33165

Inspection Date: 01/25/2024 Inspection Number: 3347735 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher in red zone across from back exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2321698 PASTELITOS CARLOS  
 License Type: Permanent Food Service 7868 NW 52 ST, DORAL 33166

Inspection Date: 01/23/2024 Inspection Number: 3405911 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed Extinguisher in recharge zone located by restrooms.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2336039

TRIPPING ANIMALS BREWERY

License Type: Permanent Food Service

2685 NW 105 AVE, DORAL 33172

Inspection Date: 01/22/2024

Inspection Number: 3364626

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 472243, 32969, 7/11/2023. Expired.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 Propane tanks inside kitchen. Operator removed both tanks. <b>**Corrected On-Site**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613418		GANGNAM KOREAN RESTAURANT	
License Type: Permanent Food Service		5161 BEACH BLVD STE 5, JACKSONVILLE 32207	
Inspection Date: 01/24/2024	Inspection Number: 3376239	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By mop sink **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2613737		DAIRY QUEEN 43205	
License Type: Permanent Food Service		9012 NEW KINGS RD, JACKSONVILLE 32219	
Inspection Date: 01/25/2024	Inspection Number: 3417227	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher on floor in back kitchen area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2615645		MODU RAMEN	
License Type: Permanent Food Service		8602 BAYMEADOWS RD UNIT 24, JACKSONVILLE 32256	
Inspection Date: 01/22/2024	Inspection Number: 3385046	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: BADDING, MELANIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two propane tanks in back dry storage room with dry food storage. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2614883		GREEN TEA	
License Type: Permanent Food Service		10059 SAN JOSE BLVD., UNIT #4, JACKSONVILLE 32257	
Inspection Date: 01/22/2024	Inspection Number: 3384780	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOSAI, MATT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by empty boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Escambia County**

License Number: 2706648

VIBES AND SMOOTHIES

License Type: Permanent Food Service

314 N DEVILLIERS ST, PENSACOLA 32501

Inspection Date: 01/26/2024

Inspection Number: 3331572

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Flagler County**

License Number: 2800678

PALM HARBOR GRILL

License Type: Permanent Food Service

9 HARBOR CENTER DR #11, PALM COAST 32137

Inspection Date: 01/22/2024

Inspection Number: 3379184

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: HARTMANN, MICHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher is in red. Extinguisher by back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back door off dining room blocked by supplies. Person in charge moved supplies. <b>**Corrected On-Site**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hernando County**

License Number: 3701133 FUJIYAMA JAPANESE STEAKHOUSE  
 License Type: Permanent Food Service 12070 CORTEZ BLVD, BROOKSVILLE 34613

Inspection Date: 01/25/2024 Inspection Number: 3366840 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: MEAKINS, ALLISON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. In server area near hand sink between hibachi tables - From follow-up inspection 2024-01-05: <b>**Time Extended**</b> - From follow-up inspection 202	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3700460 HARDEE'S  
 License Type: Permanent Food Service 6292 COMMERCIAL WAY, WEEKI WACHEE 34613-6329

Inspection Date: 01/24/2024 Inspection Number: 3329603 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SEXTON, CODY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher near office gauge in red	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3916085

BEEF O BRADYS

License Type: Permanent Food Service

13326 LINCOLN ROAD, RIVERVIEW 33578

Inspection Date: 01/22/2024

Inspection Number: 3379034

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRUZ, JABULANI

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Back door blocked with cart, operator removed at time of inspection. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Indian River County**

License Number: 4105442	LATIN MELTING POT
License Type: Permanent Food Service	2017 INDIAN RIVER BLVD, VERO BEACH 32960
Inspection Date: 01/24/2024	Inspection Number: 3377369
Inspector Name: SCHNEIDER, KIM	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. 2 portable fryers	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4105198	SIR B
License Type: Permanent Food Service	2605 45 STREET, VERO BEACH 32967
Inspection Date: 01/26/2024	Inspection Number: 3394368
Inspector Name: MITTEN, JAMES	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5428276

OVERSEAS PUB AND GRILL

License Type: Permanent Food Service

3574 OVERSEAS HWY, MARATHON 33050

Inspection Date: 01/25/2024

Inspection Number: 3380923

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

45-02-4

Near ice machine the Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5808285		JIMMY HULA'S RESTAURANT	
License Type: Permanent Food Service		2522 ALOMA AVE, WINTER PARK 32792	
Inspection Date: 01/22/2024	Inspection Number: 3326818	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Missing switch cover at the walk in cooler	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5806781		TACO BELL 1223299	
License Type: Permanent Food Service		5147 S KIRKMAN RD, ORLANDO 32819	
Inspection Date: 01/25/2024	Inspection Number: 3372685	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CLARKE, ALBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door blocked by fryer equipment.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5815669		LAS CASITAS	
License Type: Permanent Food Service		457 S AVALON PARK BLVD STE 100, ORLANDO 32828	
Inspection Date: 01/22/2024	Inspection Number: 3361249	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: WHITE, THOMAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. <b>**Warning**</b> - From follow-up inspection 2024-01-22: <b>**Time Extended**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5815376		WENDY'S 12485	
License Type: Permanent Food Service		7690 PALM PARKWAY, ORLANDO 32836	
Inspection Date: 01/25/2024	Inspection Number: 3378306	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Trash. <b>**Corrected On-Site**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Osceola County**

License Number: 5911172 QUEENS & KING MEXICAN KITCHEN  
 License Type: Permanent Food Service 324 BROADWAY, KISSIMMEE 34741

Inspection Date: 01/17/2024 Inspection Number: 3379046 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable k class fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5901134 MCDONALDS 11085  
 License Type: Permanent Food Service 3191 S JOHN YOUNG PKWY, KISSIMMEE 34746

Inspection Date: 01/26/2024 Inspection Number: 3334067 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SMITH JONES, SHANTASIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Boxes on a dolly. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6217087

NUEVA CANTINA

License Type: Permanent Food Service

1625 4 ST S, ST PETERSBURG 33701

Inspection Date: 01/22/2024

Inspection Number: 3392346

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MURPHY, JAMES

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.  
Fire extinguisher used to prop open door to chemical supply closet.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6802049		BOATYARD WATERFRONT BAR & GRILL	
License Type: Permanent Food Service		1500 STICKNEY POINT RD, SARASOTA 34231	
Inspection Date: 01/24/2024	Inspection Number: 3391160	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: RODARTE, ERIC			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed the exit door blocked in the kitchen. Observed an exit path blocked on the patio.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6802967		OUTBACK STEAKHOUSE	
License Type: Permanent Food Service		7207 S TAMIAMI TRL, SARASOTA 34231	
Inspection Date: 01/23/2024	Inspection Number: 3393835	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RODARTE, ERIC			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed the rear exit in the dining area blocked with a laundry cart. The operator moved the cart from the exit. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6806036		MIA'S VIETNAMESE CUISINE	
License Type: Permanent Food Service		2720 STICKNEY POINT RD, SARASOTA 34231	
Inspection Date: 01/23/2024	Inspection Number: 3394674	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RODARTE, ERIC			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Rear exit door locked. For reporting purposes only. The operator unlocked the exit door. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6805914		LIDO BEACH TIKI BAR	
License Type: Permanent Food Service		700 BEN FRANKLIN DR, SARASOTA 34236	
Inspection Date: 01/22/2024	Inspection Number: 3377135	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MCKEON, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 propane tanks stored in a hallway near the ice machine. Chef removed the tanks. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Volusia County**

License Number: 7407210	KALE CAFE
License Type: Permanent Food Service	116 N BEACH ST, DAYTONA BEACH 32114
Inspection Date: 01/24/2024	Inspection Number: 3345474
Inspector Name: BRANNER, LISELOTTE	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. -3 in Mopsink room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407419	FAMOUS PHILLY'S CHEESESTEAK GRILL
License Type: Permanent Food Service	1173 W INTERNATIONAL SPEEDWAY, BLVD STE 3, DAYTONA BEACH 32114
Inspection Date: 01/23/2024	Inspection Number: 3380468
Inspector Name: BRANNER, LISELOTTE	Inspection Type: Routine - Food
	Inspection Disposition: Administrative complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -bicycle in front of rear exit by bathrooms	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407790	STOKED POKE
License Type: Permanent Food Service	260 DAYTONA BLVD D-440, DAYTONA BEACH 32114
Inspection Date: 01/22/2024	Inspection Number: 3377190
Inspector Name: BRANNER, LISELOTTE	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back exit partial blocked by old equipment reach in cooler and grills on top of reach in cooler. Tables and chairs in front of next business doors back door-manager moved	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407497	JACKIES JAMAICA POT
License Type: Permanent Food Service	996 DERBYSHIRE RD, DAYTONA BEACH 32117
Inspection Date: 01/25/2024	Inspection Number: 3392780
Inspector Name: RUTLEDGE, REBECCA	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7407578 YUKI SUSHI HIBACHI  
 License Type: Permanent Food Service 1964 STATE RD 44, NEW SMYRNA BEACH 32168

Inspection Date: 01/24/2024 Inspection Number: 3392175 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PICHARDO, RENEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Hallway to back door from dining room blocked by curtain, cases of beer, speed rack, other items <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407540 TIPSYP TACO CANTINA  
 License Type: Permanent Food Service 746 S ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 01/23/2024 Inspection Number: 3379952 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending  
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : 2 unit tabletop fryer not under fire suppression system. - From follow-up inspection 2024-01-23: <b>**Time Extended**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407580 BEACHSIDE CAFE AND DONUTS  
 License Type: Permanent Food Service 1350 OCEAN SHORE BLVD UNIT F, ORMOND BEACH 32176

Inspection Date: 01/23/2024 Inspection Number: 3384554 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.