

Alachua County

License Number: 1103642

SPURRIER'S GRIDIRON GRILLE FIRST FLOOR

License Type: Permanent Food Service

4860 SW 31 PL #20, GAINESVILLE 32608

Inspection Date: 01/29/2024

Inspection Number: 3392527

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
 Observed: the Exit (marked) door by the ice machine, was blocked by a rolling cart. The cart was moved away. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1302975

TOKYO PANAMA CITY FL

License Type: Permanent Food Service

144 E 23 ST, PANAMA CITY 32405

Inspection Date: 01/31/2024

Inspection Number: 3418004

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. 2 extinguishers at north end of building and 1 extinguisher by bar in recharge zone.
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1653608

LOS SABORES DE MI TIERRA

License Type: Mobile Food Dispensing Vehicle

324 S FEDERAL HWY, DANIA BEACH 33004

Inspection Date: 02/02/2024

Inspection Number: 1271777

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

45-01-4 No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2334231		THE PLAZA MARKET	
License Type: Permanent Food Service		913 BRICKELL AVE, MIAMI 33131	
Inspection Date: 01/31/2024	Inspection Number: 3382162	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2325776		CHEZ LE BEBE RESTAURANT	
License Type: Permanent Food Service		114 NE 54TH STREET, MIAMI 33137	
Inspection Date: 01/29/2024	Inspection Number: 3370919	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: GRODEWALD, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher on wall next to restrooms. Fire extinguisher on wall at end of cook line.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2332596		SALUMERIA 104	
License Type: Permanent Food Service		3451 NE 1 AVE STE 104-105, MIAMI 33137	
Inspection Date: 01/30/2024	Inspection Number: 3326029	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BAILEY, KIMBERLY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Multiple stored in walk in cooler storage room, tanks are usually used for outside heaters.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2333630		HALF MOON EMPANADAS	
License Type: Permanent Food Service		860 NE 79 ST, MIAMI 33138	
Inspection Date: 02/02/2024	Inspection Number: 3351280	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRODEWALD, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher next to back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2316834	GREAT HOUSE REST (THE)		
License Type: Permanent Food Service	5000 TOWERSIDE TERR, MIAMI 331382233		
Inspection Date: 01/30/2024	Inspection Number: 3332026	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: GRODEWALD, PAUL			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two propane tanks stored in kitchen. Mana moved tanks outside.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336217	SOL BISTRO		
License Type: Permanent Food Service	7400 SW 88 STREET, 6TH FLOOR, MIAMI 33156		
Inspection Date: 01/31/2024	Inspection Number: 3352636	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: LEIDECKER, EDILMA			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Duval County

License Number: 2612841		LONGHORN STEAKHOUSE 5147	
License Type: Permanent Food Service		4401 ROOSEVELT BLVD, JACKSONVILLE 32210	
Inspection Date: 01/30/2024	Inspection Number: 3404648	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: YARBERRY, BEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher located next to prep area and front line of kitchen in red.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2600389		SPICES CARIBBEAN RESTAURANT	
License Type: Permanent Food Service		1319 ROGERO RD, JACKSONVILLE 32211	
Inspection Date: 01/29/2024	Inspection Number: 3361156	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: ROBINSON, EMERY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed large propane tank inside detached building adjacent to licensed establishment. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2609701		KUSINA	
License Type: Permanent Food Service		4190 BELFORT RD SUITE 120, JACKSONVILLE 32216	
Inspection Date: 02/02/2024	Inspection Number: 3398829	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VILBRUN, JOSUE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator has stove top for cooking and frying and not under hood suppression system * **Repeat Violati	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2608622		PAGODA REST AT BAYMEADOWS	
License Type: Permanent Food Service		8617 BAYMEADOWS RD, JACKSONVILLE 32256	
Inspection Date: 01/31/2024	Inspection Number: 3371487	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: BADDING, MELANIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by back door in red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2613647 PANDA HOUSE
 License Type: Permanent Food Service 7643 GATE PKWY STE 106, JACKSONVILLE 32256
 Inspection Date: 01/30/2024 Inspection Number: 3391190 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BADDING, MELANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by back door in red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615014 AL SHAMI
 License Type: Permanent Food Service 8606 BAYMEADOWS RD #22-23, JACKSONVILLE 32256
 Inspection Date: 01/31/2024 Inspection Number: 3385028 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BADDING, MELANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment has two table top fryers in use in kitchen, no hood over units.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2614949 LEONAS CUCINA
 License Type: Permanent Food Service 10550 OLD ST AUGUSTINE RD STE 6, JACKSONVILLE 32257
 Inspection Date: 02/01/2024 Inspection Number: 3384994 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment has two bay fryer on counter top with no hood system	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hendry County

License Number: 3600555

THE CUBAN DELY

License Type: Permanent Food Service

216 S MAIN ST, LABELLE 33935

Inspection Date: 01/30/2024

Inspection Number: 3378638

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: METCALF, VIRGIL

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed rear kitchen fire door dead bolted.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917953

DUNKIN DONUTS # 2224

License Type: Permanent Food Service

1930 NORTH DALE MABRY HIGHWAY, TAMPA 33607

Inspection Date: 01/31/2024

Inspection Number: 3339788

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MOULDER, BRITTANY

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.
 Observed red fire extinguisher stored under hand sink adjacent to manager desk
 Corrected observed employee place on shelf in plastic container labeled and plac

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4500866

HARDEE'S #1500724

License Type: Permanent Food Service

301 E BURLEIGH BLVD, TAVARES 32778

Inspection Date: 02/01/2024

Inspection Number: 3417992

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: GUTTERMAN, KENNETH

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
- back door block with trash

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605261

EMJAYS TAVERN & GRILL

License Type: Permanent Food Service

700 LEELAND HEIGHTS BLVD W, LEHIGH ACRES 33936

Inspection Date: 02/01/2024

Inspection Number: 3382164

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: METCALF, VIRGIL

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Observed rear exit fire door locked.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Levy County

License Number: 4800651

1998 GRILL

License Type: Permanent Food Service

17751 NW US HWY 19, FANNING SPRINGS 32693

Inspection Date: 01/31/2024

Inspection Number: 3417368

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BERRY, JOHNNY

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Propane tank inside kitchen near cookline. Manager stated the system was being tested and the tank could not be removed.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202981

WENDY'S 11678

License Type: Permanent Food Service

11191 N WILLIAMS ST, DUNNELLO 34432

Inspection Date: 01/29/2024

Inspection Number: 3375008

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BERRY, JOHNNY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher gauge in the red in kitchen near back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5815806	SUSHI SAGA		
License Type: Permanent Food Service	6551 N ORANGE BLOSSOM TRL UNIT 221, MOUNT DORA	32757	
Inspection Date: 02/02/2024	Inspection Number: 3386374	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CONNOLLY, MADELINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked next to register For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5808285	JIMMY HULA'S RESTAURANT		
License Type: Permanent Food Service	2522 ALOMA AVE, WINTER PARK	32792	
Inspection Date: 01/29/2024	Inspection Number: 3326818	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Missing switch cover at the walk in cooler - From follow-up inspection 2024-01-29: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5812922	MICHEL RESTAURANT		
License Type: Permanent Food Service	2680 S RIO GRANDE AVE, ORLANDO	32805	
Inspection Date: 01/29/2024	Inspection Number: 3346336	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: LINDSAY, SHARON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-03-4	- From initial inspection : Fuel- burning equipment inside an enclosed. For reporting purposes only. Lawnmower inside dining area. - From follow-up inspection 2023-12-08: **Time Extended** - From follow-up inspection 2024-01-29: **Time Extended	509.211(2)(a) FS Reporting: (2) (a) It is unlawful for any person to use within any public lodging establishment or public food service establishment any fuel-burning wick-type equipment for space heating unless such equipment is vented so as to prevent the accumulation of toxic or injurious gases or liquids. For reporting purposes only.	

Osceola County

License Number: 5910377

TROPICO MOFONGO LATIN FOOD

License Type: Permanent Food Service

3160 VINELAND RD UNIT 2, KISSIMMEE 34746

Inspection Date: 02/02/2024

Inspection Number: 3364788

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: SMITH JONES, SHANTASIA

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryers added to facility not placed under hood system. - From fol

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6005675 MARRIOTT WEST PALM BEACH HOTEL 1001 BISTRO
 License Type: Permanent Food Service 1001 OKEECHOBEE BLVD, WEST PALM BEACH 33401

Inspection Date: 01/30/2024 Inspection Number: 3391903 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: AHLE, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6006527 HILTON PALM BEACH AIRPORT
 License Type: Permanent Food Service 150 AUSTRALIAN AVE, WEST PALM BEACH 33406

Inspection Date: 01/29/2024 Inspection Number: 3407260 Inspection Type: Complaint Full Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: FRANCE, GASTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2023-11-28: **Time Extended** - From follow-up ins	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6012480 GRILLE ROOM
 License Type: Permanent Food Service 11501 EL CLAIR RANCH RD, BOYNTON BEACH 33437

Inspection Date: 02/01/2024 Inspection Number: 3392624 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6218373		ST PETE BREWING COMPANY LLC	
License Type: Permanent Food Service		538-544 1 AVE N, ST. PETERSBURG 33701	
Inspection Date: 02/01/2024	Inspection Number: 3360935	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MURPHY, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguishers on floor in rear storage area. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6216674		WENDY'S PROPERTIES LLC	
License Type: Permanent Food Service		4840 PARK ST, ST. PETERSBURG 33709	
Inspection Date: 01/31/2024	Inspection Number: 3394174	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOWEY, JANINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Trash cart in front of back door exit. Manager moved cart. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6216720		HOLIDAY INN	
License Type: Permanent Food Service		1200 34TH ST N, ST. PETERSBURG 33713	
Inspection Date: 02/01/2024	Inspection Number: 3407695	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Warning Issued
Inspector Name: HOWEY, JANINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on floor next to soda boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Sarasota County

License Number: 6803501

ROYAL PEACOCK INDIAN KITCHEN

License Type: Permanent Food Service

5445 FRUITVILLE RD, SARASOTA 34232

Inspection Date: 02/03/2024

Inspection Number: 3399796

Inspection Type: Routine - Food

Inspection Disposition: Emergency

Inspector Name: YOTHERS, DANIEL

Order Callback Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the back fire extinguisher under pressure in the red. - From follow-up inspection 2024-02-03: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the back fire extinguisher under pressure in the red.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405468 TACO BELL #27
 License Type: Permanent Food Service 2140 W INTERNATIONAL SPDWY BLVD, DAYTONA BEACH 32114
 Inspection Date: 02/01/2024 Inspection Number: 3384252 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-03-4	Gas odor by fryers. For reporting purposes only. Manager called maintenance	509.211(2)(a) FS Reporting: (2) (a) It is unlawful for any person to use within any public lodging establishment or public food service establishment any fuel-burning wick-type equipment for space heating unless such equipment is vented so as to prevent the accumulation of toxic or injurious gases or liquids. For reporting purposes only.

License Number: 7407323 HOULIGAN'S A SPIRITED SPORTS GRILLE
 License Type: Permanent Food Service 1725 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114
 Inspection Date: 02/01/2024 Inspection Number: 3382166 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -Stairway exit by door partial blocked by tiles **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7402455 STROUDS HOG HEAVEN
 License Type: Permanent Food Service 37 N ATLANTIC AVE, DAYTONA BEACH 32118
 Inspection Date: 02/02/2024 Inspection Number: 3391775 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -marked fire exit door at west end of dining area blocked by sign **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
49-03-4	Flammables stored/debris present in water heater room. For reporting purposes only. -packaged paper products, cardboard boxed items, furniture(wood/vinyl/fabric)	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Volusia County

License Number: 7407565		PONCHO'S TACOS & ICE CREAM	
License Type: Permanent Food Service		201 SEABREEZE BLVD, DAYTONA BEACH 32118	
Inspection Date: 02/02/2024	Inspection Number: 3390926	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WOOD, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. -on wall next to hand sink on cook line	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7404002		CATON CATERING	
License Type: Permanent Food Service		2295 S RIDGEWOOD AVE, SOUTH DAYTONA 32119	
Inspection Date: 01/31/2024	Inspection Number: 3381958	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: COREY, DEREK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only. **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7407046		BRUNOS PIZZA	
License Type: Permanent Food Service		1254 OCEAN SHORE BLVD, ORMOND BEACH 32176	
Inspection Date: 01/30/2024	Inspection Number: 3385519	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: RUTLEDGE, REBECCA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7450501		TIERRA CALIENTE FOOD TRUCK LLC` (FOOD TRUCK 1	
License Type: Mobile Food Dispensing Vehicle		509 S SPRING GARDEN AVE, DELAND 32720	
Inspection Date: 02/01/2024	Inspection Number: 1280412	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OCASIO-LOPEZ, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 20 lb and 10 lb tank of propane connected to griddle. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	