

Brevard County

License Number: 1505935

CAUSEWAY DINER

License Type: Permanent Food Service

3712 N COURTENAY PKWY #102 & 104, MERRITT ISLAND 32953

Inspection Date: 02/08/2024

Inspection Number: 3418836

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: FICHTER, GARRICK

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Near rear unisex restroom

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1609045 AT'S A PIZZA
 License Type: Permanent Food Service 6714 N UNIVERSITY DR, TAMARAC 33321

Inspection Date: 02/08/2024 Inspection Number: 3405473 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SILVA, DENIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked by flour container. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1617970 TACO BELL # 135
 License Type: Permanent Food Service 2451 N UNIVERSITY DR, SUNRISE 33322

Inspection Date: 02/08/2024 Inspection Number: 3418849 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIGHTY, NICOLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked trash can and cardboard boxes. Manager removed. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Charlotte County

License Number: 1850161

BAYLOR'S SOUTHERN SOUL FOOD

License Type: Mobile Food Dispensing Vehicle

771 DOBELL TERRACE, PORT CHARLOTTE 33948

Inspection Date: 02/07/2024

Inspection Number: 1276807

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TARTAGLIONE, EVA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Scheduled to have recharged through Fire Prevention.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2001136 CHILI'S GRILL & BAR
 License Type: Permanent Food Service 2005 E WEST PKWY, FLEMING ISLAND 32003

Inspection Date: 02/05/2024 Inspection Number: 3354773 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BUCKLER, MANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed heater in outside storage room with a 130 gallon capacity. No boiler report available. Operator unaware it is a boiler. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2001100 HUDDLE HOUSE #581
 License Type: Permanent Food Service 4094 CR 218, MIDDLEBURG 32068

Inspection Date: 02/07/2024 Inspection Number: 3333128 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: BUCKLER, MANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back exit door blocked by multiple empty boxes.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2316424 EL MANI RESTAURANT
 License Type: Permanent Food Service 1200 NW 78 AVE STE 116, MIAMI 33126

Inspection Date: 02/06/2024 Inspection Number: 3348947 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed a propane gas inside the kitchen. Manager took it out **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2333584 COYO TACO
 License Type: Permanent Food Service 1111 SW 1ST AVE UNIT 4, MIAMI 33130

Inspection Date: 02/08/2024 Inspection Number: 3351727 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MAKOWSKI, JARED

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two 20lb propane tanks stored inside restaurant.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329026 EL TAMBO GRILL
 License Type: Permanent Food Service 7118-7126 SW 117TH AVE, MIAMI 33183

Inspection Date: 02/08/2024 Inspection Number: 3367744 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ASTROQUIZA, MIGUEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605265

HOMEWOOD SUITES BY HILTON BONITA SPRINGS

License Type: Permanent Food Service

8901 HIGHLAND WOODS BLVD, BONITA SPRINGS 34135

Inspection Date: 02/08/2024

Inspection Number: 3347044

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANKLIN, JOY

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. . Boiler certificates expired 10-23-21 090304, 10-23-21 090305 **Repeat Violation**

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Leon County

License Number: 4702551

SAM'S COUNTRY BUFFET INC

License Type: Permanent Food Service

1214 CAPITAL CIR SE STE D&E, TALLAHASSEE 32301

Inspection Date: 02/06/2024

Inspection Number: 3380808

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

45-06-4

Portable fire extinguisher is inaccessible. For reporting purposes only. Extinguisher by back door obstructed by ladder and rolled up mats. K class by dish pit obstructed by dish rack. Operator moved items away from extinguisher at time of inspection. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5104333

GOLDEN CORRAL #871

License Type: Permanent Food Service

5525 W CORTEZ RD, BRADENTON 34210

Inspection Date: 02/06/2024

Inspection Number: 3418434

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SURWILLO, JACQUELINE

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.Observed no boiler certification or inspection.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Marion County

License Number: 5202748

RAINBOW'S END GOLF CLUB

License Type: Permanent Food Service

20650 SW 80 PL RD, DUNNELLON 34432

Inspection Date: 02/07/2024

Inspection Number: 3389616

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BERRY, JOHNNY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
One fire extinguisher on wall outside back door in red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6013789

OVATIONS FOOD SERVICES LP MAIN KITCHEN

License Type: Catering

650 OKEECHOBEE BLVD, WEST PALM BEACH 33401

Inspection Date: 02/09/2024

Inspection Number: 1126448

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation Code

Observation

Violation Citation

48-01-5

Expired insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

13323 , 13324 , 121640 , 6/11/2022

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6020895

GANZO

License Type: Permanent Food Service

14811 LYONS RD STE 106, DELRAY BEACH 33446

Inspection Date: 02/05/2024

Inspection Number: 3390091

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at cook line fire extinguisher

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6218386

TERIYAKI MADNESS

License Type: Permanent Food Service

7253 PARK BLVD N STE 4, PINELLAS PARK 33781

Inspection Date: 02/05/2024

Inspection Number: 3361874

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HOWEY, JANINE

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.
2 extinguisher on floor in back area next to CO2 tank.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6805281 LOPERA BAKERY BISTROT
 License Type: Permanent Food Service 2336 GULF GATE DR, SARASOTA 34231

Inspection Date: 02/07/2024 Inspection Number: 3388468 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RODARTE, ERIC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805880 BRINE SEAFOOD & RAW BAR
 License Type: Permanent Food Service 2250 GULF GATE DRIVE, SARASOTA 34231

Inspection Date: 02/07/2024 Inspection Number: 3394140 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RODARTE, ERIC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. The operator removed the propane tanks. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6803501 ROYAL PEACOCK INDIAN KITCHEN
 License Type: Permanent Food Service 5445 FRUITVILLE RD, SARASOTA 34232

Inspection Date: 02/03/2024 Inspection Number: 3399796 Inspection Type: Routine - Food Inspection Disposition: Emergency Order Callback Complied
 Inspector Name: YOTHERS, DANIEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the back fire extinguisher under pressure in the red. - From follow-up inspection 2024-02-03: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905050

BJ'S RESTAURANT & BREWHOUSE 561

License Type: Permanent Food Service

8285 RED BUG LAKE RD, OVIEDO 32765

Inspection Date: 02/06/2024

Inspection Number: 3341516

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VO, STEVE

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
- gas water heater with btu rating of 499,999 and max psi rating of 160.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Volusia County

License Number: 7403951	HAMPTON INN DAYTONA SPEEDWAY AIRPORT		
License Type: Permanent Food Service	1715 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114-1303		
Inspection Date: 02/09/2024	Inspection Number: 3363694	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -exit from food storage to next room both marked exits partial blocked by boxes and ladders.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407865	UN GIRO ITALIAN PIZZA AND GRILL		
License Type: Permanent Food Service	515 N ATLANTIC AVE, DAYTONA BEACH 32118		
Inspection Date: 02/05/2024	Inspection Number: 3392347	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WOOD, JUSTIN			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. -back fire exit door, manager unlocked **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.