

Alachua County

License Number: 1103021		JIMMY JOHN'S 2644	
License Type: Permanent Food Service		4123 NW 16 BLVD, GAINESVILLE 32605	
Inspection Date: 02/12/2024	Inspection Number: 3367706	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BAILEY, KIMBERLY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. In the recharge zone across from soda machine in dining room. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1103320		PEPPERS MEXICAN GRILL & CANTINA	
License Type: Permanent Food Service		7750 W NEWBERRY RD, GAINESVILLE 32606	
Inspection Date: 02/13/2024	Inspection Number: 3392568	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: GRODEWALD, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher next to back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1103628		SENSEI ASIAN BISTRO	
License Type: Permanent Food Service		4860 SW 31 PL #10, GAINESVILLE 32608	
Inspection Date: 02/16/2024	Inspection Number: 3398834	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CASEY, KEITH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed: by the back door, 2 liquid propane tanks stored inside. The outside storage is being reworked to accommodate the tanks.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1103314		WAFFLE HOUSE	
License Type: Permanent Food Service		5130 NW 13 ST, GAINESVILLE 32609	
Inspection Date: 02/16/2024	Inspection Number: 3396093	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: GRODEWALD, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher behind front counter.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Alachua County

License Number: 1103428 ADAMS RIB CO
 License Type: Permanent Food Service 2109 NW 13TH ST, GAINESVILLE 32609

Inspection Date: 02/16/2024 Inspection Number: 3396345 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: GRODEWALD, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher next to back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103683 YOUNG KITCHEN
 License Type: Permanent Food Service 13682 SW ST RD 45, ARCHER 32618

Inspection Date: 02/13/2024 Inspection Number: 3395454 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: BERRY, JOHNNY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank stored inside kitchen near back door. Manager removed tank from building during this inspection. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505613

LILI'S BEACHSIDE RESTAURANT

License Type: Permanent Food Service

240 HWY A1A, SATELLITE BEACH 32937

Inspection Date: 02/12/2024

Inspection Number: 3391764

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRAYBOY, LYNN

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver extinguisher by dish pit area is in recharge.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620158 CLUB LEVEL CONCIERGE LOUNGE
 License Type: Permanent Food Service 3555 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 02/15/2024 Inspection Number: 3355742 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Certification for boilers expired 08/10/2023. Fire Marshall inspected boilers 7/31/2023. Engineering department awaiting permits to correct violations cited by fire marshal before current certification is issued.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1620159 SOUTH TOWER PREP AREA
 License Type: Permanent Food Service 3575 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 02/15/2024 Inspection Number: 3361681 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Certification for boilers expired 08/10/2023. Fire Marshall inspected 7/31/2023. Engineering department awaiting permits to correct violations cited by fire marshal before current certification is issued.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1620160 MEETING ROOM BR KITCHEN PREP AREA
 License Type: Permanent Food Service 3555 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 02/15/2024 Inspection Number: 3343600 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Certification for boilers expired 08/10/2023. Fire Marshall inspected boilers 7/31/2023. Engineering department awaiting permits to correct violations cited by fire marshal before current certification is issued.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Broward County

License Number: 1620238 KOSHER KITCHEN
 License Type: Permanent Food Service 3575 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 02/15/2024 Inspection Number: 3361753 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Certification for boilers expired 08/10/2023. Fire Marshall inspected 7/31/2023. Engineering department awaiting permits to correct violations cited by fire marshal before current certification is issued.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1620241 GARDE MANGER 1M CONVENTION
 License Type: Permanent Food Service 3575 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 02/15/2024 Inspection Number: 3343499 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Certification for boilers expired 08/10/2023. Engineering department awaiting permits to correct violations cited by fire marshal before current certification is issued. Fire Marshall inspected boilers 7/31/2023.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Citrus County

License Number: 1901349 CEDAR RIVER SEAFOOD OF INVERNESS INC
 License Type: Permanent Food Service 804 US HWY 41 S, INVERNESS 34450

Inspection Date: 02/16/2024 Inspection Number: 3394092 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: DEMARCO, AMBER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in cook line area - From follow-up inspection 2024-02-16: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in cook line area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2001036	MERCURY MOON BAR & GRILLE
License Type: Permanent Food Service	2015 COUNTY RD, FLEMING ISLAND 32003
Inspection Date: 02/15/2024	Inspection Number: 3369214
Inspector Name: BUCKLER, MANDY	Inspection Type: Routine - Food
	Inspection Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed a 15 pound propane tank across from the ice machine.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001202	FUSHIMI SUSHI
License Type: Permanent Food Service	1786 BLANDING BLVD STE 13, MIDDLEBURG 32068
Inspection Date: 02/15/2024	Inspection Number: 3393788
Inspector Name: BUCKLER, MANDY	Inspection Type: Routine - Food
	Inspection Disposition: Administrative complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher at back exit door has the gauge showing needing recharging. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001373	KOREAN HOUSE
License Type: Permanent Food Service	1540 WELLS ROAD #14, ORANGE PARK 32073
Inspection Date: 02/16/2024	Inspection Number: 3395066
Inspector Name: BUCKLER, MANDY	Inspection Type: Routine - Food
	Inspection Disposition: Emergency order recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. On dish machine at box where start button is located, an extension cord connection is attached and operator must use another piece of extension cord-not plugged in-wrapped with electrical tape at the end to operate machine.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2103812

SARKURA JAPAN

License Type: Permanent Food Service

12975 COLLIER BLVD STE 104, NAPLES 34116

Inspection Date: 02/16/2024

Inspection Number: 3405295

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MEADE, ARTHUR

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In kitchen attached to a Wok.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2360488		CHEESEBURGER BABY	
License Type: Mobile Food Dispensing Vehicle		940 NE 79TH ST, MIAMI 33138	
Inspection Date: 02/16/2024	Inspection Number: 1275657	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VO, STEVE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2326775		ISSABELLA'S	
License Type: Permanent Food Service		1022 LINCOLN RD, MIAMI BEACH 33139	
Inspection Date: 02/14/2024	Inspection Number: 3383926	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SWIGERT, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed four by the employee restroom.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2359414		SUSHI EXPRESS	
License Type: Mobile Food Dispensing Vehicle		3995 NW 25ST, MIAMI 33142	
Inspection Date: 02/15/2024	Inspection Number: 1272036	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RAMON, JESSICA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 tank.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2360108		CHURROWORLD CO.	
License Type: Mobile Food Dispensing Vehicle		2732 SW 137TH AVE, MIAMI 33175	
Inspection Date: 02/13/2024	Inspection Number: 1274268	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RAMON, JESSICA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2337176 TRATTORIA DAL PLIN
 License Type: Permanent Food Service 9420 NW 41 ST #109, DORAL 33178

Inspection Date: 02/13/2024 Inspection Number: 3369387 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: MERCADO, GLORYMAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boiler units at 650,000 BTU's without certification located at boiler room/ dry storage. **Repeat Violation** - From follow-up inspection 2024-02-13: During the time of callback inspection observed No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boiler units at 650,000 BTU's without certification located at boiler room/ dry storage. **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2361046 T&F COFFEE AND CO
 License Type: Mobile Food Dispensing Vehicle 13920 SW 139 CT, MIAMI 33186

Inspection Date: 02/09/2024 Inspection Number: 1284830 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2614229

LA NOPALERA MEXICAN RESTAURANT

License Type: Permanent Food Service

9734 CROSSHILL BOULEVARD, JACKSONVILLE 32222

Inspection Date: 02/12/2024

Inspection Number: 3326797

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher by bar.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3905611 APOLLO BEACH DINER
 License Type: Permanent Food Service 6048 N US HWY 41, APOLLO BEACH 33572

Inspection Date: 02/14/2024 Inspection Number: 3395326 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRUZ, JABULANI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back door blocked with bread. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906679 HAVANA 86
 License Type: Permanent Food Service 3434 W COLUMBUS DR #101, TAMPA 33607

Inspection Date: 02/15/2024 Inspection Number: 3374742 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MOULDER, BRITTANY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed fryer on prep table adjacent to grill top on cookline	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918831 TAQUERIA FAMILIAR
 License Type: Permanent Food Service 1450 SKIPPER RD, TAMPA 33613

Inspection Date: 02/14/2024 Inspection Number: 3393504 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VINSON, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4603639

EL PILON RESTAURANT INC

License Type: Permanent Food Service

4650 S CLEVELAND AVE, FORT MYERS 33907

Inspection Date: 02/13/2024

Inspection Number: 3392335

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YURDAKUL, AYKAN

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
 Observed propane tank larger than 1 lb stored in kitchen.
 Operator removed correct storage at outside. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5150455

TAQUERIA MI REINA

License Type: Mobile Food Dispensing Vehicle

1880 63RD AVE E, BRADENTON 34203

Inspection Date: 02/14/2024

Inspection Number: 1282281

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: AUBIN, GARY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. As a repeat violation the importance of following proper protocol with this violation was reinforced with the manager. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5815421 TROPICAL PARADISE RESTAURANT AND BAKERY INC
 License Type: Permanent Food Service 73 S SEMORAN BLVD, ORLANDO 32807

Inspection Date: 02/14/2024 Inspection Number: 3401797 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MERRILL, RICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer on table. Operator moved fryer to up under hood **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5812312 MRS POTATO RESTAURANT
 License Type: Permanent Food Service 4550 S KIRKMAN RD, ORLANDO 32811

Inspection Date: 02/14/2024 Inspection Number: 3398477 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JAMES-HARDEN, ALDEAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Gas container (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Gas container stored at back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814534 SAGOS BAR AND GRILL
 License Type: Permanent Food Service 8040 PALM PKWY, ORLANDO 32836

Inspection Date: 02/15/2024 Inspection Number: 3376668 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: CONNOLLY, MADELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Osceola County

License Number: 5910817 CHINATOWN OF KISSIMMEE LLC
 License Type: Permanent Food Service 1158 W OSCEOLA PKWY, KISSIMMEE 34741

Inspection Date: 02/13/2024 Inspection Number: 3386339 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-06-4	Portable fire extinguisher is not accessible. For reporting purposes only. Red extinguisher at back door, tucked into back corner-On the floor	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5907663 WOODSBYS CAFE
 License Type: Permanent Food Service 4515 S ORANGE BLOSSOM TRL, KISSIMMEE 34746-4214

Inspection Date: 02/13/2024 Inspection Number: 3418963 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SMITH JONES, SHANTASIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. In the kitchen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6011834 TASSO'S GREEK TAVERNA
 License Type: Permanent Food Service 14802 S MILITARY TRL, DELRAY BEACH 33484

Inspection Date: 02/12/2024 Inspection Number: 3383706 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Flammables stored near a source of ignition. For reporting purposes only. Flammable aerosols stored directly behind oven. Operator removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6021638 WOOD & FIRE
 License Type: Permanent Food Service 5199 W. ATLANTIC AVENUE, DELRAY BEACH 33484

Inspection Date: 02/13/2024 Inspection Number: 3389816 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed at front counter. Exit blocked by storage cabinet. Operator removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6020685 CHEZ MARIE FRENCH BISTROT
 License Type: Permanent Food Service 5030 CHAMPION BLVD #D3, BOCA RATON 33496

Inspection Date: 02/14/2024 Inspection Number: 3399805 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6150861 MEXICAN CRAVINGS
 License Type: Mobile Food Dispensing Vehicle 15014 US 19, HUDSON 34667

Inspection Date: 02/13/2024 Inspection Number: 1279723 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EASLER, VERONICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system working. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6214879		THE BIG CATCH AT SALT CREEK	
License Type: Permanent Food Service		1500 2 ST S, ST. PETERSBURG 33701	
Inspection Date: 02/13/2024	Inspection Number: 3419222	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: MURPHY, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher in office area on a shelf and not secured to designated location.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6218508		BAY ROUTE LLC	
License Type: Permanent Food Service		4480 PARK ST N, ST. PETERSBURG 33709	
Inspection Date: 02/13/2024	Inspection Number: 3381790	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOWEY, JANINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on floor next oil tank	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6214318		CHARLEY'S PHILLY STEAKS	
License Type: Permanent Food Service		2260 TYRONE SQUARE, ST. PETERSBURG 33710	
Inspection Date: 02/15/2024	Inspection Number: 3410479	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOWEY, JANINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher under hand sink in kitchen area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6214322		PIERR'S EATERY	
License Type: Permanent Food Service		6901 22 AVE N UNIT VC08, ST. PETERSBURG 33710	
Inspection Date: 02/15/2024	Inspection Number: 3419578	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: HOWEY, JANINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher under soda machine on the floor	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6217067 JUNGLE PRADA TAVERN
 License Type: Permanent Food Service 1700 PARK ST N, ST. PETERSBURG 33710

Inspection Date: 02/16/2024 Inspection Number: 3412046 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: HOWEY, JANINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguishers on floor in prep area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216720 HOLIDAY INN
 License Type: Permanent Food Service 1200 34TH ST N, ST. PETERSBURG 33713

Inspection Date: 02/13/2024 Inspection Number: 3407695 Inspection Type: Food-Licensing Inspection Inspection Disposition: Call Back - Complied
 Inspector Name: HOWEY, JANINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	- From initial inspection : Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on floor next to soda boxes. - From follow-up inspection 2024-02-13: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215650 WENDY'S PROPERTIES LLC
 License Type: Permanent Food Service 900 S MISSOURI AVE, CLEARWATER 33756

Inspection Date: 02/13/2024 Inspection Number: 3379989 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PEARCE, LAURA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone by back door . For reporting purposes only	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216595 WINGHOUSE BAR + GRILL
 License Type: Permanent Food Service 2640 GULF TO BAY BLVD, CLEARWATER 33759

Inspection Date: 02/13/2024 Inspection Number: 3355287 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-02-4	Flammables stored/debris present in storage area. For reporting purposes only. 2 propane tanks stored in stored room.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Sarasota County

License Number: 6801966 SHOGUN JAPANESE STEAKHOUSE
 License Type: Permanent Food Service 1219 S 41 BY-PASS, VENICE 34292

Inspection Date: 02/13/2024 Inspection Number: 3394896 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RODARTE, ERIC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Observed the rear exit door locked near the walk in cooler.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6802148 PERKINS RESTAURANT
 License Type: Permanent Food Service 1331 S 41 BYPASS, VENICE 34292

Inspection Date: 02/15/2024 Inspection Number: 3393730 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: RODARTE, ERIC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked in the back storage area. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406391		D I S PRODUCTION KITCHEN AREA 1 AND 2	
License Type: Catering		1801 W INTNL SPEEDWAY BLVD, DAYTONA BEACH 32114	
Inspection Date: 02/15/2024	Inspection Number: 1126261	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per boiler inspector they are aware of the situation with the flow switch and that it will be replace as soon as parts are made available. There are three other safety devices on these boilers to prevent A the boiler from over heating if water flow is stopped or interrupted. The boiler Safety Section is allowing these boilers to operate and expect the violation to be clearedA up int the few weeks	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 7407825		RIVERSIDE JOHNNY'S	
License Type: Permanent Food Service		115 MAIN ST, DAYTONA BEACH 32118	
Inspection Date: 02/13/2024	Inspection Number: 3402604	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WOOD, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -fire exit located on north end near entrance to kitchen blocked by stacked stools. Advised person in charge to clear obstructions to fire exits at beginning of shift.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7405344		BOONDOCKS PORT ORANGE	
License Type: Permanent Food Service		3948 S PENINSULA DR, PORT ORANGE 32127	
Inspection Date: 02/13/2024	Inspection Number: 3398179	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WOOD, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked/obstructed. For reporting purposes only. -large cooler obstructing door marked with fire exit on side kitchen entrance near walk in coolers. Manager stated that intention is to move/swap fridges to clear obstruction.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7400445		LITTLE GRIDDLE LLC	
License Type: Permanent Food Service		412 CANAL ST, NEW SMYRNA BEACH 32168	
Inspection Date: 02/14/2024	Inspection Number: 3402558	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PICHARDO, RENEE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only. Back door next to ice machine	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Volusia County

License Number: 7406732

DUNKIN DONUTS AND BASKIN ROBBINS

License Type: Permanent Food Service

441 3 RD AVE, NEW SMYRNA BEACH 32169

Inspection Date: 02/13/2024

Inspection Number: 3327670

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PICHARDO, RENEE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.