

**Alachua County**

License Number: 1103205		ICE CREAM AND CREPES EATERY	
License Type: Permanent Food Service		1025 W UNIVERSITY AVE, GAINESVILLE 32601	
Inspection Date: 02/29/2024	Inspection Number: 3420360	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BAILEY, KIMBERLY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. In front of Handwash sink extinguisher is in the recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1150277		LA MARACUCHA FOOD & SERVICES	
License Type: Mobile Food Dispensing Vehicle		1025 W UNIVERSITY AVE, GAINESVILLE 32601	
Inspection Date: 02/29/2024	Inspection Number: 1284180	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BAILEY, KIMBERLY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. In the recharge zone the extinguisher by the microwave and reach in freezer. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1103609		CAVA	
License Type: Permanent Food Service		1404 W UNIVERSITY AVE STE 20, GAINESVILLE 32603	
Inspection Date: 02/27/2024	Inspection Number: 3420380	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: CASEY, KEITH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed: a sign on the wall by the cook line, for a K-Class fire extinguisher, the hook is empty, nothing visible on the floor nearby. Later the Kclass was found behind the Co2 tanks.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1102750		HILTON UNVIERISTY OF FLORIDA CONFERENCE CENTER GAINESVILLE	
License Type: Permanent Food Service		1714 SW 34 ST, GAINESVILLE 32607	
Inspection Date: 03/01/2024	Inspection Number: 3392718	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: GRODEWALD, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificate expired on 12/29/2022.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

**Alachua County**

License Number: 1103063

BAYMONT INN & SUITES

License Type: Permanent Food Service

6901 NW 4 BLVD, GAINESVILLE 32607

Inspection Date: 02/27/2024

Inspection Number: 3364723

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  
Boiler certificate expired on 5/23/2023. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.







**Collier County**

License Number: 2103095

SUNBURST CAFE

License Type: Permanent Food Service

2340 PINE RIDGE ROAD, NAPLES 34109

Inspection Date: 02/28/2024

Inspection Number: 3393136

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MEADE, ARTHUR

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. In kitchen area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2336467		MIAMI PIZZA CO	
License Type: Permanent Food Service		7801 NW 95 ST #6, HIALEAH GARDENS 33016	
Inspection Date: 02/28/2024	Inspection Number: 3404882	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MIRABAL, MAYRELIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed trash cans in front of exit door. Manager removed trash cans. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2336294		CAFETERIA MIAMI	
License Type: Permanent Food Service		1150 NW 72 AVE STE 160, MIAMI 33126	
Inspection Date: 02/27/2024	Inspection Number: 3405847	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, JULIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed double portable grease fryer, and three electric stoves, located in the kitchen with no hood suppression system. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2316188		PASEO CATRACHO	
License Type: Permanent Food Service		824 SW 8 ST, MIAMI 33130	
Inspection Date: 02/28/2024	Inspection Number: 3383143	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LYNN, NICKOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by back door, gauge in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2316342		TALKIN TACOS	
License Type: Permanent Food Service		97 SW 8 ST, MIAMI 33130	
Inspection Date: 03/01/2024	Inspection Number: 3417760	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: LYNN, NICKOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. K class in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2326758		ROCK BOY PIZZA	
License Type: Permanent Food Service		30 SW 8 ST, MIAMI 33130	
Inspection Date: 02/29/2024	Inspection Number: 3394643	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LYNN, NICKOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank connected to small oven near pizza display. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2332359		PIOLA	
License Type: Permanent Food Service		1250 S MIAMI AVE UNIT 105, MIAMI 33130	
Inspection Date: 02/26/2024	Inspection Number: 3399350	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SHANKLIN, CYNTHIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two 15 pound propane tanks stored in dry storage area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2334055		SERGIO'S CUBAN CAFE + GRILL	
License Type: Permanent Food Service		40 SW 12 ST, MIAMI 33130	
Inspection Date: 02/29/2024	Inspection Number: 3375223	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LYNN, NICKOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by fry oil reservoir in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2335927		LOST BOYS DRY GOODS	
License Type: Permanent Food Service		157 E FLAGLER STREET, MIAMI 33131	
Inspection Date: 02/26/2024	Inspection Number: 3385059	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed cooking meat balls no hood suppression system.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	



**Dade County**

License Number: 2329107		SETAI SOUTH BEACH	
License Type: Catering		2001 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 02/26/2024	Inspection Number: 1126189	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SWIGERT, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2330875		SETAI POOL BAR/ OCEAN GRILL AT THE SETAI	
License Type: Permanent Food Service		2001 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 02/26/2024	Inspection Number: 3381965	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SWIGERT, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2332418		FIFI'S ON THE BEACH	
License Type: Permanent Food Service		6930-34 COLLINS AVE, MIAMI BEACH 33141	
Inspection Date: 02/27/2024	Inspection Number: 3328248	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher located next to the dishwasher machine .	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2322868		LA NOUVELLE BOULANGERIE	
License Type: Permanent Food Service		328 CRANDON BLVD #125, KEY BISCAYNE 33149	
Inspection Date: 02/26/2024	Inspection Number: 3414660	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LYNN, NICKOLAS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by door in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	





**Dade County**

License Number: 2337174	POKE MIA		
License Type: Permanent Food Service	9420 NW 41 ST 101, DORAL 33178		
Inspection Date: 03/01/2024	Inspection Number: 3384813	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boiler units at 650,000 BTU's without certification located at boiler room/ dry storage. Hotels & Restaurants DDM Chi, informed the Division of State Fire Marshal, the authorized jurisdiction over certification of boilers on 8/23/2023, forwarding the agency information regarding boilers cited at Shoma Bazaar - food hall, 9420 NW 41 St. Doral, Fl. 33178. **Repeat Violation**		61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
License Number: 2337175	SHIMUJA		
License Type: Permanent Food Service	9420 NW 41 S UNIT 102, DORAL 33178		
Inspection Date: 03/01/2024	Inspection Number: 3418822	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boiler units at 650,000 BTU's without certification located at boiler room/ dry storage.  Hotels & Restaurants DDM Chi, informed the Division of State Fire Marshal, the authorized jurisdiction over certification of boilers on 8/23/2023, forwarding the agency information regarding boilers cited at Shoma Bazaar - food hall, 9420 NW 41 St. Doral, Fl. 33178.		61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
License Number: 2357419	COLOMBIAN EXTREME FOOD		
License Type: Mobile Food Dispensing Vehicle	13380 SW 131 ST UNIT 116, MIAMI 33186		
Inspection Date: 02/28/2024	Inspection Number: 1274967	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LODENQUAI, BARRINGTON			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only.		509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Hernando County**

License Number: 3701307

JERSEY MIKE'S SUBS

License Type: Permanent Food Service

12376 CORTEZ BLVD, BROOKSVILLE 34613

Inspection Date: 02/27/2024

Inspection Number: 3420390

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SEXTON, CODY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher near rear kitchen door gauge in red zone. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5105986

WENDY'S

License Type: Permanent Food Service

5100 CORTEZ RD W, BRADENTON 34210

Inspection Date: 02/27/2024

Inspection Number: 3388153

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SURWILLO, JACQUELINE

Violation Code

Observation

Violation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603986

TOWNE PLACE SUITES

License Type: Permanent Food Service

843 EGLIN PARKWAY, FORT WALTON BEACH 32547

Inspection Date: 02/28/2024

Inspection Number: 3363411

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only:

Establishment ha four boilers and all boiler certificates are expired: 130385, 11/27/2019; 130386, 11/27/2019; 130387, 11/27/2019. One boiler is offline awaiting replacement. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



**Orange County**

License Number: 5815878		CHUAN FU	
License Type: Permanent Food Service		1035 N ORLANDO AVE STE 105, WINTER PARK 32789	
Inspection Date: 02/28/2024	Inspection Number: 3398445	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. K class fire extinguisher at the kitchen exit door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5807930		TIJUANA FLATS BURRITO CO	
License Type: Permanent Food Service		7608 UNIVERSITY BLVD, WINTER PARK 327928815	
Inspection Date: 02/26/2024	Inspection Number: 3399002	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At the back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5812501		GRINGOS LOCOS	
License Type: Permanent Food Service		22 E WASHINGTON ST, ORLANDO 32801	
Inspection Date: 02/27/2024	Inspection Number: 3420421	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MERRILL, RICK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Flat top along wall. Per operator used to heat tortillas and cook eggs.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5805072		CENTERPLATE @ PHASE II KITCHEN	
License Type: Permanent Food Service		9800 INTERNATIONAL DR, ORLANDO 32819	
Inspection Date: 02/29/2024	Inspection Number: 3394739	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LUI, SUK HAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./FL 131317, expired 1/5/2024.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	



**Osceola County**

License Number: 5911421 SMITH FRANCHISE SERVICES  
 License Type: Permanent Food Service 54 RILEY ROAD, CELEBRATION 34747  
 Inspection Date: 02/28/2024 Inspection Number: 3420622 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: QUIJANO, LAUREN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-03-4	Flammables stored/debris present in boiler room. For reporting purposes only. Paint in water heater room.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 5911845 COWBOY CHICKEN  
 License Type: Permanent Food Service 3290 MARGARITAVILLE BLVD STE A100, KISSIMMEE 34747  
 Inspection Date: 02/26/2024 Inspection Number: 3379004 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: QUIJANO, LAUREN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by cart and trash can **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911551 DUNKIN DONUTS #2229  
 License Type: Permanent Food Service 800 CYPRESS PKWY, KISSIMMEE 34759  
 Inspection Date: 03/01/2024 Inspection Number: 3419818 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: QUIJANO, LAUREN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. By trash can and cardboard boxes. Preparing to do a trash run per operator. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6020878 KINGDOM SUSHI  
 License Type: Permanent Food Service 22191 POWERLINE RD BUILDING 26C, STE 140, BOCA RATON 33433  
 Inspection Date: 03/01/2024 Inspection Number: 3407036 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GONZALEZ, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on the floor by the women's restroom door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6020195 SALS ITALIAN RISTORANTE  
 License Type: Permanent Food Service 12355 HAGEN RANCH RD, BOYNTON BEACH 33437  
 Inspection Date: 02/26/2024 Inspection Number: 3348586 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed on cook line - From follow-up inspection 2024-02-26:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6019304 A & G RESTAURANTS LLC  
 License Type: Permanent Food Service 1210 LINTON BLVD, DELRAY BEACH 33444  
 Inspection Date: 02/28/2024 Inspection Number: 3398112 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KHATOON, BEGUM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only...stored discarded boxes front of the exit door . Operator removed. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6020796 LAKESIDE  
 License Type: Permanent Food Service 17557 CLARIDGE OVAL W, BOCA RATON 33496  
 Inspection Date: 02/27/2024 Inspection Number: 3419977 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GOODWIN, NICHOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed table top fryer in pizza section not under hood	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6215243 TOP SLICE  
 License Type: Permanent Food Service 21 3 ST N, ST. PETERSBURG 33701

Inspection Date: 02/29/2024 Inspection Number: 3390130 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on floor just inside back door area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215578 SUSHI INC  
 License Type: Permanent Food Service 270 1ST AVE N, ST. PETERSBURG 33701

Inspection Date: 02/26/2024 Inspection Number: 3397886 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MURPHY, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on floor by side door leading to 3rd street.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6306444

TAQUERIA MEDEROS

License Type: Permanent Food Service

2829 SWINDELL RD, LAKE LAND 33805

Inspection Date: 02/25/2024

Inspection Number: 3363530

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WHITE, CHERYL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking on flattop LP grill inside wooden building	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 tanks inside building	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6805328 PANERA BREAD #1600  
 License Type: Permanent Food Service 17899 TAMIAMI TRL, NORTH PORT 34287

Inspection Date: 02/27/2024 Inspection Number: 3397136 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: TARTAGLIONE, EVA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit blocked with cardboard. Observed operator removing cardboard and clearing path **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6804432 PAPA JOHN'S PIZZA  
 License Type: Permanent Food Service 1223 US 41 BYP S, VENICE 34292

Inspection Date: 02/28/2024 Inspection Number: 3414537 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RODARTE, ERIC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Rear exit door locked. For reporting purposes only. The operator unlocked the door. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903229

HEART OF JERUSALEM CAFE

License Type: Permanent Food Service

5683 RED BUG LAKE RD, WINTER SPRINGS 32708

Inspection Date: 02/26/2024

Inspection Number: 3395127

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VO, STEVE

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**St. Johns County**

License Number: 6502022

NONNA'S TRATTORIA

License Type: Permanent Food Service

2 AVILES ST, SAINT AUGUSTINE 32084

Inspection Date: 02/28/2024

Inspection Number: 3370913

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: MAKOWSKI, JARED

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
Observed two 20lb propane tanks stored inside storage room. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6603186

PUPUSERIA LAS DELICIAS RESTAURANT

License Type: Permanent Food Service

8757 S US HWY 1, PORT ST LUCIE 34952

Inspection Date: 03/01/2024

Inspection Number: 3354936

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Portable fryer being used on table top in kitchen. Contacted AHJ spoke with Jess.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Volusia County**

License Number: 7407046 BRUNOS PIZZA  
 License Type: Permanent Food Service 1254 OCEAN SHORE BLVD, ORMOND BEACH 32176

Inspection Date: 02/28/2024 Inspection Number: 3385519 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. <b>**Repeat Violation**</b> - From follow-up inspection 2024-02-28:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. -small table top fryers in use in back kitchen area. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407561 DUNKIN' DONUTS  
 License Type: Permanent Food Service 499 HOWLAND BLVD, DELTONA 32738

Inspection Date: 02/28/2024 Inspection Number: 3366294 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: JENKINS, ELAINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-06-4	Portable fire extinguisher is inaccessible. For reporting purposes only. -umbrella hanging on fire extinguisher <b>**Corrected On-Site**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.