

Bay County

License Number: 1305062

CATERING BY BOB

License Type: Permanent Food Service

1530 FLORIDA AVE, PANAMA CITY 32401

Inspection Date: 03/07/2024

Inspection Number: 3381380

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Extinguisher by dish room in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505646 SPACE COAST CONVENTION CENTER

License Type: Permanent Food Service 301 TUCKER LN, COCOA 32926

Inspection Date: 03/05/2024 Inspection Number: 3409674 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FRANZ, LINDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-01-4	Flammables stored/debris present in dry food stock room, being used as door stop. Portable propane bottle.. For reporting purposes only.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 1503695 KENTUCKY FRIED CHICKEN # 62
License Type: Permanent Food Service 6105 N HWY 1, PORT ST JOHN 32927-4923

Inspection Date: 03/05/2024 Inspection Number: 3401976 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FRANZ, LINDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Observed Electrical line from the counter top oven unit to plug frayed.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505717 PANERA BREAD STORE 2782
License Type: Permanent Food Service 275 E EAU GALLIE BLVD, INDIAN HARBOUR BEACH 32937

Inspection Date: 03/06/2024 Inspection Number: 3395125 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
Inspector Name: BRAYBOY, LYNN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher next to back door is in recharge zone. - From follow-up inspection 2024-03-06: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506460 EL PUEBLO MAGICO MEXICAN RESTAURANT
License Type: Permanent Food Service 2137 N COURTENAY PKWY, MERRITT ISLAND 32953

Inspection Date: 03/06/2024 Inspection Number: 3398404 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
Inspector Name: FICHTER, GARRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to rear storage room door, across from triple sink	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1624848 JERSEY MIKE'S SUBS
 License Type: Permanent Food Service 1750 N UNIVERSITY DR, CORAL SPRINGS 33071-6076

Inspection Date: 03/04/2024 Inspection Number: 3411354 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEWIS, LYNDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1622074 B-5 EVENT BAR
 License Type: Permanent Food Service 3101 BAYSHORE DR, FORT LAUDERDALE 33304

Inspection Date: 03/07/2024 Inspection Number: 3338789 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1622098 A-5 BAR
 License Type: Permanent Food Service 3101 BAYSHORE DR, FORT LAUDERDALE 33304

Inspection Date: 03/07/2024 Inspection Number: 3326980 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Broward County

License Number: 1622128		C-3 LOBBY BAR	
License Type: Permanent Food Service		3101 BAYSHORE DR, FORT LAUDERDALE 33304	
Inspection Date: 03/07/2024	Inspection Number: 3362557	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 1622154		C-5 WARMING KITCHEN	
License Type: Permanent Food Service		3101 BAYSHORE DR, FORT LAUDERDALE 33304	
Inspection Date: 03/07/2024	Inspection Number: 3362560	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per operator, boilers were recently re-certified. **Repeat Violation**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 1622156		POOL DECK BAR	
License Type: Permanent Food Service		3101 BAYSHORE DR, FORT LAUDERDALE 33304	
Inspection Date: 03/07/2024	Inspection Number: 3338402	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per operator, boilers were recently re-certified.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Charlotte County

License Number: 1801964

HOLIDAY INN EXPRESS & SUITES PUNTA GORDA

License Type: Permanent Food Service

9075 MAC DR, PUNTA GORDA 33950

Inspection Date: 03/06/2024

Inspection Number: 3400957

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. ****Repeat Violation****

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Citrus County

License Number: 1901457

THE SIDEBAR TAVERN

License Type: Permanent Food Service

203 COURTHOUSE SQ, INVERNESS 34450

Inspection Date: 03/05/2024

Inspection Number: 3391148

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DEMARCO, AMBER

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator is using flat top griddle in kitchen area without hood system

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2001235

LUCA'S ITALIAN AMERICAN RESTAURANT

License Type: Permanent Food Service

1339 BLANDING BLVD#8, ORANGE PARK 32065

Inspection Date: 03/07/2024

Inspection Number: 3406802

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only.
Rear exit door by restrooms is locked with large bar. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300147		JOES STONE CRABS RESTAURANT	
License Type: Permanent Food Service		11 WASHINGTON AVE, MIAMI BEACH 33139	
Inspection Date: 03/05/2024	Inspection Number: 3421019	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ASTROQUIZA, MIGUEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate ate expired on 10.21.2023.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2337215		ROMINA'S RISTORANTE ITALIANO	
License Type: Permanent Food Service		833 LINCOLN RD, MIAMI BEACH 33139	
Inspection Date: 02/05/2024	Inspection Number: 3366729	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SWIGERT, RICHARD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Observed: Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 5 large tanks in the private dining room. Priority: Reporting	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2335291		FORUM - BAR	
License Type: Permanent Food Service		3300 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 03/04/2024	Inspection Number: 3392712	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed missing extinguisher (second floor in front of the bar, next to the AHU room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2326699		THE COFFE POT	
License Type: Permanent Food Service		9682 NW 25 ST, DORAL 33172	
Inspection Date: 03/06/2024	Inspection Number: 3404806	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MIRABAL, MAYRELIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2335566 CHANA THAI
 License Type: Permanent Food Service 8737-39 SW 136TH STREET, MIAMI 33176

Inspection Date: 03/04/2024 Inspection Number: 3351998 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GONZALEZ, JULIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit blocked. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337032 DOGGI'S AREPA BAR
 License Type: Permanent Food Service 9420 NW 41 ST UNIT 105, DORAL 33178

Inspection Date: 03/07/2024 Inspection Number: 3395147 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boiler units at 650,000 BTU's without certification located at boiler room/ dry storage. Hotels & Restaurants DDM Chi, inform	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2337171 SNDWCH MIAMI
 License Type: Permanent Food Service 9420 NW 41 ST #115, DORAL 33178

Inspection Date: 03/07/2024 Inspection Number: 3383967 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. mation visit: http://www.myfloridalicense.com/DBPR/hotels-restaurants/ " Observed 2 boiler units at 650,000	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2337176		TRATTORIA DAL PLIN	
License Type: Permanent Food Service		9420 NW 41 ST #109, DORAL 33178	
Inspection Date: 03/07/2024	Inspection Number: 3383968	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boiler units at 650,000 BTU's without certification located at boiler room/ dry storage. Hotels & Restaurants DDM Chi, inform	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2337316		BANDIDOS TAQUERIA	
License Type: Permanent Food Service		9420 NW 41 ST UNIT 111, DORAL 33178	
Inspection Date: 03/07/2024	Inspection Number: 3420610	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boiler units at 650,000 BTU's without certification located at boiler room/ dry storage. Hotels & Restaurants DDM Chi, inform	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2360722		OASIS DEL SABOR	
License Type: Mobile Food Dispensing Vehicle		14605 SW 104 ST, MIAMI 33186	
Inspection Date: 03/08/2024	Inspection Number: 1285623	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LODENQUAI, BARRINGTON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2361092		ZERO DIETA	
License Type: Mobile Food Dispensing Vehicle		12700 SW 128 ST, MIAMI 33186	
Inspection Date: 03/05/2024	Inspection Number: 1283176	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LODENQUAI, BARRINGTON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2615054		LA GRAN PARADA FOOD STORE	
License Type: Permanent Food Service		5266 BEACH BLVD, JACKSONVILLE 32207	
Inspection Date: 03/07/2024	Inspection Number: 3393747	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: ESPINOSA-BECKERT, ILIANA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By entrance to kitchen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2609884		BONO'S BBQ	
License Type: Permanent Food Service		5711 BOWDEN RD #19, JACKSONVILLE 322166160	
Inspection Date: 03/04/2024	Inspection Number: 3389150	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VILBRUN, JOSUE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door near restrooms blocked with stored cases of to go containers in hallway	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2615693		SALSAS MEXICAN RESTAURANT	
License Type: Permanent Food Service		7083 COLLINS ROAD STE 106-108, JACKSONVILLE 32244	
Inspection Date: 03/05/2024	Inspection Number: 3400777	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit door by restrooms blocked by bikes and mop buckets.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2652692		TACOS EL BUEN	
License Type: Mobile Food Dispensing Vehicle		8866 BAYMEADOWS RD, JACKSONVILLE 32256	
Inspection Date: 03/04/2024	Inspection Number: 1285480	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BADDING, MELANIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-01-4	No portable fire extinguisher present. For reporting purposes only. No fire extinguisher present during inspection. Person in charge states will have by end of week.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Flagler County

License Number: 2800801

NAPOLI PIZZA

License Type: Permanent Food Service

4845 BELLE TERRE PKWY, SUITE B, PALM COAST 32164

Inspection Date: 03/04/2024

Inspection Number: 3399807

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARTMANN, MICHELLE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Back door blocked by boxes. Person in charge moved all boxes. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3916171

TASTE

License Type: Permanent Food Service

513 S FLORIDA AVE, TAMPA 33602

Inspection Date: 03/04/2024

Inspection Number: 3409566

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AIELLO, ROCCI

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Operator will provide information that they may not be boilers at next inspection. ****Repeat Violation****

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Lee County

License Number: 4603046

GATEWAY GOLF

License Type: Permanent Food Service

12091 GATEWAY GREENS DR, FORT MYERS 33913

Inspection Date: 03/06/2024

Inspection Number: 3353275

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DOMKOWSKI, DANIEL

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Carts and equipment blocking marked exit behind bar.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Levy County

License Number: 4800593

BEEF'O'BRADY'S

License Type: Permanent Food Service

7050 NW 140 ST, CHIEFLAND 32626

Inspection Date: 03/04/2024

Inspection Number: 3358969

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BERRY, JOHNNY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Red fire extinguisher gauge on wall in kitchen near back door in red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5814039		SUNSHINE SOUL FOOD CAFÉ	
License Type: Permanent Food Service		2528 W COLONIAL DR SUITE #B, ORLANDO 32804	
Inspection Date: 03/04/2024	Inspection Number: 3380718	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: ANDINO, CATHERINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In storage area **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5813545		MARITA'S LATIN BITES	
License Type: Permanent Food Service		9446 E COLONIAL DR, ORLANDO 32817	
Inspection Date: 03/04/2024	Inspection Number: 3373442	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MESA, NICOLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5814733		BURNTWOOD TAVERN	
License Type: Permanent Food Service		5078 DR PHILLIPS BLVD, ORLANDO 32819	
Inspection Date: 03/07/2024	Inspection Number: 3388824	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WOOD, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-05-4	Flammables/combustibles stored near a source of ignition. For reporting purposes only. -cooking spray can up next to bottom section of flat top grill near open flame underneath. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5814224		POP-BAR	
License Type: Permanent Food Service		8200 VINELAND AVE #162, ORLANDO 32821	
Inspection Date: 03/05/2024	Inspection Number: 3339808	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ZAPATA, MAUREEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By the entrance	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Orange County

License Number: 5811626

PANDA EXPRESS #1304

License Type: Permanent Food Service

688 N ALAFAYA TRAIL SPC #110, ORLANDO 32828

Inspection Date: 03/08/2024

Inspection Number: 3397082

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AZMY, DINA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
vacuum machine and mop bucket front of exit door . ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5909573 EL PALACIO BUFFET
 License Type: Permanent Food Service 909 VINE ST, KISSIMMEE 34741

Inspection Date: 03/07/2024 Inspection Number: 3390477 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Outlet plate missing from behind bottom shelf.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5910517 CHINO RICO
 License Type: Permanent Food Service 1315 N JOHN YOUNG PKWY, KISSIMMEE 34741

Inspection Date: 03/04/2024 Inspection Number: 3376737 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Fryer in new beverage dessert area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6217758

SHAKER & PEEL

License Type: Permanent Food Service

3150 TAMPA RD STE 12, OLDSMAR 34677

Inspection Date: 03/06/2024

Inspection Number: 3403003

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SPENCER, HALEE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804763 ICHIBAN RESTAURANT
 License Type: Permanent Food Service 2724 STICKNEY POINTE RD, SARASOTA 34231

Inspection Date: 03/08/2024 Inspection Number: 3394541 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RODARTE, ERIC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Observed the exit door in the rear of the dining room locked. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6801915 SARASOTA SPORTS CLUB
 License Type: Permanent Food Service 3600 TORREY PINES BLVD, SARASOTA 34238

Inspection Date: 03/08/2024 Inspection Number: 3394958 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: CATTLEY, RAYMOND

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.Observed Fire extinguisher on floor near hand wash sink in preparation area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905177

SANFORD BREWING COMPANY

License Type: Permanent Food Service

400 S SANFORD AVE, SANFORD 32771

Inspection Date: 03/04/2024

Inspection Number: 3361830

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JENKINS, ELAINE

Violation Code

Observation

Violation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
-certificate expired 8/20/22

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

St. Lucie County

License Number: 6605228

TREASURE COAST BAGEL BAKERY

License Type: Permanent Food Service

1401 US-1 STE 1471, FORT PIERCE 34946

Inspection Date: 03/06/2024

Inspection Number: 3396931

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Flat griddle to cook eggs infrared burners to boil potatoes and macaroni in kitchen area. Spoke with L

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405261 DELICIAS CENTROAMERICANAS LLC
 License Type: Permanent Food Service 722 MASON AVE, DAYTONA BEACH 32117

Inspection Date: 03/08/2024 Inspection Number: 3400857 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Tabletop fryer not under hood suppression system. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406052 MIKE'S MUNCHIES
 License Type: Permanent Food Service 1045 MASON AVE, DAYTONA BEACH 32117

Inspection Date: 03/07/2024 Inspection Number: 3360645 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.