

Alachua County

License Number: 1101214

WENDYS OLD FASHIONED HAMBURGER

License Type: Permanent Food Service

6700 NEWBERRY RD, GAINESVILLE 326054313

Inspection Date: 03/13/2024

Inspection Number: 3404222

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
By the kitchen back door yellow arrow in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2103371	VAN VAN CUBAN CAFÉ
License Type: Permanent Food Service	2500 TAMiami TRL N STE 111, NAPLES 34103

Inspection Date: 03/12/2024	Inspection Number: 3407798	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MEADE, ARTHUR			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Near reach in freezer, two propane tanks observed	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2102827	SWFL CATERING AND EVENTS LLC
License Type: Catering	2196 AIRPORT RD S, NAPLES 34112

Inspection Date: 03/12/2024	Inspection Number: 1126751	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRAVES, PETER			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Flammables stored near a source of ignition. For reporting purposes only. In the kitchen propane tanks are stored between the deep fryer and the convection ovens. Operator removed the propane tanks from inside the kitchen. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326798 FRITANGA LA FUENTE
License Type: Permanent Food Service 4353 NW 7TH ST, MIAMI 33126

Inspection Date: 03/12/2024 Inspection Number: 3411560 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FICHTER, GARRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Near doorway to rear prep room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335311 DELIGHTS OF BEIRUT
License Type: Permanent Food Service 1223 W FLAGLER ST, MIAMI 33135

Inspection Date: 03/12/2024 Inspection Number: 3420554 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed establishment using a portable gas fryer without hood on a table. During the time of the inspection, observed employee frying fries.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326487 OH MEXICO AT MERCATO DELLA PESCHERIA
License Type: Permanent Food Service 410-412 ESPANOLA WAY, MIAMI BEACH 33139

Inspection Date: 03/11/2024 Inspection Number: 3384552 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SWIGERT, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed at the drink station.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335291 FORUM - BAR
License Type: Permanent Food Service 3300 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 03/04/2024 Inspection Number: 3392712 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
Inspector Name: GATO, RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed missing extinguisher (second floor in front of the bar, next to the AHU room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2314774 THE RICKENBACKER
 License Type: Permanent Food Service 3900 NW 21 ST, MIAMI 33142

Inspection Date: 03/12/2024 Inspection Number: 3404611 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: COREY, DEREK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -marked exit path blocked by carts, operator relocated carts **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2360722 OASIS DEL SABOR
 License Type: Mobile Food Dispensing Vehicle 14605 SW 104 ST, MIAMI 33186

Inspection Date: 03/08/2024 Inspection Number: 1285623 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615940 FANCY SUSHI ASIAN FUSION
 License Type: Permanent Food Service 8324 MERCHANTS WAY 1, JACKSONVILLE 32222

Inspection Date: 03/13/2024 Inspection Number: 3402716 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver fire extinguisher by cook line.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612637 BONOS PIT BAR-B-Q
 License Type: Permanent Food Service 10065 SKINNER LAKE DR, JACKSONVILLE 32246

Inspection Date: 03/11/2024 Inspection Number: 3372948 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JEFFERS, MARY-BETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank stored in front counter area used to light wood at front smoker area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3919071 UNION NEW AMERICAN
 License Type: Permanent Food Service 1111 N WESTSHORE BLVD, TAMPA 33607

Inspection Date: 03/12/2024 Inspection Number: 3399358 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MOULDER, BRITTANY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a small fryer located on the cookline sushi counter and 1 fryer on back dessert counter	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906543 BAR 700
 License Type: Permanent Food Service 700 N WESTSHORE BLVD, TAMPA 33609

Inspection Date: 03/15/2024 Inspection Number: 3404394 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BUSHEY, CHRISTOPHER MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Lee County

License Number: 4650736

ARIAS'S PUPUSAS

License Type: Mobile Food Dispensing Vehicle

1501 ORTIZ AVE, FORT MYERS 33905

Inspection Date: 03/09/2024

Inspection Number: 1273892

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: FREED, JOSEPH

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tanks stored within structure.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Levy County

License Number: 4800649

ZAXBY'S

License Type: Permanent Food Service

1515 NW 25 AVE, CHIEFLAND 32626

Inspection Date: 03/11/2024

Inspection Number: 3420466

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BERRY, JOHNNY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher on floor near mop sink in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105593

NONNA'S PIZZA AND RESTAURANT LLC

License Type: Permanent Food Service

7604 CORTEZ RD W STE 10, BRADENTON 34210

Inspection Date: 03/14/2024

Inspection Number: 3420632

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: SURWILLO, JACQUELINE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Exit door in the dry storage area blocked by a preparation table.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5427971

LAZY DAYS SOUTH

License Type: Permanent Food Service

725 11TH STREET OCEAN, MARATHON 33050-2044

Inspection Date: 03/12/2024

Inspection Number: 3332651

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
Observed a electric outlet with no cover and wires hanging out of the outlet box next to microwave oven .

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5813418 LOS GENERALES
 License Type: Permanent Food Service 2901 CURRY FORD RD #211 A, ORLANDO 32806

Inspection Date: 03/15/2024 Inspection Number: 3413358 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Side exit door, marked with an Exit sign, has chairs and high chairs in front of door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5815432 CHURCH'S CHICKEN
 License Type: Permanent Food Service 2414 W OAKRIDGE ROAD UNIT 130, ORLANDO 32809

Inspection Date: 03/15/2024 Inspection Number: 3397837 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GREENE, MARVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Both extinguishers next to back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810224 LAKE BUENA VISTA RESIDENCE INN
 License Type: Permanent Food Service 11450 MARBELLA PALM CT, ORLANDO 32836

Inspection Date: 03/12/2024 Inspection Number: 3375529 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificates are expired 3/3/2024 Spoke to engineering. - From follow-up inspection 2024-03-12: Operator boiler certificates are expired 3/3/2024 **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificates are expired 3/3/2024 Spoke to engineering.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificates are expired 3/3/2024 Spoke to engineering. - From follow-up inspection 2024-03-12: Operator boiler certificates are expired 3/3/2024 **Time Extended** - From follow-up inspection 2024-03-13: Operator boiler certificates are expired 3/3/2024 **Time Extended**	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Osceola County

License Number: 5911073

EL TENAMPA MEXICAN RESTAURANT

License Type: Permanent Food Service

4563 W IRLO BRONSON MEM HWY, KISSIMMEE 34746

Inspection Date: 03/12/2024

Inspection Number: 3399037

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: PICHARDO, RENEE

Violation Code

Observation

Violation Citation

48-04-4

Gas water heater venting into kitchen. Vent stack not over water heater vent

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6019476

HAMPTON INN WEST PALM BEACH CENTRAL AIRPORT

License Type: Permanent Food Service

1601 WORTHINGTON RD, WEST PALM BEACH 33409

Inspection Date: 03/15/2024

Inspection Number: 3377043

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANCE, GASTON

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Pasco County

License Number: 6100318

SUNNYSIDE UP

License Type: Permanent Food Service

14148 US 19 N, HUDSON 34667

Inspection Date: 03/11/2024

Inspection Number: 3403876

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: EASLER, VERONICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked at rear exit door off hallway leading to bathrooms with tables, a fridge, and decoration. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-02-4	Observed scorch marks and fire damage on outer shed ceiling and walls directly outside of rear kitchen door containing the mop sink and water heater. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-02-4	- From initial inspection : Observed scorch marks and fire damage on outer shed ceiling and walls directly outside of rear kitchen door containing the mop sink and water heater. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2024-03-15: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6217638 11 CHICKS WHOLESLES DIV
License Type: Permanent Food Service 199 DR MLK JR ST N, ST. PETERSBURG 33701

Inspection Date: 03/13/2024 Inspection Number: 3381258 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MURPHY, JAMES

Violation Code	Observation	Violation Citation
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on floor in corner of dining room. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door in kitchen is blocked by food prep tables. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216922 DUNKIN DONUTS
License Type: Permanent Food Service 4599 66TH ST, KENNETH CITY 33709

Inspection Date: 03/13/2024 Inspection Number: 3420919 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOWEY, JANINE

Violation Code	Observation	Violation Citation
46-04-4	Exit door locked. For reporting purposes only. Exit door blocked with trash bin. Manager moved trash bin. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804794

HERON CREEK GOLF & COUNTRY CLUB

License Type: Permanent Food Service

5301 HERON CREEK BLVD, NORTH PORT 34287

Inspection Date: 03/13/2024

Inspection Number: 3402607

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TARTAGLIONE, EVA

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed vac master equipment on counter next to two compartment sink, with no splash guard separating unit, plugged into extension cord running in to ceiling.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905476 AN VI VIETNAMESE FOOD & CRAWFISH CAJUN
 License Type: Permanent Food Service 1052 STATE ROAD 436, CASSELBERRY 32707

Inspection Date: 03/15/2024 Inspection Number: 3410240 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: VO, STEVE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - electric counter top fryer - electric counter top flat top grill	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6904941 LA MEXICANA #7 RESTAURANT
 License Type: Permanent Food Service 2715 S ORLANDO DR, SANFORD 32773

Inspection Date: 03/11/2024 Inspection Number: 3410683 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Missing box cover at the bar (wall at the ice bin)	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

