

Alachua County

License Number: 1103578

HANA SUSHI

License Type: Permanent Food Service

3147 SW 45 ST STE 10, GAINESVILLE 32608

Inspection Date: 04/01/2024

Inspection Number: 3417902

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed: the fire extinguisher by the back door indicates it is in the recharge zone, and the pin was pulled.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1305350 EL RODEO TEQUILA BAR AND GRILL INC
 License Type: Permanent Food Service 1136 THOMAS DR, PANAMA CITY 32408

Inspection Date: 04/02/2024 Inspection Number: 3418133 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by fry station in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1350395 EL RODEO TEQUILA BAR & GRILL
 License Type: Mobile Food Dispensing Vehicle 1136 THOMAS DR, PANAMA CITY BEACH 32408

Inspection Date: 04/02/2024 Inspection Number: 1283979 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by door. Portable fire extinguisher handle broken by hand wash sink.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305535 DUNKIN DONUTS
 License Type: Permanent Food Service 2230 S HWY 77 #102, LYNN HAVEN 32444

Inspection Date: 04/01/2024 Inspection Number: 3422876 Inspection Type: Complaint Partial Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LYNN, NICKOLAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Wires hanging from dining room ceiling in path to bathroom. Foreman put wires higher up during inspection. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621208 CLUB LEVEL PRIVATE CLUB
 License Type: Permanent Food Service 2555 PANTHER PKWY, SUNRISE 33323
 Inspection Date: 04/02/2024 Inspection Number: 3328641 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIGHTY, NICOLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1623019 CLUB 954
 License Type: Permanent Food Service 1 PANTHER PKWY, SUNRISE 33323
 Inspection Date: 04/02/2024 Inspection Number: 3328626 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIGHTY, NICOLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1625192 CLUB PREP KITCHEN
 License Type: Permanent Food Service 1 PANTHER PKWY, SUNRISE 33323
 Inspection Date: 04/02/2024 Inspection Number: 3365355 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MIGHTY, NICOLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Charlotte County

License Number: 1801450 ASIA CAFE
 License Type: Permanent Food Service 1441 TAMIAMI TRL, PORT CHARLOTTE 33948

Inspection Date: 04/03/2024 Inspection Number: 3404265 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: TARTAGLIONE, EVA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed hood suppression system fan not working in kitchen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1801733 TIJUANA FLATS
 License Type: Permanent Food Service 1100 EL JOBEAN RD STE 102, PORT CHARLOTTE 33948

Inspection Date: 04/03/2024 Inspection Number: 3402405 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: RODARTE, ERIC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked by cardboard boxes . For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2336191		MR C 4TH FLOOR PANTRY KITCHEN	
License Type: Permanent Food Service		2988 MCFARLANE RD, MIAMI 33133	
Inspection Date: 04/03/2024	Inspection Number: 3402826	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LODENQUAI, BARRINGTON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2321924		SARA SHARPE CATERING	
License Type: Permanent Food Service		3328 SW 23 TERR, MIAMI 331453128	
Inspection Date: 04/04/2024	Inspection Number: 3401444	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed the establishment with a portable grease fryer without a hood system. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2336603		PURA VIDA MIAMI	
License Type: Permanent Food Service		8400 NW 53 ST UNIT F108, DORAL 33166	
Inspection Date: 04/05/2024	Inspection Number: 3401328	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone located by rear door exit	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2324045		PATACON RESTAURANT 2	
License Type: Permanent Food Service		7902 NW 36 ST, MIAMI 33166	
Inspection Date: 04/03/2024	Inspection Number: 3377098	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MIRABAL, MAYRELIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed garbage can in front of exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2337177

SUSHI SAKE

License Type: Permanent Food Service

9240 NW 41 ST #103, DORAL 33178

Inspection Date: 04/02/2024

Inspection Number: 3385178

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 2 boiler units at 650,000 BTU's without certification located at boiler room/ dry storage.
Hotels & Restaurants DDM Chi, inform

61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Duval County

License Number: 2613538 V PIZZA
 License Type: Catering 1509 HENDRICKS AVE, JACKSONVILLE 32207

Inspection Date: 04/01/2024 Inspection Number: 1126743 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By cook line **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612320 FREQUENCY RESTAURANT & LOUNGE
 License Type: Permanent Food Service 2101 DIXIE CLIPPER RD, JACKSONVILLE 32218

Inspection Date: 04/01/2024 Inspection Number: 3389522 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: MERCER, THOMAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Both boiler certificates expired 3/17/2024. Operator stated they are waiting on new certificates.	61C-1.004(10) FAC Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Highlands County

License Number: 3850188

CARNITAS EL PRIMO

License Type: Mobile Food Dispensing Vehicle

2050 US HWY 27 N, SEBRING 33870

Inspection Date: 04/05/2024

Inspection Number: 1286052

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

45-01-4 No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3919063

SMALL GIANT & WINE ON WATER

License Type: Permanent Food Service

1051 WATER ST, TAMPA 33602

Inspection Date: 04/02/2024

Inspection Number: 3413368

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AIELLO, ROCCI

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 4 Propane tanks up stairs storage
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4651479

GRANDMA'S FOOD

License Type: Mobile Food Dispensing Vehicle

11770 METRO PKWY UNIT A, FORT MYERS 33966

Inspection Date: 04/04/2024

Inspection Number: 1283761

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WALTER, KAYLA

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed gas tank inside food truck.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4702594

HAYWARD HOUSE

License Type: Permanent Food Service

228 S ADAMS ST, TALLAHASSEE 32301

Inspection Date: 04/03/2024

Inspection Number: 3408979

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HAND, NATASHA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed fire extinguisher in red Near managers office.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5203053

THE BRICK CITY LODGE

License Type: Permanent Food Service

36 S MAGNOLIA AVE, OCALA 34471

Inspection Date: 04/01/2024

Inspection Number: 3412026

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRES, WILLIAM

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Observed a 20# LP gas tank located in heater in hallway next to restroom.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5650304 THE JDC GROUP UNLIMITED LLC
 License Type: Mobile Food Dispensing Vehicle 102 HARBOR BLVD STE Z, DESTIN 32541

Inspection Date: 04/04/2024 Inspection Number: 1273162 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: STEINMAN, MARC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed - Fryer in use under hood without suppression system.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5650322 WAVE ACAI
 License Type: Mobile Food Dispensing Vehicle 104 HARBOR BLVD, DESTIN 32541

Inspection Date: 04/04/2024 Inspection Number: 1279036 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: STEINMAN, MARC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Flat Top grill added to cook raw proteins.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5910377

TROPICO MOFONGO LATIN FOOD

License Type: Permanent Food Service

3160 VINELAND RD UNIT 2, KISSIMMEE 34746

Inspection Date: 04/04/2024

Inspection Number: 3409676

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PICHARDO, RENEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Dish area - blocked partially by storage racks, rolling rack, plastic containers	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6022337

TROPICAL ISLAND RESTAURANT

License Type: Permanent Food Service

126 W BOYNTON BEACH BLVD, BOYNTON BEACH 33435

Inspection Date: 04/01/2024

Inspection Number: 3409238

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Hot plate utilized to cooked eggs with oils.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215389

SEA WORTHY FISH BAR

License Type: Permanent Food Service

1110 PINELLAS BAYWAY S STE 206, TIERRA VERDE 33715

Inspection Date: 04/03/2024

Inspection Number: 3353133

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: HUMPHREY, TERRENCE

Violation Code

Observation

Violation Citation

49-01-4

- From initial inspection : Flammables stored/debris present in meter room. For reporting purposes only. 3 propane tanks stored in meter room. Operator will alert property manager to have them removed. - From follow-up inspection 2024-04-03: **Time

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Sarasota County

License Number: 6804736	MARCELS		
License Type: Permanent Food Service	1568 MAIN ST, SARASOTA	34236	
Inspection Date: 04/04/2024	Inspection Number: 3403823	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MCKEON, MICHAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Owner placed the tank outside. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6804103	LIBBY'S NEIGHBORHOOD BRASSERIE		
License Type: Permanent Food Service	1917 S OSPREY AVE, SARASOTA	34239	
Inspection Date: 04/01/2024	Inspection Number: 3403697	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CATTLEY, RAYMOND			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.Observed fire extinguisher on floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6804954	FAFA INC CHINA BUFFET		
License Type: Permanent Food Service	4411 AIDAN LN, NORTH PORT	34287	
Inspection Date: 04/03/2024	Inspection Number: 3406940	Inspection Type: Routine - Food	Inspection Disposition: Emergency order recommended
Inspector Name: RODARTE, ERIC			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Rear exit door locked with a sliding bolt lock. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
46-04-4	- From initial inspection : Rear exit door locked with a sliding bolt lock. For reporting purposes only. - From follow-up inspection 2024-04-04: Observed rear exit door locked. Not open for business at time of call back inspection.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
46-04-4	- From initial inspection : Rear exit door locked with a sliding bolt lock. For reporting purposes only. - From follow-up inspection 2024-04-04: Observed rear exit door locked. Not open for business at time of call back inspection. - From follow-	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Sarasota County

License Number: 6805659

CULVERS

License Type: Permanent Food Service

5648 TUSCOLA BLVD, NORTH PORT 34287

Inspection Date: 04/02/2024

Inspection Number: 3422600

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TARTAGLIONE, EVA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked with broken down boxes. Observed operator removing boxes out of the way, clearing a path on his own. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905261

5TH ELEMENT AUTHENTIC INDIAN RESTAURANT

License Type: Permanent Food Service

1133 RINEHART RD, SANFORD 32771

Inspection Date: 04/04/2024

Inspection Number: 3408197

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JENKINS, ELAINE

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
 -several empty propane tanks stacked at back door. Operator states they were left there by a former employee.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.