



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Broward**

License Number: 1625088

**JUST 1 MORE**

License Type: Food

3074 NE 33 AVE , FORT LAUDERDALE 33308

Insp Date: 05/15/2024

Inspection Number: 3422722

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed flat top no hood suppression system

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621850

**POOL BAR**

License Type: Food

1 N FT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 05/15/2024

Inspection Number: 3422182

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. \*\*Repeat Violation\*\*

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Broward**

License Number: 1621851

**BANQUET KITCHEN**

License Type: Food

1 N FT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 05/15/2024

Inspection Number: 3422070

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  
**\*\*Repeat Violation\*\***

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1622847

**CLUB LOUNGE**

License Type: Food

1 N FT LAUDERDALE BLVD , FORT LAUDERDALE 33304

Insp Date: 05/15/2024

Inspection Number: 3422077

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  
**\*\*Repeat Violation\*\***

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Broward**

License Number: 1621852

**BURLOCK COAST**

License Type: Food

1 N FT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 05/15/2024

Inspection Number: 3344713

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. <b>**Repeat Violation**</b> - From follow-up inspection 2024-05-15: Observed same. <b>**Time Extended**</b>	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	--

License Number: 1621852

**BURLOCK COAST**

License Type: Food

1 N FT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 05/16/2024

Inspection Number: 3422079

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. <b>**Repeat Violation**</b> - From follow-up inspection 2024-05-16: Observed same. <b>**Time Extended**</b>	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Broward**

License Number: 1621852

**BURLOCK COAST**

License Type: Food

1 N FT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 05/15/2024

Inspection Number: 3422079

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. <b>**Repeat Violation**</b>	Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	--

License Number: 2322639

**SARUSSI'S CAFE**

License Type: Food

9836 SW 40 STREET , MD MIAMI 33165

Insp Date: 05/17/2024

Inspection Number: 3417432

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Dining area.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2322475

**CORAL GABLES GOLF AND COUNTRY CLUB**

License Type: Food

997 N GREENWAY DR , CORAL GABLES 33134

Insp Date: 05/14/2024

Inspection Number: 3414796

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed at kitchen.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2360606

**ANTOJITOS MIXTOS CORP**

License Type: Food

12491 SW 130 ST , MIAMI 33186

Insp Date: 05/15/2024

Inspection Number: 1281372

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only. Observed no k class fire extinguisher present, fryer present at cookline, no fire suppression system in place.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332418

**FIFI'S ON THE BEACH**

License Type: Food

6930-34 COLLINS AVE , MIAMI BEACH 33141

Insp Date: 05/10/2024

Inspection Number: 3420532

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed by the dishwasher machine. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2336806

**KETO KITCHEN MIAMI**

License Type: Food

9640 CORAL WAY , MIAMI 33165

Insp Date: 05/14/2024

Inspection Number: 3417678

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed across from back exit door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337884

**BAIRES GRILL**

License Type: Food

8551 NW 53 ST BLDG A STE 103 , DORAL 33166

Insp Date: 05/14/2024

Inspection Number: 3408946

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone located by mop sink.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 05/18/2024

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2331847

**RESTAURANT**

License Type: Food

10295 COLLINS AVE , BAL HARBOUR 33154

Insp Date: 05/17/2024

Inspection Number: 3417239

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificates expired, FL 121557 2/2/2024, 121558 2/2/2024, 121560 2/2/2024, 121591: 2/2/2024, 024076 2/18/2022.

Reporting: (10) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspectors boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2333786

**STG RESTAURANT LLC**

License Type: Food

290 NW 71 ST , MIAMI 33150

Insp Date: 05/14/2024

Inspection Number: 3417118

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed in the kitchen.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2336230

**CHEF YANK CORPORATION**

License Type: Food

7900 NW 27TH AVE F06 , MIAMI 33147

Insp Date: 05/10/2024

Inspection Number: 3417677

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Observed in the kitchen. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2337884

**BAIRES GRILL**

License Type: Food

8551 NW 53 ST BLDG A STE 103 , DORAL 33166

Insp Date: 05/14/2024

Inspection Number: 3408946

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 4 tanks by mop sink.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2360891

**EL SALTO DEL TIGRE**

License Type: Food

12491 SW 130 ST , MIAMI 33186

Insp Date: 05/10/2024

Inspection Number: 1282744

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-01-4

- From initial inspection : No portable fire extinguisher present. For reporting purposes only.Observed no K Class fire extinguisher at the time of the inspection,fryers present. - From follow-up inspection 2024-05-10: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Dade**

License Number: 2332418

**FIFI'S ON THE BEACH**

License Type: Food

6930-34 COLLINS AVE , MIAMI BEACH 33141

Insp Date: 05/10/2024

Inspection Number: 3328248

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher located next to the dishwasher machine . - From follow-up inspection 2024-05-10: **\*\*Time Extended\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Duval**

License Number: 2613152

**SONNYS REAL PIT BBQ**

License Type: Food

12719 ATLANTIC BLVD , JACKSONVILLE 32225

Insp Date: 05/17/2024

Inspection Number: 3406140

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in red zone by back door.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2609126

**HUFFMAN CATERING**

License Type: Food

5102 TIMUQUANA RD UNIT 5 , JACKSONVILLE 32210

Insp Date: 05/16/2024

Inspection Number: 3422643

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tanks stored in unused walk-in cooler. \*\*Repeat Violation\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2616030

**EL QUETZAL CUISINE**

License Type: Food

10916 ATLANTIC BLVD STE 1 , JACKSONVILLE 32225

Insp Date: 05/16/2024

Inspection Number: 3411686

Insp Type: Routine - Food

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Large helium propane tank stored next to restroom area. Manager removed from inside building

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Hernando**

License Number: 3750321

**NEW YORK DOG HOUSE**

License Type: Food

13251 CORTEZ BLVD , SPRING HILL 34613

Insp Date: 05/15/2024

Inspection Number: 1286850

Insp Type: Complaint Partial

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system working. Notified Fire AHJ. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4604104

**ALVA COUNTRY DINER**

License Type: Food

21200 SR 80 , ALVA 33920

Insp Date: 05/14/2024

Inspection Number: 3425712

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed outlet cover for light switch inside walk in cooler for walk in freezer broken.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4604104

**ALVA COUNTRY DINER**

License Type: Food

21200 SR 80 , ALVA 33920

Insp Date: 05/16/2024

Inspection Number: 3425712

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Observed outlet cover for light switch inside walk in cooler for walk in freezer broken. - From follow-up inspection 2024-05-16: Observed outlet cover for light switch inside walk in cooler for walk in freezer broken. **\*\*Time Extended\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Orange**

License Number: 5815432

**CHURCH'S CHICKEN**

License Type: Food

2414 W OAKRIDGE ROAD UNIT 130 , ORLANDO 32809

Insp Date: 05/15/2024

Inspection Number: 3397837

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Both extinguishers next to back door. - From follow-up inspection 2024-05-15: <b>**Time Extended**</b>	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 5911538

**HOOTERS OF KISSIMMEE**

License Type: Food

8207 W IRLO BRONSON MEMORIAL HWY , KISSIMMEE 34747

Insp Date: 05/13/2024

Inspection Number: 3405157

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.- next to back door	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number:

**REYNA'S BAKERY CORP**

License Type: Food

1975 S CONGRESS AVE , WEST PALM BEACH 33406

Insp Date: 05/14/2024

Inspection Number: 3425346

Insp Type: Food-Licensing Inspection

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.At rear exit; door blocked by storage of multiple unnecessary items.Operator moved some items, one side of door unblocked. <b>**Corrective Action Taken**</b>	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Report Date: 05/18/2024

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Pasco**

License Number: 6113004

**HERSCHEL'S SCRATCH KITCHEN**

License Type: Food

5749 MAIN ST , NEW PORT RICHEY 34652

Insp Date: 05/17/2024

Inspection Number: 3407931

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.Observed 2-20lb propane tanks under front counter

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Pinellas**

License Number: 6216189

**EL CARRIEL**

License Type: Food

1215 N MARTIN LUTHER KING , CLEARWATER 33755

Insp Date: 05/10/2024

Inspection Number: 3404908

Insp Type: Routine - Food

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone next prep food area. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6252347

**GRANT'S CRAB & SEAFOOD MOBILE**

License Type: Food

13030 STARKEY RD 3 , LARGO 33773

Insp Date: 05/13/2024

Inspection Number: 1274964

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone - Class K . For reporting purposes only. Reviewed with manager

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216189

**EL CARRIEL**

License Type: Food

1215 N MARTIN LUTHER KING , CLEARWATER 33755

Insp Date: 05/13/2024

Inspection Number: 3404908

Insp Type: Routine - Food

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone next prep food area. For reporting purposes only. - From follow-up inspection 2024-05-13: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Putnam**

License Number: 6400935

**POWER UP CAFE**

License Type: Food

890 N HWY 17 , PALATKA 32177

Insp Date: 05/16/2024

Inspection Number: 3425153

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

51-04-4

No child labor law poster. For reporting purposes only.No child labor law poster present.

Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.

License Number: 6804845

**MAMA LEONES**

License Type: Food

2300 TAMIAMI TRAIL N , NOKOMIS 34275

Insp Date: 05/10/2024

Inspection Number: 3425402

Insp Type: Food-Licensing Inspection

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked in the hallway behind the office. For reporting purposes only. - From follow-up inspection 2024-05-10: \*\*Time Extended\*\*

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**Seminole**

License Number: 6903879

**PADDY'S PUB**

License Type: Food

924 W SR 436 #1100 , ALTAMONTE SPRINGS 32714

Insp Date: 05/16/2024

Inspection Number: 3333735

Insp Type: Routine - Food

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank under 3 comp sink. Operator immediately removed to outside **\*\*Corrected On-Site\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**St. Johns**

License Number: 6502558

**RITAS ITALIAN WATER ICE AND FROZEN CUSTARD**

License Type: Food

840 A1A N STE 150 , PONTE VEDRA BEACH 32082

Insp Date: 05/13/2024

Inspection Number: 3409363

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

51-04-4	No child labor law poster. For reporting purposes only.	Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.
---------	---	---

License Number: 6502561

**AGRIAUTISM**

License Type: Food

14A-1 S ROSCOE BLVD , PONTE VEDRA BEACH 32082

Insp Date: 05/16/2024

Inspection Number: 3419899

Insp Type: Food-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

51-04-4	No child labor law poster. For reporting purposes only.	Reporting: Proof of age; posting of notices. (1) Any person who hires, employs, or suffers to work any child shall, in addition to the limitations provided in this part, first obtain and keep on record during the entire period of such employment proof of the child's age. This requirement shall be satisfied by (a) A photocopy of the child's birth certificate; (b) A photocopy of the child's driver's license; (c) An age certificate issued by the district school board of the district in which the child is employed, certifying the child's date of birth; or (d) A photocopy of a passport or visa which lists the child's date of birth. (2) Any person who hires, employs, or suffers to work any minor shall post at a conspicuous place on the property or place of employment, where it may be easily read, a poster notifying minors of the Child Labor Law, to be provided by the division upon request. For reporting purposes only.
---------	---	---



Division of Hotels & Restaurants

**Fire Observations Reporting**

*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS*

**St. Lucie**

License Number: 6602880

**SHINGDIG IRISH RESTAURANT & PUB**

License Type: Food

464 SW PORT ST LUCIE BLVD 115 , PORT ST LUCIE 34953

Insp Date: 05/13/2024

Inspection Number: 3425546

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Burnt electrical outlet on cooks line. - From follow-up inspection 2024-05-13: **\*\*Time Extended\*\***

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602880

**SHINGDIG IRISH RESTAURANT & PUB**

License Type: Food

464 SW PORT ST LUCIE BLVD 115 , PORT ST LUCIE 34953

Insp Date: 05/10/2024

Inspection Number: 3425546

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Burnt electrical outlet on cooks line.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.