



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Alachua

License Number: 1102956

RESIDENCE INN BY MARRIOTT

License Type: Lodging

3275 SW 40 BLVD , GAINESVILLE 32608

Insp Date: 01/23/2026

Inspection Number: 1187361

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed : The fire alarm control panel indicates room 127, living room, has a malfunction.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 1607221

FORT LAUDERDALE GRAND HOTEL

License Type: Lodging

4900 POWERLINE ROAD , OAKLAND PARK 33309

Insp Date: 01/28/2026

Inspection Number: 1189216

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1602179

FT. LAUDERDALE MARRIOTT POMPANO BEACH RESORT AND SPA

License Type: Lodging

1200 1208 N OCEAN BLVD , POMPANO BEACH 33062

Insp Date: 01/30/2026

Inspection Number: 1184147

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. ****Warning****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1622130

TAFT PROPERTY INVESTMENTS INC.

License Type: Lodging

1725 N 16 AVE MANAGER'S OFFICE, HOLLYWOOD 33020

Insp Date: 01/30/2026

Inspection Number: 1580231

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher between units 302 & 303 undercharged.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1622131

GARFIELD NAD FRIENDS VSIO LLC

License Type: Lodging

2247 TAYLOR ST , HOLLYWOOD 33020

Insp Date: 01/30/2026

Inspection Number: 1580780

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.All three fire extinguisher boxes missing extinguishers.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1622088

RIVR LOFTS

License Type: Lodging

307 SW 5 ST , FORT LAUDERDALE 33315

Insp Date: 01/23/2026

Inspection Number: 1646110

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1603260

CO-MIT APARTMENTS

License Type: Lodging

333 NW 5 ST , POMPANO BEACH 33069

Insp Date: 01/28/2026

Inspection Number: 1633284

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Observed grill with lp gas tanks stored under north side stairwell/balcony

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1612251

HORIZON CLUB

License Type: Lodging

1208 S MILITARY TRL , DEERFIELD BEACH 33442

Insp Date: 01/30/2026

Inspection Number: 1631450

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble alarm on fire panel.Maintenance said they already called

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1612422

LAQUINTA INN & SUITES

License Type: Lodging

351 W HILLSBORO BLVD , DEERFIELD BEACH 33441

Insp Date: 01/27/2026

Inspection Number: 1246216

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

04-03-4	Smoke detector/alarm in guest room 204, damaged as to appear to be inoperable. For reporting purposes only.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2331373

FORMA MIAMI

License Type: Lodging

2900 BISCAYNE BLVD , MIAMI 33137

Insp Date: 01/29/2026

Inspection Number: 1646255

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2304345

HOLIDAY INN MIAMI BEACH OCEANFRONT

License Type: Lodging

4333 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 01/29/2026

Inspection Number: 1186987

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL130111, 124822, exp 1/9/2026

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329441

DUNNS JOSEPHINE HOTEL

License Type: Lodging

1028 N.W. 3RD AVE , MIAMI 33136

Insp Date: 01/27/2026

Inspection Number: 1189205

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2307288

MIAMI SPRINGS INN

License Type: Lodging

661 EAST DRIVE , MIAMI SPRINGS 33166

Insp Date: 01/29/2026

Inspection Number: 1244931

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguisher located between Rooms 107 and 108.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329526

BLU VACATION RENTAL

License Type: Lodging

5445 COLLINS AVE CU20 , MIAMI BEACH 33140

Insp Date: 01/28/2026

Inspection Number: 1187780

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device on extinguisher located inside hallway by CU20. Common fixtures and areas belong to Condo Association. ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2310887

RUBIN SANDRA S & LEONARD H

License Type: Lodging

16151 NE 18 PL , NORTH MIAMI BEACH 24875

Insp Date: 01/27/2026

Inspection Number: 1630385

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Apartment #2,5.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329213

HILTON GARDEN INN MIAMI BRICKELL SOUTH

License Type: Lodging

2500 BRICKELL AVENUE , MIAMI 33129

Insp Date: 01/30/2026

Inspection Number: 1187673

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2307942

MIAMI INT'L AIRPORT HOTEL

License Type: Lodging

NW 20TH STREET & LE JEUNE ROAD , MIAMI 33122

Insp Date: 01/23/2026

Inspection Number: 1186617

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329544

SIGNATURE INN BY SONESTA MIAMI

License Type: Lodging

7330 NW 36 ST , MIAMI 33166

Insp Date: 01/28/2026

Inspection Number: 1188026

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329392

KEREM NORTH BEACH APTS LLC

License Type: Lodging

7609-7617 CARLYLE AVE , MIAMI BEACH 33141

Insp Date: 01/27/2026

Inspection Number: 1635883

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310696

PINTADO APARTMENTS

License Type: Lodging

455 SW 27 AVE , MIAMI 52942

Insp Date: 01/29/2026

Inspection Number: 1567352

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed throughout the property. ****Repeat Violation**** ****Warning**** - From follow-up inspection 2026-01-29: Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed throughout the property. ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329660

BVG

License Type: Lodging

5601 NW 1 AVE , MIAMI 33127

Insp Date: 01/29/2026

Inspection Number: 1576647

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

01-06-4	<p>- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next unit #15. **Repeat Violation** - From follow-up inspection 2026-01-29: Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next unit #15. **Time Extended**</p>	<p>Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
---------	---	---

License Number: 2329485

GLOBAL AT ALTON LLC

License Type: Lodging

1700 ALTON ROAD , MIAMI BEACH 33139

Insp Date: 01/30/2026

Inspection Number: 1187112

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-01-4	<p>Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed by room 206.</p>	<p>Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
---------	--	---



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2328824

HAVANA MIAMI APTS

License Type: Lodging

826 SW 3 STREET , MIAMI 33130

Insp Date: 01/30/2026

Inspection Number: 1640801

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at fire extinguisher located at rear of main building.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2600599

DELLWOOD APTS

License Type: Lodging

2975 DELLWOOD AVE , JACKSONVILLE 32205

Insp Date: 01/30/2026

Inspection Number: 1631700

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher is in the red overcharge area closest to apartment 3.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Gilchrist

License Number: 3100004

CADILLAC MOTEL

License Type: Lodging

7490 N HWY 19 , FANNING SPRINGS 32693

Insp Date: 01/30/2026

Inspection Number: 1244757

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher missing from hook in laundry room.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 3800987

LAKESIDE COTTAGES

License Type: Lodging

740 S LAKEVIEW DR , LAKE PLACID 33852

Insp Date: 01/26/2026

Inspection Number: 1242434

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only : located at Laundry Room. Operator stated she will call them today. **Corrective Action Taken** **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lee

License Number: 4602772

LA QUINTA INN AND SUITES

License Type: Lodging

20091 SUMMERLIN RD , FORT MYERS 33908

Insp Date: 01/30/2026

Inspection Number: 1187822

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. 137013 expired 02/10/23, 137014 expired 02/10/23 Educated operator on updating boiler certifications. Establishment has work order in place and in the process of fixing. For reporting purposes only. ****Corrective Action Taken****
****Repeat Violation****

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4700572

OAKWOOD RESERVE APARTMENTS

License Type: Lodging

2616 MISSION RD , TALLAHASSEE 32304

Insp Date: 01/30/2026

Inspection Number: 1646262

Insp Type: Complaint Partial

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Extinguisher by building 52 is on the ground. ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Leon

License Number: 4702292

SOUTHGATE CAMPUS CENTER

License Type: Lodging

675 W JEFFERSON ST , TALLAHASSEE 32304

Insp Date: 01/27/2026

Inspection Number: 1636183

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the 5th floor, For reporting purposes only. 1 missing fire extinguisher on 5th floor.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4702292

SOUTHGATE CAMPUS CENTER

License Type: Lodging

675 W JEFFERSON ST , TALLAHASSEE 32304

Insp Date: 01/27/2026

Inspection Number: 1636183

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. Certificates in office and only for two boilers.

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Marion

License Number: 5200266

MAGNOLIA TRACE APARTMENTS

License Type: Lodging

2952 NE 14 ST , OCALA 34470

Insp Date: 01/30/2026

Inspection Number: 1628208

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Inaccessible fire extinguisher between unit 1 and 8 building C.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Monroe

License Number: 5402153

MARGARITAVILLE BEACH HOUSE KEY WEST

License Type: Lodging

2001 ROOSEVELT BLVD , KEY WEST 33040

Insp Date: 01/26/2026

Inspection Number: 1188380

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 5400248

BLUE MARLIN MOTEL

License Type: Lodging

1320 SIMONTON ST , KEY WEST 03114

Insp Date: 01/27/2026

Inspection Number: 1244028

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble shoot on alarm. **Repeat Violation**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 5402153

MARGARITAVILLE BEACH HOUSE KEY WEST

License Type: Lodging

2001 ROOSEVELT BLVD , KEY WEST 33040

Insp Date: 01/26/2026

Inspection Number: 1184534

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2026-01-26: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Time Extended**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Nassau

License Number: 5500464

CANTEBURY OF HILLIARD

License Type: Lodging

37119 CANTEBURY DR , HILLIARD 32046

Insp Date: 01/27/2026

Inspection Number: 1630668

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Portable fire extinguisher in pavilion/grill area in red recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500157

EASTWOOD OAKS

License Type: Lodging

37149 CODY CIRCLE , HILLIARD 32046

Insp Date: 01/28/2026

Inspection Number: 1640730

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Portable fire extinguisher near unit D1 in red recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5809006

EXTENDED STAY AMERICA #9809

License Type: Lodging

8687 COMMODITY CIR , ORLANDO 32819

Insp Date: 01/23/2026

Inspection Number: 1189188

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 5811117

SPRINGHILL SUITES ORLANDO AT SEAWORLD

License Type: Lodging

10801 INTERNATIONAL DRIVE , ORLANDO 32821

Insp Date: 01/27/2026

Inspection Number: 1189043

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4	Boiler certificate or insurance inspector's boiler report expired. 122942 expired 7/23/22 **Repeat Violation**	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Osceola

License Number: 5900879

DELTA ORLANDO CELEBRATION RESORT

License Type: Lodging

2900 PARKWAY BLVD , KISSIMMEE 34747

Insp Date: 01/26/2026

Inspection Number: 1189203

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6207416

RED ROOF INN

License Type: Lodging

4999 34 ST N , ST. PETERSBURG 33714

Insp Date: 01/23/2026

Inspection Number: 1244848

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher located on the East side of second floor walkway facing the courtyard.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6215795

STAYBRIDGE SUITES

License Type: Lodging

940 5 AVE S , ST. PETERSBURG 33705

Insp Date: 01/26/2026

Inspection Number: 1187036

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher on the third floor hallway, adjacent to room 302 in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6207769

BEACHVIEW INN

License Type: Lodging

325 S GULFVIEW BLVD , CLEARWATER BEACH 33767

Insp Date: 01/23/2026

Inspection Number: 1244074

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Floor 4 next to ice machine.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6215786

PIER HOUSE 60

License Type: Lodging

101 CORONADO DR , CLEARWATER 33767

Insp Date: 01/30/2026

Inspection Number: 1186676

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Strobe circuit yellow.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 6215810

FAIRFIELD INN AND SUITES BY MARRIOTT

License Type: Lodging

650 BAY ESPLANADE , CLEARWATER BEACH 33767

Insp Date: 01/23/2026

Inspection Number: 1187511

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6215782

PELICAN POINTE RESORT AND HOTEL

License Type: Lodging

445 GULFVIEW BLVD , CLEARWATER 33767

Insp Date: 01/28/2026

Inspection Number: 1187032

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6501614

STAYABLE ST. AUGUSTINE

License Type: Lodging

2535 SR 16 , SAINT AUGUSTINE 32092

Insp Date: 01/27/2026

Inspection Number: 1244182

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.Missing from receptacle in front of room 209

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

St. Lucie

License Number: 6601920

MOTEL 6 - FT PIERCE

License Type: Lodging

2500 PETERS RD , FORT PIERCE 34945

Insp Date: 01/28/2026

Inspection Number: 1245350

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** ****Warning**** - From follow-up inspection 2025-11-19: ****Time Extended**** - From follow-up inspection 2025-11-24: ****Time Extended**** - From follow-up inspection 2026-01-28: ****Time Extended****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406504

HILTON GARDEN INN DAYTONA BEACH OCEANFRONT

License Type: Lodging

2560 N ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 01/27/2026

Inspection Number: 1186515

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.-not functioning in unit 503, engineer replaced during inspection ****Corrected On-Site****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 01/31/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7401000

BEST WESTERN AKU TIKI INN

License Type: Lodging

2225 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 01/23/2026

Inspection Number: 1246195

Insp Type: Complaint Full

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.-suspended boiler certificates per fire Marshall database-20-00131722-001417 - From follow-up inspection 2026-01-23: **Time Extended**	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 7401000

BEST WESTERN AKU TIKI INN

License Type: Lodging

2225 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 01/26/2026

Inspection Number: 1246195

Insp Type: Complaint Full

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.-suspended boiler certificates per fire Marshall database-20-00131722-001417 - From follow-up inspection 2026-01-23: **Time Extended** - From follow-up inspection 2026-01-26: **Time Extended**	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--